

VENTILATION AUDIT REPORT

SCHOOL:	Como Public School (1605)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

1605 - Como Public School
Site Plan (10324)
















1:588

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (57.36 SQM)	 Student Space (26)	
B00A - R0004 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (56.96 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0011 - Sick Bay - (5.25 SQM)	 Student Space (2)	
B00A - R0012 - Staff Room - (19.79 SQM)	 Office (4)	
B00A - R0013 - Entry Vestibule - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (11.51 SQM)	 Office (2)	
B00A - R0015 - Principal - (15.36 SQM)	 Office (3)	
B00B - R0001 - Home Base - (47.5 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0002 - Home Base - (49.53 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0005 - Movement - (25.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Canteen - (18.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Canteen - (10.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Reading Area - (89.28 SQM)	 Student Space (41)	
B00E - R0002 - Home Base - (53.59 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0003 - Home Base - (53.59 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0004 - Practical Activities - 1hb - (22.7 SQM)	 Student Space (10)	
B00H - R0002 - Reading Area - (92.51 SQM)	 Student Space (42)	