


VENTILATION AUDIT REPORT

SCHOOL:	Como West Public School (3896)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

3896 - Como West Public School
Site Plan (10325)



1:628

Printed: 28-Jul-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (45.12 SQM)	Office (11)	
B00A - R0004 - Deputy Principal - (12.78 SQM)	Office (3)	
B00A - R0005 - Deputy Principal - (13.12 SQM)	Office (3)	
B00A - R0006 - Interview - (13.12 SQM)	Office (3)	
B00A - R0008 - Sick Bay - (8.58 SQM)	Student Space (3)	
B00A - R0009 - Clerical Office - (17.62 SQM)	Office (4)	
B00A - R0010 - Movement - (127.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (15.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Duplicating Workroom - (19.38 SQM)	Office (4)	
B00A - R0013 - Principal - (16.49 SQM)	Office (4)	
B00A - R0018 - Staff Room Annexe - (19.5 SQM)	Office (4)	
B00A - R0019 - Movement - (57.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (76.94 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0007 - Withdrawal Space - 1hb - (11.08 SQM)	Student Space (5)	
B00B - R0008 - Home Base - (74.99 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0015 - Home Base - (75.2 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0016 - Withdrawal Space - 1hb - (10.98 SQM)	Student Space (5)	
B00B - R0017 - Home Base - (75.05 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0001 - Canteen - (31.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Raised Platform - (49.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Interview - (11.7 SQM)	Office (2)	
B00C - R0019 - Communal Space - (166.85 SQM)	Student Space (77)	
B00C - R0022 - Movement - (196.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Withdrawal Space - 1hb - (5.37 SQM)	Student Space (2)	
B00D - R0004 - Home Base - (76 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0006 - Home Base - (77.42 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0008 - Withdrawal Space - 1hb - (5.74 SQM)	Student Space (2)	
B00D - R0009 - Withdrawal Space - 1hb - (5.73 SQM)	Student Space (2)	
B00D - R0011 - Home Base - (77.06 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0013 - Home Base - (77.25 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0015 - Withdrawal Space - 1hb - (5.7 SQM)	Student Space (2)	
B00E - R0006 - Withdrawal Space - 1hb - (5.8 SQM)	Student Space (2)	
B00E - R0008 - Home Base - (76.77 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R0010 - Home Base - (77.16 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R0011 - Withdrawal Space - 1hb - (5.8 SQM)	Student Space (2)	
B00F - R0007 - Clerical Office - (11.43 SQM)	Office (2)	
B00F - R0009 - Staff Kitchen - (6.14 SQM)	Office (1)	
B00L - R0001 - Reading Area - (136.85 SQM)	Student Space (63)	
B00L - R0006 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Special Programs Room - (51.83 SQM)	Student Space (24)	
B00M - R0001 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0003 - Practical Activities - 1hb - (19.93 SQM)	Student Space (9)	
B00M - R0004 - Withdrawal Space - 2hb - (11.73 SQM)	Student Space (5)	
B00M - R0005 - Home Base - (59.95 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0007 - Practical Activities - 1hb - (18.97 SQM)	Student Space (8)	
B00M - R0008 - Special Programs Room - (37.88 SQM)	Student Space (17)	
OS 602 10417 - OS 602 10417 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 12660 - OS 602 12660 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 17916 - OS 603 17916 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	