


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Concord High School (8535)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Drummoyne</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Canada Bay</b>

8535 - Concord High School  
Site Plan (10940)



1:1,294

Printed: 22-Jun-2021




## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M1001 - Movement - (16 SQM)	Not Applicable	Circulation or storage space.
B00A - M1002 - Workroom - (10.99 SQM)	Office (2)	
B00A - M1003 - Movement - (54.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Deputy Principal Office - (16 SQM)	Office (4)	
B00A - R0002 - Clinic - Boys - (14.21 SQM)	Office (3)	
B00A - R0005 - Clinic - Girls - (13.27 SQM)	Office (3)	
B00A - R0006 - Movement - (26.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Interview/Office - Type 1 - (10.96 SQM)	Office (2)	
B00A - R0008 - Interview/Office - Type 1 - (10.69 SQM)	Office (2)	
B00A - R0009 - Administration - Clerical - (14.32 SQM)	Office (3)	
B00A - R0010 - Movement - (118.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Principal Office - (22.12 SQM)	Office (5)	
B00A - R0013 - Administration - Clerical - (9.28 SQM)	Office (2)	
B00A - R0014 - Administration - Clerical - (9.02 SQM)	Office (2)	
B00A - R0015 - Administration - Clerical - (28.62 SQM)	Office (7)	
B00A - R0016 - Public Entry - (49.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Interview/Meeting - (26.02 SQM)	Office (6)	
B00A - R0021 - Movement - (37.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (23.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Seminar - (85.19 SQM)	Office (21)	
B00A - R0027 - Workroom - (52.66 SQM)	Office (13)	
B00A - R0028 - Audio Visual Workroom - (42.05 SQM)	Student Space (19)	
B00A - R0029 - Workroom - (12.99 SQM)	Office (3)	
B00A - R0030 - Main Area - (218.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Administration - Clerical - (18.36 SQM)	Office (4)	
B00A - R1001 - Seminar - (12.24 SQM)	Office (3)	
B00A - R1002 - Seminar - (9.13 SQM)	Office (2)	
B00A - R1003 - Staff Study - (11.8 SQM)	Office (2)	
B00A - R1005 - Commonroom - (20 SQM)	Office (5)	
B00A - R1006 - Commonroom - (12.78 SQM)	Office (3)	
B00A - R1007 - Commonroom - (81.98 SQM)	Office (20)	
B00A - R1008 - Movement - (59.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Senior Study - (100.43 SQM)	Office (25)	
B00A - R1012 - Senior Study - (20.3 SQM)	Office (5)	
B00A - R1015 - Movement - (35.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Ancillary Staff - (24.91 SQM)	Office (6)	
B00A - R1019 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Staff Study - (30.87 SQM)	Office (7)	
B00B - R0005 - Staff Study - (9.91 SQM)	Office (2)	
B00B - R0006 - Movement - (111.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (39.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (121.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - General Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0012 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0014 - General Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0015 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0016 - Staff Study - (37.48 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0018 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0019 - General Learning Space - (51.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0020 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0021 - General Learning Space - (50.2 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1002 - Movement - (120.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Staff Study - (34.69 SQM)	● Office (8)	
B00B - R1005 - Interview/Office - Type 1 - (10.04 SQM)	● Office (2)	
B00B - R1006 - Movement - (38.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Movement - (121.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - General Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1011 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1013 - Staff Study - (21.37 SQM)	● Office (5)	
B00B - R1014 - General Learning Space - (51.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1015 - General Learning Space - (51.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Staff Study - (37.09 SQM)	● Office (9)	
B00B - R1018 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1019 - General Learning Space - (51.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1020 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1021 - General Learning Space - (50.06 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0001 - Movement - (59.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Laboratory L.S. - (97.31 SQM) - Teaching Space: 1	● Student Space (45)	
B00C - R0007 - Preparation - (68.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Laboratory L.S. - (94.57 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0009 - Laboratory L.S. - (91.93 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0010 - Preparation - (50.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Laboratory L.S. - (92.62 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0012 - Growing/Breeding - (24.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (197.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Laboratory L.S. - (92.09 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0017 - Staff Study - (46.63 SQM)	● Office (11)	
B00C - R0018 - Dark Room - (28.06 SQM)	● Office (7)	
B00C - R1001 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1002 - General Learning Space - (55.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1003 - Movement - (66.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - General Learning Space - (51.71 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1009 - General Learning Space - (51.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1011 - Seminar - (42.75 SQM)	● Office (10)	
B00C - R1014 - General Learning Space - (53.77 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1015 - Movement - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1018 - Staff Study - (37.12 SQM)	● Office (9)	
B00C - R1019 - Interview/Office - Type 1 - (15.1 SQM)	● Office (3)	
B00C - R1020 - Movement - (131.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Art Learning Space - (64.95 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0002 - Workshop - (49.83 SQM)	● Student Space (23)	
B00D - R0004 - Art Learning Space - (65.17 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0011 - Movement - (33.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Design L.S. - (66.27 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0014 - Design L.S. - (60.83 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0017 - Movement - (40.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (109.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (88.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Art Learning Space - (63.64 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0028 - Materials Technology L.S. - (85.87 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0029 - Staff Study - (18.59 SQM)	● Office (4)	
B00D - R0031 - Materials Technology L.S. - (80.67 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0032 - Metal Technology Bay - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Materials Technology L.S. - (98.22 SQM) - Teaching Space: 1	● Student Space (45)	
B00D - R0036 - Materials Technology L.S. - (92.54 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0037 - Wood Technology Bay - (18.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Movement - (32.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Design L.S. - (65.55 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1004 - Movement - (158.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Food Technology L.S. - (100.35 SQM) - Teaching Space: 1	● Student Space (46)	
B00D - R1007 - Food Technology L.S. - (101.16 SQM) - Teaching Space: 1	● Student Space (46)	
B00D - R1008 - Food/Research Space - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Design L.S. - (63.97 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1014 - Movement - (33.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Movement - (104.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - General Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1017 - General Learning Space - (54.83 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1021 - Staff Study - (21.81 SQM)	● Office (5)	
B00E - R0001 - Multi-Purpose Space - (469.42 SQM)	● Student Space (217)	
B00E - R0005 - Stage - (65.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (51.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Study - (8.48 SQM)	● Office (2)	
B00E - R0010 - Staff Study - (8.48 SQM)	● Office (2)	
B00E - R0021 - Student Canteen - (51.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Movement - (84.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Performance Workspace - (77.17 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0002 - Practice/Seminar - (123.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R9001 - General Assistants - (6.94 SQM)	● Office (1)	
B00G - R0001 - Staff Study - (26.04 SQM)	● Office (6)	
B00G - R0002 - Music Learning Space - (71.01 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0004 - Practice/Seminar - (26.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Music Learning Space - (90.05 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0007 - Movement - (57.62 SQM)	Not Applicable	Circulation or storage space.
NS 220 13195 - NS 220 13195 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 10504 - OS 600 10504 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11104 - OS 600 11104 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11472 - OS 600 11472 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11603 - OS 600 11603 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11952 - OS 600 11952 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15200 - OS 600 15200 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15439 - OS 600 15439 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 16367 - OS 600 16367 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 17826 - OS 600 17826 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 17833 - OS 600 17833 - Learning Unit - Small - (57 SQM)	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 11166 - OS 601 11166 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 700 10974 - OS 700 10974 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 710 10923 - OS 710 10923 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 710 15508 - OS 710 15508 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	