


VENTILATION AUDIT REPORT

SCHOOL:	Condong Public School (1611)
AMU REGION:	North Coast
STATE ELECTORATE:	Tweed
LOCAL GOVERNMENT AREA:	Tweed

1611 - Condong Public School
Site Plan (10318)














1:359

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (21.81 SQM)	 Office (5)	
B00A - R0002 - Home Base - (59.07 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0003 - Home Base - (56.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0004 - Home Base - (46.99 SQM) - Teaching Space: 1	 Student Space (21)	
B00A - R0008 - Reading Area - (65.77 SQM)	 Student Space (30)	
B00A - R0010 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Withdrawal Space - 1hb - (11.15 SQM)	 Student Space (5)	
B00A - R0016 - Movement - (45.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (9.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Canteen - (21.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Practical Activities - (52.54 SQM)	 Student Space (24)	
B00B - R0005 - Movement - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (21.42 SQM)	 Student Space (9)	
B00E - R0002 - Home Base - (55.2 SQM) - Teaching Space: 1	 Student Space (25)	
B00E - R0004 - Withdrawal Space - 1hb - (8.7 SQM)	 Student Space (4)	
OS 505 11218 - OS 505 11218 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	