


VENTILATION AUDIT REPORT

SCHOOL:	Connells Point Public School (1613)
AMU REGION:	Sydney
STATE ELECTORATE:	Oatley
LOCAL GOVERNMENT AREA:	Georges River

1613 - Connells Point Public School
Site Plan (10302)















1:1,287

Printed: 02-Jul-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - Raised Platform - (35.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Communal Space - (274.4 SQM)	● Student Space (127)	
B00B - R0005 - Movement - (76.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Staff Kitchen - (13.58 SQM)	● Office (3)	
B00C - R0001 - Home Base - (57.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0007 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0009 - Staff Room Annexe - (19.97 SQM)	● Office (4)	
B00C - R0010 - Staff Room - (57.05 SQM)	● Office (14)	
B00C - R0015 - Deputy Principal - (13.86 SQM)	● Office (3)	
B00C - R0017 - Duplicating Workroom - (21.5 SQM)	● Office (5)	
B00C - R0018 - Interview - (12.57 SQM)	● Office (3)	
B00C - R0019 - Clerical Office - (20.79 SQM)	● Office (5)	
B00C - R0020 - Movement - (32.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Principal - (17.37 SQM)	● Office (4)	
B00C - R0025 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Movement - (50.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (81.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (47.76 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0003 - Home Base - (48.05 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0004 - Home Base - (47.9 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1003 - Reading Area - (49.39 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1005 - Movement - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Movement - (29.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Home Base - (48.04 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1012 - Practical Activities - (18.54 SQM)	● Student Space (8)	
B00D - R1013 - Withdrawal Space - 1hb - (11.97 SQM)	● Student Space (5)	
B00D - R1014 - Home Base - (48.95 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0002 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0003 - Home Base - (53.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Home Base - (72.13 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0008 - Staff Room Annexe - (18.89 SQM)	● Office (4)	
B00E - R0011 - Movement - (21.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Movement - (25.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Outdoor Learning Area - (68.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (84.68 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R0004 - Home Base - (56.28 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0001 - Home Base - (56.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Home Base - (55.6 SQM) - Teaching Space: 1	● Student Space (25)	
B00G - R0005 - Home Base - (83.67 SQM) - Teaching Space: 1	● Student Space (38)	
B00G - R0006 - Outdoor Learning Area - (69.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R9001 - Special Programs Room - (52.94 SQM)	● Student Space (24)	
B00I - R0004 - Home Base - (56.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0005 - Home Base - (57.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0012 - Home Base - (55.7 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0017 - Home Base - (56.91 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0002 - Canteen - (17.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (13.55 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0001 - Interview - (14.92 SQM)	 Office (3)	
B00K - R0003 - Special Programs Room - Type 1 - (99.03 SQM)	 Student Space (45)	
B00M - R0008 - Reading Area - (231.46 SQM)	 Student Space (107)	
B00N - R0001 - Practical Activities - (19.51 SQM)	 Student Space (9)	
B00N - R0003 - Home Base - (59.86 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0004 - Withdrawal Space - 2hb - (11.96 SQM)	 Student Space (5)	
B00N - R0005 - Practical Activities - (19.51 SQM)	 Student Space (9)	
B00N - R0007 - Home Base - (60.01 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0008 - Practical Activities - (19.42 SQM)	 Student Space (9)	
B00N - R0009 - Home Base - (58.08 SQM) - Teaching Space: 1	 Student Space (26)	
B00N - R0010 - Withdrawal Space - 1hb - (8.91 SQM)	 Student Space (4)	
NS 250 11369 - NS 250 11369 - Learning Unit - Single E.S.L./Store - (38 SQM)	 Student Space (17)	