

VENTILATION AUDIT REPORT

SCHOOL:	Coolamon Central School (1624)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Coolamon

1624 - Coolamon Central School
Site Plan (12265)



1:842

Printed: 10-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (53.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Deputy Principal - (13.15 SQM)	Office (3)	
B00A - R0006 - Clerical Office - (24.27 SQM)	Office (6)	
B00A - R0007 - Principal - (17.76 SQM)	Office (4)	
B00A - R0012 - Interview - (22.69 SQM)	Office (5)	
B00A - R0013 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Entry Vestibule - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Staff Room Annexe - (13.31 SQM)	Office (3)	
B00A - R0016 - Staff Room Annexe - (9.45 SQM)	Office (2)	
B00A - R0019 - Sick Bay - (8.78 SQM)	Student Space (4)	
B00B - R0001 - Movement - (48.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Staff Kitchen - (13.66 SQM)	Office (3)	
B00B - R0010 - Staff Study - (106.28 SQM)	Office (26)	
B00B - R0011 - Staff Kitchen - (58.19 SQM)	Office (14)	
B00C - R0002 - Staff Room Annexe - (20.82 SQM)	Office (5)	
B00C - R0003 - Laboratory L.S. - (92.23 SQM) - Teaching Space: 1	Student Space (42)	
B00C - R0005 - Preparation - (25.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - General Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Seminar/Study - (17.14 SQM)	Office (4)	
B00C - R0011 - Movement - (64.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Materials Technology L.S. - (103.5 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0003 - Design L.S. - (53.31 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - Movement - (40.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (74.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Darkroom Space - (25.84 SQM)	Office (6)	
B00D - R0027 - Workshop Area - (71.17 SQM)	Student Space (33)	
B00D - R0030 - Wood Technology Bay - (17.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Welding Area - (11.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (110.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Food Technology L.S. - (66.07 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1009 - Computer Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1020 - Preparation - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (16.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Canteen - (32.23 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Home Base - (46.2 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0004 - Home Base - (43.91 SQM) - Teaching Space: 1	Student Space (20)	
B00K - R0009 - Main Entry - (18.65 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Reading Area - (45.99 SQM)	Student Space (21)	
B00K - R0011 - Staff Study - (20.87 SQM)	Office (5)	
B00K - R0013 - Interview - (12.35 SQM)	Office (3)	
B00K - R0015 - Reading Area - (87.61 SQM)	Student Space (40)	
B00K - R0020 - Movement - (27.32 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Movement - (93.94 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 1hb - (20.83 SQM)	Student Space (9)	
B00N - R0003 - Withdrawal Space - 1hb - (11.63 SQM)	Student Space (5)	
B00N - R0004 - Practical Activities - 1hb - (20.84 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0006 - Home Base - (59.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0008 - Home Base - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0010 - Movement - (5.1 SQM)	Not Applicable	Circulation or storage space.
B00N - R0011 - Practical Activities - 1hb - (20.77 SQM)	● Student Space (9)	
B00N - R0012 - Withdrawal Space - 1hb - (11.7 SQM)	● Student Space (5)	
B00N - R0013 - Practical Activities - 1hb - (20.77 SQM)	● Student Space (9)	
B00N - R0015 - Home Base - (58.72 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0016 - Home Base - (58.87 SQM) - Teaching Space: 1	● Student Space (27)	
B00P - R0002 - Communal Space - (147.16 SQM)	● Student Space (68)	
B00P - R0003 - Movement - (6.2 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Raised Platform - (59.71 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Movement - (11.21 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Home Base - (60.61 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0003 - Practical Activities - (19.23 SQM)	● Student Space (8)	
B00Q - R0004 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00Q - R0005 - Home Base - (60.46 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0006 - Practical Activities - (18.67 SQM)	● Student Space (8)	
B00Q - R0008 - Home Base - (58.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00Q - R0009 - Practical Activities - (18.7 SQM)	● Student Space (8)	
B00Q - R0011 - Withdrawal Space - 1hb - (9.29 SQM)	● Student Space (4)	
B00Q - R0012 - Special Programs Room - (38.75 SQM)	● Student Space (17)	
B00R - R0001 - Music Learning Space - (78.65 SQM) - Teaching Space: 1	● Student Space (36)	
B00R - R0004 - Seminar - (13.06 SQM)	● Office (3)	
B00R - R0006 - General Learning Space - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0001 - Art Learning Space - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0002 - General Learning Space - (60.53 SQM) - Teaching Space: 1	● Student Space (28)	
B00S - R0003 - General Learning Space - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	