

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cooma Public School (1628)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Monaro</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Snowy Monaro</b>

1628 - Cooma Public School  
Site Plan (10304)



1:837

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (56.73 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0007 - Home Base - (56.58 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0010 - Sick Bay - (7.14 SQM)	Student Space (3)	
B00A - R0015 - Interview - (9.49 SQM)	Office (2)	
B00A - R0016 - Principal - (18.54 SQM)	Office (4)	
B00A - R0017 - Entry Vestibule - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (109.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (14.13 SQM)	Office (3)	
B00A - R0022 - Clerical Office - (14.13 SQM)	Office (3)	
B00A - R0023 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1006 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1009 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1013 - Home Base - (56.81 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1015 - Movement - (90.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (96.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Canteen - (17.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (38.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (42.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1006 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0002 - Movement - (22.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - M - (40.77 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R0007 - Practical Activities - M - 1hb - (5.28 SQM)	Student Space (2)	
B00C - R0008 - Home Base - M - (45.22 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R0009 - Practical Activities - M - 1hb - (7.04 SQM)	Student Space (3)	
B00C - R0010 - Withdrawal - S - (18.13 SQM)	Student Space (8)	
B00C - R0015 - Staff Kitchen - (13.22 SQM)	Office (3)	
B00D - R0001 - Staff Room Annexe - (10.28 SQM)	Office (2)	
B00D - R0003 - Movement - (18.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (52.95 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0007 - Home Base - (73.28 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0006 - Practical Activities - 1hb - (11.76 SQM)	Student Space (5)	
B00E - R0007 - Home Base - (64.42 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0008 - Home Base - (64.84 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0009 - Practical Activities - 1hb - (10.61 SQM)	Student Space (4)	
B00E - R1004 - Movement - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R1013 - Reading Area - (166.77 SQM)	Student Space (77)	
B00E - R1014 - Special Programs Room - (30.72 SQM)	Student Space (14)	
B00F - R0001 - Withdrawal Space - 1hb - (20.57 SQM)	Student Space (9)	
B00F - R0002 - Movement - (9.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Home Base - (71.93 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0004 - Withdrawal Space - 1hb - (24.35 SQM)	Student Space (11)	
B00F - R0005 - Home Base - (46.63 SQM) - Teaching Space: 1	Student Space (21)	
B00G - R0001 - Withdrawal Space - 1hb - (18.66 SQM)	Student Space (8)	
B00G - R0005 - Movement - (67.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Withdrawal Space - 1hb - (21.41 SQM)	Student Space (9)	
B00G - R0008 - Deputy Principal - (16.37 SQM)	Office (4)	
B00G - R0010 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0013 - Home Base - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0014 - Home Base - (90.09 SQM) - Teaching Space: 1	● Student Space (41)	
B00G - R0015 - Practical Activities - 1hb - (16.89 SQM)	● Student Space (7)	
B00G - R0018 - Withdrawal Space - 1hb - (51.9 SQM)	● Student Space (24)	
B00G - R0020 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (41.43 SQM)	Not Applicable	Circulation or storage space.
B00G - R9001 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Raised Platform - (28.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Communal Space - (99.11 SQM)	● Student Space (45)	
B00I - R0014 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Communal Space - (145.26 SQM)	● Student Space (67)	
B00M - R0002 - Raised Platform - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00M - R0017 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (12.43 SQM)	Not Applicable	Circulation or storage space.