


VENTILATION AUDIT REPORT

SCHOOL:	Coonabarabran High School (8347)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warrumbungle

8347 - Coonabarabran High School
Site Plan (10611)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Study - (23.78 SQM)	Office (5)	
B00A - R0015 - Workshop Area - (170.06 SQM)	Student Space (78)	
B00A - R0021 - Seminar - (32.67 SQM)	Office (8)	
B00A - R0023 - General Learning Space - (77 SQM)	Student Space (35)	
B00A - R1001 - Staff Study - (32.41 SQM)	Office (8)	
B00A - R1002 - Materials Technology L.S. - (82.63 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R1005 - Materials Technology L.S. - (82.53 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0003 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Art Learning Space - (63.56 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1001 - Senior Study - (41.41 SQM)	Office (10)	
B00B - R1004 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Computer Learning Space - (52.04 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1010 - Movement - (34.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (52.12 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0003 - General Learning Space - (51.97 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0007 - Computer Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Movement - (33.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0010 - Staff Study - (25.69 SQM)	Office (6)	
B00C - R1001 - General Learning Space - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1003 - General Learning Space - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - Seminar - (13.17 SQM)	Office (3)	
B00C - R1006 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1007 - Movement - (39.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1010 - Movement - (29.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (90.59 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0005 - Laboratory L.S. - (90.77 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0020 - Preparation - Science - (44.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Darkroom Space - (8.16 SQM)	Office (2)	
B00D - R1003 - Laboratory L.S. - (90.25 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1006 - Laboratory L.S. - (90.77 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1007 - Movement - (81.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Staff Kitchen - (10.48 SQM)	Office (2)	
B00D - R1021 - Staff Study - (35.94 SQM)	Office (8)	
B00E - R0004 - Clinic - Boys - (12.42 SQM)	Office (3)	
B00E - R0005 - Clinic - Girls - (12.95 SQM)	Office (3)	
B00E - R0009 - Leading Teacher - (12.57 SQM)	Office (3)	
B00E - R0010 - Deputy Principal Office - (15.79 SQM)	Office (3)	
B00E - R0013 - Principal Office - (19.94 SQM)	Office (4)	
B00E - R0014 - Seminar - (10.19 SQM)	Office (2)	
B00E - R0015 - Movement - (73.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Administration - Clerical - (13.72 SQM)	Office (3)	
B00E - R0017 - Duplicating Workroom - (14.23 SQM)	Office (3)	
B00E - R0018 - Administration - Clerical - (30.04 SQM)	Office (7)	
B00E - R0023 - Staff Kitchen - (6.57 SQM)	Office (1)	
B00E - R0024 - Staff Study - (65.49 SQM)	Office (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1005 - Seminar - (25.63 SQM)	Office (6)	
B00E - R1006 - Seminar - (12.46 SQM)	Office (3)	
B00E - R1007 - Seminar - (12.78 SQM)	Office (3)	
B00E - R1008 - Main Area - (183.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Main Area - (51.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Movement - (58.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Design L.S. - (82.62 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0006 - Food/Research Space - (16.32 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Staff Study - (15.79 SQM)	Office (3)	
B00F - R0008 - Food Technology L.S. - (82.53 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R1001 - Staff Study - (32.02 SQM)	Office (8)	
B00F - R1002 - Materials Technology L.S. - (65.61 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1008 - Music Learning Space - (65.42 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R1009 - Movement - (79.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (22.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Stage - (84.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Multi-Purpose Space - (303.76 SQM)	Student Space (140)	
B00G - R0013 - Student Canteen - (45.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (23.76 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Visitors Office - (6.98 SQM)	Office (1)	
OS 600 14027 - OS 600 14027 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 10740 - OS 601 10740 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 10741 - OS 601 10741 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12257 - OS 601 12257 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13934 - OS 601 13934 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14357 - OS 601 14357 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15929 - OS 601 15929 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	