


VENTILATION AUDIT REPORT

SCHOOL:	Coonabarabran Public School (1630)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warrumbungle

1630 - Coonabarabran Public School
Site Plan (10611)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (48.36 SQM)	Not Applicable	Circulation or storage space.
B001 - R0002 - Canteen - (30.6 SQM)	Not Applicable	Circulation or storage space.
B001 - R0006 - Reading Area - (47.07 SQM)	● Student Space (21)	
B001 - R0010 - Reading Area - (79.29 SQM)	● Student Space (36)	
B001 - R0012 - Reading Area - (44.96 SQM)	● Student Space (20)	
B001 - R0014 - Movement - (144.23 SQM)	Not Applicable	Circulation or storage space.
B001 - R0020 - Withdrawal Space - 1hb - (18.5 SQM)	● Student Space (8)	
B001 - R0021 - Duplicating Workroom - (16.72 SQM)	● Office (4)	
B001 - R0024 - Staff Study - (12.74 SQM)	● Office (3)	
B001 - R0027 - Staff Room Annexe - (12.92 SQM)	● Office (3)	
B001 - R0033 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Raised Platform - (39.41 SQM)	Not Applicable	Circulation or storage space.
B001 - R0035 - Communal Space - (184.78 SQM)	● Student Space (85)	
B001 - R0057 - Movement - (123.01 SQM)	Not Applicable	Circulation or storage space.
B001 - R0062 - Practical Activities - 1hb - (8.25 SQM)	● Student Space (3)	
B001 - R0063 - Home Base - (46.22 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R0064 - Practical Activities - 1hb - (7.21 SQM)	● Student Space (3)	
B001 - R0065 - Home Base - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R0066 - Practical Activities - 1hb - (7.21 SQM)	● Student Space (3)	
B001 - R0067 - Home Base - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R0068 - Practical Activities - 1hb - (7.22 SQM)	● Student Space (3)	
B001 - R0069 - Home Base - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R0070 - Deputy Principal - (14.07 SQM)	● Office (3)	
B001 - R0075 - Staff Room Annexe - (12.06 SQM)	● Office (3)	
B001 - R0080 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B001 - R0087 - Staff Kitchen - (14.06 SQM)	● Office (3)	
B001 - R0088 - Staff Room - (63.2 SQM)	● Office (15)	
B001 - R1001 - Movement - (125.91 SQM)	Not Applicable	Circulation or storage space.
B001 - R1004 - Special Programs Room - (21.29 SQM)	● Student Space (9)	
B001 - R1005 - Practical Activities - 1hb - (7.3 SQM)	● Student Space (3)	
B001 - R1006 - Home Base - (46.83 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R1007 - Practical Activities - 1hb - (7.3 SQM)	● Student Space (3)	
B001 - R1008 - Home Base - (46.83 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R1009 - Practical Activities - 1hb - (7.31 SQM)	● Student Space (3)	
B001 - R1010 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R1011 - Practical Activities - 1hb - (6.78 SQM)	● Student Space (3)	
B001 - R1012 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B001 - R1013 - Staff Room Annexe - (9.88 SQM)	● Office (2)	
B004 - R0001 - Movement - (9.31 SQM)	Not Applicable	Circulation or storage space.
B004 - R0007 - Movement - (9.3 SQM)	Not Applicable	Circulation or storage space.
B004 - R0010 - Movement - (21.58 SQM)	Not Applicable	Circulation or storage space.
B005 - R0001 - Movement - (9.5 SQM)	Not Applicable	Circulation or storage space.
B005 - R0004 - Movement - (90.89 SQM)	Not Applicable	Circulation or storage space.
B005 - R0007 - Movement - (9.3 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Staff Room - (33.89 SQM)	● Office (8)	
B006 - R0005 - Movement - (18.48 SQM)	Not Applicable	Circulation or storage space.
B006 - R0007 - Sick Bay - (5.63 SQM)	● Student Space (2)	
B006 - R0008 - Staff Room Annexe - (15.98 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B006 - R0009 - Duplicating Workroom - (10.42 SQM)	Office (2)	
B006 - R0011 - Home Base - (55.22 SQM) - Teaching Space: 1	Student Space (25)	
B006 - R0015 - Home Base - (73.06 SQM) - Teaching Space: 1	Student Space (33)	
B006 - R0017 - Practical Activities - 1hb - (36.92 SQM)	Student Space (17)	
B006 - R0022 - Home Base - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0001 - Home Base - (55.3 SQM) - Teaching Space: 1	Student Space (25)	
B007 - R0005 - Home Base - (73.05 SQM) - Teaching Space: 1	Student Space (33)	
B007 - R0008 - Practical Activities - 1hb - (37.68 SQM)	Student Space (17)	
B007 - R0013 - Home Base - (55.21 SQM) - Teaching Space: 1	Student Space (25)	
B008 - R0001 - Practical Activities - 1hb - (27.77 SQM)	Student Space (12)	
B008 - R0002 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B009 - R0002 - Practical Activities - 1hb - (96.47 SQM)	Student Space (44)	
B010 - R0002 - Movement - (45.45 SQM)	Not Applicable	Circulation or storage space.
B010 - R0003 - Movement - (30.09 SQM)	Not Applicable	Circulation or storage space.
B010 - R0004 - Home Base - (54.97 SQM) - Teaching Space: 1	Student Space (25)	
B010 - R0005 - Practical Activities - 1hb - (8.38 SQM)	Student Space (3)	
B010 - R0006 - Movement - (21.08 SQM)	Not Applicable	Circulation or storage space.
B010 - R0007 - Home Base - (51.42 SQM) - Teaching Space: 1	Student Space (23)	
B010 - R0008 - Movement - (32.39 SQM)	Not Applicable	Circulation or storage space.
B010 - R0009 - Home Base - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B010 - R0011 - Withdrawal Space - 1hb - (13.04 SQM)	Student Space (6)	
B010 - R0016 - Movement - (51.02 SQM)	Not Applicable	Circulation or storage space.
B010 - R0017 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B010 - R0028 - Interview - (7.88 SQM)	Office (1)	
B010 - R0029 - Staff Kitchen - (5.56 SQM)	Office (1)	
B010 - R0031 - Entry Vestibule - (9.52 SQM)	Not Applicable	Circulation or storage space.
B010 - R0032 - Clerical Office/Workroom - (18.8 SQM)	Office (4)	
B010 - R0033 - Duplicating Workroom - (23.7 SQM)	Office (5)	
B010 - R0035 - Interview - (11.85 SQM)	Office (2)	
B010 - R0036 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.
B010 - R0037 - Principal - (17.91 SQM)	Office (4)	
B010 - R0038 - Deputy Principal - (14.3 SQM)	Office (3)	
B010 - R0042 - Sick Bay - (10.57 SQM)	Student Space (4)	
B010 - R0044 - Movement - (10.59 SQM)	Not Applicable	Circulation or storage space.
B010 - R0046 - Movement - (38.77 SQM)	Not Applicable	Circulation or storage space.
B010 - R0047 - Movement - (12.03 SQM)	Not Applicable	Circulation or storage space.
B011 - R0005 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B012 - R0002 - Practical Activities - 1hb - (19.12 SQM)	Student Space (8)	
B012 - R0004 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B012 - R0005 - Withdrawal Space - 2hb - (11.68 SQM)	Student Space (5)	
B012 - R0006 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B012 - R0008 - Practical Activities - 1hb - (19.12 SQM)	Student Space (8)	
B012 - R0010 - Clerical Office - (33.65 SQM)	Office (8)	