


# VENTILATION AUDIT REPORT

SCHOOL:	Cootamundra High School (8190)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Cootamundra-Gundagai

8190 - Cootamundra High School  
Site Plan (10311)





## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (19.88 SQM)	Office (4)	
B00A - R0003 - Administration - Clerical - (13.3 SQM)	Office (3)	
B00A - R0006 - Movement - (43.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - General Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0010 - General Learning Space - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0011 - General Learning Space - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0012 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0013 - General Learning Space - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0014 - Special Learning Space - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0015 - Commonroom - (21.66 SQM)	Office (5)	
B00A - R0016 - Commonroom - (40.98 SQM)	Office (10)	
B00A - R0019 - Pupil Entry - (9.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (15.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (68.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Administration - Clerical - (6.86 SQM)	Office (1)	
B00A - R0025 - Interview/Office - Type 1 - (22.78 SQM)	Office (5)	
B00A - R0027 - Multi-Purpose Space - (269.31 SQM)	Student Space (124)	
B00A - R0028 - Darkroom Space - (9.25 SQM)	Office (2)	
B00A - R0034 - Pupil Entry - (22.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Clinic - Boys - (21.95 SQM)	Office (5)	
B00A - R0039 - Interview/Office - Type 1 - (10.69 SQM)	Office (2)	
B00A - R0041 - Deputy Principal Office - (19.81 SQM)	Office (4)	
B00A - R0043 - Administration - Clerical - (12.73 SQM)	Office (3)	
B00A - R0045 - Stage - (83.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Interview/Office - Type 1 - (12.08 SQM)	Office (3)	
B00A - R0056 - Movement - (156.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Main Area - (155.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Main Area - (54.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Computer Learning Space - (55.8 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1004 - General Learning Space - (56.02 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1005 - General Learning Space - (54.98 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1006 - Laboratory L.S. - (55.81 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1008 - Laboratory L.S. - (89.19 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R1009 - Staff Study - (20.05 SQM)	Office (5)	
B00A - R1012 - Duplicating Workroom - (8.94 SQM)	Office (2)	
B00A - R1013 - Audio Visual Workroom - (29.08 SQM)	Student Space (13)	
B00A - R1015 - Workroom - (9.51 SQM)	Office (2)	
B00A - R1017 - Movement - (156.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - General Learning Space - (51.81 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - General Learning Space - (65.94 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0008 - General Learning Space - (60.97 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0011 - Staff Study - (26.21 SQM)	Office (6)	
B00B - R0013 - Movement - (111.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - General Learning Space - (51.16 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1002 - Laboratory L.S. - (81.62 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1003 - Growing/Breeding - (9.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Preparation - (28.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Laboratory L.S. - (88.49 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1007 - Music Learning Space - (66.03 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1012 - Movement - (109.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Staff Study - (25.62 SQM)	Office (6)	
B00C - M0004 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Leading Teacher - (12.89 SQM)	Office (3)	
B00C - R0008 - Design L.S. - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0010 - Administration - Clerical - (12.19 SQM)	Office (3)	
B00C - R0011 - Interview/Office - Type 1 - (12.89 SQM)	Office (3)	
B00C - R0012 - Duplicating Workroom - (12.13 SQM)	Office (3)	
B00C - R0013 - Staff Study - (12.13 SQM)	Office (3)	
B00C - R0013 - Staff Study - (12.13 SQM)	Office (3)	
B00C - R0020 - Laboratory L.S. - (92.9 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0021 - Preparation - (28.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Leading Teacher - (11.69 SQM)	Office (2)	
B00C - R0030 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Movement - (290.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Staff Study - (39.17 SQM)	Office (9)	
B00C - R0039 - Art Learning Space - (93.45 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R1002 - Materials Technology L.S. - (86.3 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R1006 - Food Technology L.S. - (65.43 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1011 - Staff Study - (24.71 SQM)	Office (6)	
B00C - R1014 - Computer Learning Space - (55.79 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1017 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1018 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1019 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1022 - Senior Seminar - (12.92 SQM)	Office (3)	
B00C - R1023 - Senior Seminar - (12.92 SQM)	Office (3)	
B00C - R1024 - Senior Study - (66.18 SQM)	Office (16)	
B00C - R1025 - Senior Seminar - (14.46 SQM)	Office (3)	
B00C - R1026 - Senior Seminar - (22.85 SQM)	Office (5)	
B00C - R1032 - Movement - (205.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R1034 - Preparation - Materials - (25.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Materials Technology L.S. - (102.53 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0004 - Staff Study - (27.5 SQM)	Office (6)	
B00D - R0004 - Staff Study - (27.5 SQM)	Office (6)	
B00D - R0005 - Pupil Entry - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Design L.S. - (76.95 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R0004 - Pupil Entry - (17.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Wood Technology Bay - (76.94 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Metal Technology Bay - (77.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Welding Area - (9.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Food Technology L.S. - (103.24 SQM) - Teaching Space: 1	Student Space (47)	
B00F - R0008 - Pupil Entry - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Staff Study - (14.31 SQM)	Office (3)	
B00F - R0012 - Staff Study - (9.52 SQM)	Office (2)	
B00F - R0013 - Materials Technology L.S. - (63.76 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0016 - Preparation - Materials - (20.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Pupil Entry - (41.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Pupil Entry - (53.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Student Canteen - (40.98 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0020 - Special Learning Space - (51.88 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0002 - Art Learning Space - (38.82 SQM) - Teaching Space: 1	 Student Space (18)	