

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Cootamundra Public School (1636)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cootamundra-Gundagai</b>

1636 - Cootamundra Public School  
Site Plan (12269)




1:909

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (35.26 SQM)	● Student Space (16)	
B00A - R0003 - Home Base - (48.92 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0010 - Home Base - M - (46.96 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0013 - Principal - (19.99 SQM)	● Office (4)	
B00A - R0014 - Interview - (14.06 SQM)	● Office (3)	
B00A - R0015 - Staff Room - (47.91 SQM)	● Office (11)	
B00A - R0020 - Sick Bay - (10.14 SQM)	● Student Space (4)	
B00A - R0023 - Reading Area - (142.83 SQM)	● Student Space (66)	
B00A - R0034 - Home Base - (47.31 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0035 - Home Base - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0037 - Clerical Office - (27.17 SQM)	● Office (6)	
B00A - R0038 - Movement - (13.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Interview - (9.24 SQM)	● Office (2)	
B00A - R0040 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Staff Kitchen - (8.28 SQM)	● Office (2)	
B00A - R0042 - Movement - (50.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Staff Kitchen - (19.99 SQM)	● Office (4)	
B00B - R0006 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (45.82 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0008 - Home Base - (61.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0018 - Movement - (17.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Canteen - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Raised Platform - (51.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Communal Space - (135.83 SQM)	● Student Space (63)	
B00G - R0002 - Home Base - (47.49 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0003 - Home Base - (47.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0002 - Home Base - (46.95 SQM) - Teaching Space: 1	● Student Space (21)	
B00H - R0003 - Practical Activities - 1hb - (9.77 SQM)	● Student Space (4)	
B00H - R0004 - Home Base - (31.85 SQM) - Teaching Space: 1	● Student Space (14)	
B00H - R0005 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Withdrawal Space - 1hb - (24.65 SQM)	● Student Space (11)	
B00J - R0005 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0006 - Home Base - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0007 - Staff Room Annexe - (12.55 SQM)	● Office (3)	
B00J - R0009 - Home Base - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R0010 - Home Base - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0002 - Practical Activities - (21.61 SQM)	● Student Space (10)	
B00L - R0004 - Home Base - (62.72 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (62.73 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0008 - Practical Activities - (21.61 SQM)	● Student Space (10)	
BOB1 - R0001 - Staff Room - (12.69 SQM)	● Office (3)	
BOB1 - R0003 - Movement - (5.41 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0004 - Home Base - (79.19 SQM) - Teaching Space: 1	● Student Space (36)	
BOB2 - R0002 - Home Base - (43.6 SQM) - Teaching Space: 1	● Student Space (20)	
BOB2 - R0003 - Home Base - (34.78 SQM) - Teaching Space: 1	● Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOB2 - R0004 - Computer Room - (36.59 SQM)	 Student Space (16)	
BOB2 - R0007 - Movement - (10.93 SQM)	Not Applicable	Circulation or storage space.