

VENTILATION AUDIT REPORT

SCHOOL:	Copacabana Public School (4548)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

4548 - Copacabana Public School
Site Plan (10312)

















1:830

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (79.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (7.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Raised Platform - (32.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Communal Space - (145.26 SQM)	● Student Space (67)	
B00A - R0025 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (26.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (57.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Entry Vestibule - (15.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Clerical Office - (13.03 SQM)	● Office (3)	
B00C - R0004 - Principal - (17.1 SQM)	● Office (4)	
B00C - R0008 - Staff Room Annexe - (20 SQM)	● Office (5)	
B00C - R0009 - Staff Room - (48.9 SQM)	● Office (12)	
B00C - R0010 - Staff Room Annexe - (11.33 SQM)	● Office (2)	
B00C - R0013 - Sick Bay - (8.94 SQM)	● Student Space (4)	
B00C - R0016 - Staff Room Annexe - (12.7 SQM)	● Office (3)	
B00C - R0017 - Clerical Office - (12.56 SQM)	● Office (3)	
B00C - R0018 - Movement - (19.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (33.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Duplicating Workroom - (20.47 SQM)	● Office (5)	
B00C - R0022 - Movement - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Interview - (17.48 SQM)	● Office (4)	
B00D - R0001 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Withdrawal Space - 1hb - (12.06 SQM)	● Student Space (5)	
B00E - R0005 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0013 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0015 - Practical Activities - 1hb - (71.65 SQM)	● Student Space (33)	
B00E - R0016 - Movement - (42.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0019 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0020 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Withdrawal Space - 1hb - (12.05 SQM)	● Student Space (5)	
B00E - R0026 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Reading Area - (165 SQM)	● Student Space (76)	
B00F - R0007 - Movement - (16.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (11.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Withdrawal Space - 1hb - (12.06 SQM)	● Student Space (5)	
B00H - R0005 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0007 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0016 - Practical Activities - 1hb - (72.87 SQM)	● Student Space (33)	
B00H - R0017 - Movement - (42.39 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0018 - Home Base - (60.94 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0019 - Home Base - (60.94 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0020 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Withdrawal Space - 1hb - (12.06 SQM)	 Student Space (5)	
B00H - R0024 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (20.33 SQM)	 Student Space (9)	
B00I - R0002 - Home Base - (58.35 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0003 - Withdrawal Space - 1hb - (5.92 SQM)	 Student Space (2)	
B00I - R0005 - Practical Activities/Movement - 1hb - (19.6 SQM)	 Student Space (9)	
B00I - R0006 - Home Base - (60.11 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R0008 - Withdrawal Space - 2hb - (11.51 SQM)	 Student Space (5)	
B00I - R0009 - Practical Activities - (19.56 SQM)	 Student Space (9)	
B00I - R0010 - Home Base - (60.06 SQM) - Teaching Space: 1	 Student Space (27)	
OS 601 14957 - OS 601 14957 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 13567 - OS 602 13567 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15722 - OS 602 15722 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	