

VENTILATION AUDIT REPORT

SCHOOL:	Coramba Public School (1647)
AMU REGION:	North Coast
STATE ELECTORATE:	Coffs Harbour
LOCAL GOVERNMENT AREA:	Coffs Harbour

1647 - Coramba Public School
Site Plan (12271)



1:633

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (32.46 SQM)	Office (8)	
B00A - R0002 - Clerical Office/Workroom - (22.55 SQM)	Office (5)	
B00A - R0003 - Reading Area - (79.75 SQM)	Student Space (37)	
B00A - R0004 - Special Programs Room - (11.79 SQM)	Student Space (5)	
B00A - R0006 - Entry Vestibule - (12.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (11.03 SQM)	Office (2)	
B00A - R0013 - Practical Activities - (13.01 SQM)	Student Space (6)	
B00B - R0001 - Home Base - (46.31 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0003 - Practical Activities - 1hb - (7.65 SQM)	Student Space (3)	
B00C - R0001 - Canteen - (20.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Outdoor Learning Area - (23.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Special Programs Room - (19.55 SQM)	Student Space (9)	
B00F - R0008 - Special Programs Room - (10.34 SQM)	Student Space (4)	
B00F - R0009 - Special Programs Room - (22.79 SQM)	Student Space (10)	
B00I - R0002 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00I - R0004 - Home Base - (58.88 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	Student Space (4)	
B00I - R0006 - Home Base - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	