

VENTILATION AUDIT REPORT

SCHOOL:	Coreen School (5637)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

5637 - Coreen School
Site Plan (13324)



1:1,236

Printed: 08-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (17.4 SQM)	Office (4)	
B00A - R0003 - Deputy Principal - (12.99 SQM)	Office (3)	
B00A - R0004 - Deputy Principal - (12.02 SQM)	Office (3)	
B00A - R0005 - Sick Bay - (8.49 SQM)	Student Space (3)	
B00A - R0008 - Staff Room Annexe - (10.77 SQM)	Office (2)	
B00A - R0010 - Staff Room Annexe - (13.14 SQM)	Office (3)	
B00A - R0011 - Staff Room - (63 SQM)	Office (15)	
B00A - R0015 - Duplicating Workroom - (12.15 SQM)	Office (3)	
B00A - R0016 - Clerical Office - (13.05 SQM)	Office (3)	
B00A - R0018 - Entry Vestibule - (20.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (31.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - M - 1hb - (6.28 SQM)	Student Space (2)	
B00B - R0003 - Withdrawal - M - (5.44 SQM)	Student Space (2)	
B00B - R0004 - Home Base - M - (65.25 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0005 - Practical Activities - M - 1hb - (7.82 SQM)	Student Space (3)	
B00B - R0006 - Home Base - M - (72.73 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0007 - Home Base - M - (73.09 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0008 - Practical Activities - M - 1hb - (6.84 SQM)	Student Space (3)	
B00B - R0010 - Home Base - M - (65.25 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0011 - Practical Activities - M - 1hb - (16.12 SQM)	Student Space (7)	
B00B - R0012 - Withdrawal - M - (15.55 SQM)	Student Space (7)	
B00B - R0013 - Home Base - M - (65.43 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0001 - Practical Activities - M - 1hb - (19.3 SQM)	Student Space (8)	
B00C - R0002 - Home Base - M - (27.16 SQM) - Teaching Space: 1	Student Space (12)	
B00C - R0004 - Practical Activities - M - 1hb - (17.11 SQM)	Student Space (7)	
B00C - R0005 - Home Base - M - (26.58 SQM) - Teaching Space: 1	Student Space (12)	
B00C - R0006 - Practical Activities - M - 1hb - (18.56 SQM)	Student Space (8)	
B00C - R0007 - Withdrawal - M - (9.17 SQM)	Student Space (4)	
B00C - R0008 - Staff Room Annexe - (7.29 SQM)	Office (1)	
B00C - R0010 - Practical Activities - M - 1hb - (18.56 SQM)	Student Space (8)	
B00C - R0011 - Home Base - M - (26.58 SQM) - Teaching Space: 1	Student Space (12)	
B00C - R0012 - Home Base - M - (27.16 SQM) - Teaching Space: 1	Student Space (12)	
B00C - R0013 - Home Base - M - (27.16 SQM) - Teaching Space: 1	Student Space (12)	
B00C - R0014 - Practical Activities - M - 1hb - (19.3 SQM)	Student Space (8)	
B00C - R0015 - Withdrawal - M - (6.91 SQM)	Student Space (3)	
B00C - R0016 - Withdrawal - M - (6.91 SQM)	Student Space (3)	
B00D - R0003 - Canteen - (23.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Practical Activities - M - 1hb - (54.39 SQM)	Student Space (25)	
B00D - R0011 - Reading Area - (120.24 SQM)	Student Space (55)	
B00D - R0016 - Staff Room Annexe - (6.34 SQM)	Office (1)	
B00E - R0006 - Movement - (22.05 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - M - 1hb - (94.68 SQM)	Student Space (43)	
B00F - R0008 - Special Programs Room - (79.93 SQM)	Student Space (37)	
B00F - R0009 - Special Programs Room - (6.62 SQM)	Student Space (3)	
B00G - R0001 - Communal Space - (119.18 SQM)	Student Space (55)	
B00G - R0002 - Raised Platform - (36.22 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Communal Space - (59.67 SQM)	● Student Space (27)	
OS 602 14856 - OS 602 14856 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14858 - OS 602 14858 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16841 - OS 602 16841 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 621 11572 - OS 621 11572 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	