

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Corindi Public School (1654)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Coffs Harbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Coffs Harbour</b>

1654 - Corindi Public School  
Site Plan (12273)





























1.935

Printed: 17-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0009 - Clerical Office - (32.18 SQM)	 Office (8)	
B00A - R0010 - Entry Vestibule - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (16.39 SQM)	 Office (4)	
B00A - R0012 - Deputy Principal - (13.66 SQM)	 Office (3)	
B00A - R0014 - Staff Room - (38.99 SQM)	 Office (9)	
B00A - R0015 - Staff Room Annexe - (12.3 SQM)	 Office (3)	
B00A - R0017 - Sick Bay - (7.67 SQM)	 Student Space (3)	
B00A - R0018 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (59.85 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0002 - Practical Activities - 1hb - (14.35 SQM)	 Student Space (6)	
B00B - R0005 - Practical Activities - 1hb - (14.36 SQM)	 Student Space (6)	
B00B - R0006 - Home Base - (59.85 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0007 - Withdrawal Space - 1hb - (11.48 SQM)	 Student Space (5)	
B00B - R0008 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (14.68 SQM)	 Student Space (6)	
B00C - R0002 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (46.2 SQM) - Teaching Space: 1	 Student Space (21)	
B00E - R0007 - Reading Area - (82.4 SQM)	 Student Space (38)	
B00E - R0008 - Practical Activities - 1hb - (23.91 SQM)	 Student Space (11)	
B00E - R0009 - Home Base - (51.71 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0010 - Withdrawal Space - 1hb - (6.46 SQM)	 Student Space (2)	
B00E - R0012 - Withdrawal Space - 1hb - (8.98 SQM)	 Student Space (4)	
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00H - R0004 - Home Base - (58.88 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	 Student Space (4)	
B00H - R0006 - Home Base - (58.79 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
OS 602 16811 - OS 602 16811 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16825 - OS 602 16825 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 750 17411 - OS 750 17411 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 801 15222 - OS 801 15222 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.