

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Corrimal East Public School (3877)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Keira</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollongong</b>

3877 - Corrimal East Public School  
Site Plan (12364)



1:1,134

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Kitchen - (22.21 SQM)	 Office (5)	
B00A - R0003 - Staff Room - (53 SQM)	 Office (13)	
B00A - R0006 - Sick Bay - (12.17 SQM)	 Student Space (5)	
B00A - R0007 - Entry Vestibule - (21.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (17.34 SQM)	 Office (4)	
B00A - R0010 - Deputy Principal - (14.16 SQM)	 Office (3)	
B00A - R0014 - Deputy Principal - (14.35 SQM)	 Office (3)	
B00A - R0015 - Movement - (16.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (9.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Withdrawal Space - 1hb - (13.13 SQM)	 Student Space (6)	
B00A - R0025 - Clerical Office - (21.05 SQM)	 Office (5)	
B00B - R0002 - Movement - (75.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Home Base - (52.85 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0004 - Home Base - (52.19 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0007 - Withdrawal Space - 1hb - (23.69 SQM)	 Student Space (10)	
B00B - R0008 - Home Base - (52.34 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0009 - Home Base - (52.34 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0013 - Movement - (6.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Raised Platform - (47.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Canteen - (26.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Communal Space - (268.03 SQM)	 Student Space (124)	
B00D - R0002 - Practical Activities - 1hb - (9.66 SQM)	 Student Space (4)	
B00D - R0003 - Home Base - (59.13 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0004 - Home Base - (59.24 SQM) - Teaching Space: 1	 Student Space (27)	
B00D - R0005 - Practical Activities - 1hb - (9.65 SQM)	 Student Space (4)	
B00E - R0001 - Practical Activities - 1hb - (9.59 SQM)	 Student Space (4)	
B00E - R0002 - Home Base - (59.54 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0003 - Home Base - (59.65 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0004 - Practical Activities - 1hb - (9.45 SQM)	 Student Space (4)	
B00F - R0003 - Home Base - (59.65 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0004 - Practical Activities - 1hb - (9.46 SQM)	 Student Space (4)	
B00F - R0005 - Home Base - (59.59 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0006 - Practical Activities - 1hb - (9.67 SQM)	 Student Space (4)	
B00G - R0001 - Home Base - (46.34 SQM) - Teaching Space: 1	 Student Space (21)	
B00G - R0002 - Withdrawal Space - 1hb - (23 SQM)	 Student Space (10)	
B00G - R0004 - Home Base - (52.23 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R0005 - Practical Activities - 1hb - (21.67 SQM)	 Student Space (10)	
B00I - R0003 - Home Base - (51.54 SQM) - Teaching Space: 1	 Student Space (23)	
B00K - R0004 - Home Base - (61.22 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0005 - Withdrawal Space - 1hb - (18.74 SQM)	 Student Space (8)	
B00L - R0001 - Reading Area - (125.33 SQM)	 Student Space (58)	
B00L - R0007 - Movement - (24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Special Programs Room - (37.99 SQM)	 Student Space (17)	
B00N - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0004 - Movement - (18.14 SQM)	Not Applicable	Circulation or storage space.