

VENTILATION AUDIT REPORT

SCHOOL:	Cowan Public School (1668)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

1668 - Cowan Public School
Site Plan (10942)















1:635

Printed: 22-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (66.44 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0005 - Staff Room - (26.57 SQM)	 Office (6)	
B00A - R0006 - Clerical Office - (17.86 SQM)	 Office (4)	
B00B - R0001 - Movement - (13.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Special Programs Room - (5.67 SQM)	 Student Space (2)	
B00B - R0005 - Withdrawal Space - 1hb - (41.25 SQM)	 Student Space (19)	
B00C - R0002 - Home Base - (52.7 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0002 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00H - R0004 - Home Base - (58.76 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00H - R0006 - Home Base - (58.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
OS 505 15098 - OS 505 15098 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	