



VENTILATION AUDIT REPORT

SCHOOL:	Cowra Public School (1671)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Cowra

1671 - Cowra Public School
Site Plan (11425)












Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Dental Clinic - (7.66 SQM)	Office (1)	
B00A - R0003 - Dental Clinic - (7.77 SQM)	Office (1)	
B00A - R0004 - Dental Clinic - (5.87 SQM)	Office (1)	
B00A - R0005 - Dental Clinic - (21.18 SQM)	Office (5)	
B00A - R0008 - Dental Clinic - (16.55 SQM)	Office (4)	
B00A - R0009 - Dental Clinic - (11.53 SQM)	Office (2)	
B00A - R0010 - Dental Clinic - (5.09 SQM)	Office (1)	
B00A - R0012 - Clerical Office/Workroom - (14.4 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (14.05 SQM)	Office (3)	
B00A - R0014 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Entry Vestibule - (84.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal - (23.19 SQM)	Office (5)	
B00A - R0017 - Staff Room - (71.35 SQM)	Office (17)	
B00A - R0018 - Staff Room Annexe - (24.72 SQM)	Office (6)	
B00A - R0023 - Movement - (77.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Staff Study - (14.24 SQM)	Office (3)	
B00A - R0029 - Deputy Principal - (14.32 SQM)	Office (3)	
B00A - R0030 - Interview - (14.73 SQM)	Office (3)	
B00A - R0032 - Duplicating Workroom - (13.51 SQM)	Office (3)	
B00A - R0035 - Movement - (32.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Reading Area - (277.66 SQM)	Student Space (128)	
B00A - R1003 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Seminar/Study - (15.42 SQM)	Office (3)	
B00A - R1005 - Seminar/Study - (15.66 SQM)	Office (3)	
B00A - R1016 - Movement - (60.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (69.14 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0002 - Practical Activities - 1hb - (8.66 SQM)	Student Space (4)	
B00B - R0004 - Movement - (11.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Withdrawal Space - 1hb - (6.57 SQM)	Student Space (3)	
B00B - R0007 - Practical Activities - 1hb - (7.45 SQM)	Student Space (3)	
B00B - R0008 - Home Base - (69.43 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0009 - Movement - (9.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Withdrawal Space - 1hb - (6.32 SQM)	Student Space (2)	
B00B - R0012 - Home Base - (39.76 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0013 - Home Base - (26.24 SQM) - Teaching Space: 1	Student Space (12)	
B00B - R0014 - Practical Activities - 1hb - (12.85 SQM)	Student Space (5)	
B00B - R0016 - Practical Activities - 1hb - (15.68 SQM)	Student Space (7)	
B00B - R0017 - Home Base - (46.95 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0018 - Home Base - (46.83 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0019 - Withdrawal Space - 1hb - (10.11 SQM)	Student Space (4)	
B00B - R0025 - Practical Activities - 1hb - (11.19 SQM)	Student Space (5)	
B00B - R0026 - Home Base - (79.03 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0028 - Communal Space - (230.17 SQM)	Student Space (106)	
B00C - R0004 - Canteen - (44.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Raised Platform - (63.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Communal Space - (233.64 SQM)	Student Space (108)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0014 - Movement - (185.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (12.06 SQM)	Not Applicable	Circulation or storage space.
B00D - M0001 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00D - M0002 - Movement - (5.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (110.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (61.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0008 - Practical Activities - 1hb - (17.04 SQM)	● Student Space (7)	
B00D - R0009 - Practical Activities - 1hb - (16.74 SQM)	● Student Space (7)	
B00D - R0010 - Home Base - (42.12 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0011 - Home Base - (54.62 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0012 - Practical Activities - 1hb - (17.04 SQM)	● Student Space (7)	
B00D - R0014 - Home Base - (72.22 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R0015 - Practical Activities - 1hb - (14.43 SQM)	● Student Space (6)	
B00D - R1001 - Movement - (7.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Movement - (90.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Staff Study - (19.31 SQM)	● Office (4)	
B00D - R1007 - Home Base - (41.54 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R1008 - Practical Activities - 1hb - (16.81 SQM)	● Student Space (7)	
B00D - R1009 - Practical Activities - 1hb - (20.33 SQM)	● Student Space (9)	
B00D - R1010 - Home Base - (38.61 SQM) - Teaching Space: 1	● Student Space (17)	
B00D - R1011 - Home Base - (54.63 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1012 - Practical Activities - 1hb - (17.16 SQM)	● Student Space (7)	
B00D - R1013 - Home Base - M - (72.33 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R1014 - Practical Activities - 1hb - (14.21 SQM)	● Student Space (6)	
B00D - R1017 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (133.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Interview - (11.77 SQM)	● Office (2)	
B00F - R0008 - Home Base - (95.11 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0010 - Staff Room Annexe - (5.69 SQM)	● Office (1)	
B00F - R0011 - Raised Platform - (26.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Communal Space - (263.14 SQM)	● Student Space (122)	
B00F - R0016 - Movement - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (40.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (14.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (46.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0006 - Home Base - (46.63 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0007 - Home Base - (46.84 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0008 - Home Base - (46.8 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0009 - Movement - (24.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Staff Study - (11.92 SQM)	● Office (2)	
B00G - R0012 - Withdrawal Space - 1hb - (19.05 SQM)	● Student Space (8)	
B00G - R0015 - Staff Study - (12.18 SQM)	● Office (3)	
B00G - R0021 - Communal Space - (77.89 SQM)	● Student Space (36)	
B00G - R0022 - Practical Activities - 1hb - (52.29 SQM)	● Student Space (24)	
B00G - R0024 - Movement - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Withdrawal Space - 1hb - (15.24 SQM)	● Student Space (7)	
B00G - R0026 - Movement - (9.95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0030 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (15.82 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Practical Activities - 1hb - (10.13 SQM)	 Student Space (4)	
B00G - R1003 - Home Base - (48.55 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1004 - Home Base - (47.58 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1005 - Home Base - (48.47 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1006 - Home Base - (48.56 SQM) - Teaching Space: 1	 Student Space (22)	
B00G - R1007 - Movement - (63.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Practical Activities - 1hb - (15.02 SQM)	 Student Space (6)	
B00G - R1014 - Duplicating Workroom - (18.84 SQM)	 Office (4)	
B00G - R1016 - Home Base - (53.14 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R1017 - Home Base - (51.79 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0004 - Movement - (19.71 SQM)	Not Applicable	Circulation or storage space.