


# VENTILATION AUDIT REPORT












<b>SCHOOL:</b>	<b>Crabbes Creek Public School (1674)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Tweed</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tweed</b>

1674 - Crabbes Creek Public School  
Site Plan (14346)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Practical Activities - (14.45 SQM)	 Student Space (6)	
B00A - R0004 - Home Base - (38.71 SQM) - Teaching Space: 1	 Student Space (17)	
B00A - R0005 - Home Base - (37.29 SQM) - Teaching Space: 1	 Student Space (17)	
B00A - R0006 - Practical Activities - 1hb - (13.92 SQM)	 Student Space (6)	
B00A - R0008 - Movement - (32.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Staff Room - (23.36 SQM)	 Office (5)	
B00A - R0010 - Principal - (12.92 SQM)	 Office (3)	
B00A - R0012 - Sick Bay - (6.16 SQM)	 Student Space (2)	
B00A - R0013 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (23.05 SQM)	 Office (5)	
B00B - R0002 - Home Base - (44.96 SQM) - Teaching Space: 1	 Student Space (20)	
B00B - R0004 - Practical Activities - 1hb - (20.16 SQM)	 Student Space (9)	
B00C - R0002 - Canteen - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (23.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (31.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Reading Area - (59.86 SQM)	 Student Space (27)	