

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Crawford Public School (4504)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blacktown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

4504 - Crawford Public School  
Site Plan (10293)



1:952

























Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Withdrawal Space - 1hb - (18.36 SQM)	● Student Space (8)	
B00A - R0001 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Home Base - (56.81 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0003 - Withdrawal Space - 1hb - (16.42 SQM)	● Student Space (7)	
B00A - R0004 - Home Base - (54.75 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0005 - Movement - (16.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (16.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (23.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Practical Activities - 1hb - (39.18 SQM)	● Student Space (18)	
B00A - R0011 - Practical Activities - 1hb - (43.15 SQM)	● Student Space (20)	
B00A - R0013 - Movement - (18.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Room Annexe - (22.62 SQM)	● Office (5)	
B00A - R0017 - Home Base - (63.13 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0018 - Movement - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (17.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Withdrawal Space - 1hb - (12.18 SQM)	● Student Space (5)	
B00A - R0021 - Home Base - (60.68 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - M0001 - Withdrawal Space - 1hb - (18.24 SQM)	● Student Space (8)	
B00B - R0001 - Withdrawal Space - 1hb - (15.35 SQM)	● Student Space (7)	
B00B - R0002 - Home Base - (56.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0003 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (16.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (23.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Practical Activities - 1hb - (39.27 SQM)	● Student Space (18)	
B00B - R0008 - Practical Activities - 1hb - (42.98 SQM)	● Student Space (19)	
B00B - R0012 - Movement - (18.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Staff Room Annexe - (18.5 SQM)	● Office (4)	
B00B - R0015 - Home Base - (63.45 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R0016 - Movement - (21.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Withdrawal Space - 1hb - (12.15 SQM)	● Student Space (5)	
B00B - R0019 - Home Base - (61.29 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0021 - Movement - (16.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (10.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Home Base - (56.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - M0001 - Withdrawal Space - 1hb - (18.34 SQM)	● Student Space (8)	
B00C - R0001 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (56.51 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Withdrawal Space - 1hb - (15.35 SQM)	● Student Space (7)	
B00C - R0005 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (56.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0008 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Withdrawal Space - 1hb - (12.36 SQM)	● Student Space (5)	
B00C - R0012 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (45.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Practical Activities - 1hb - (39.07 SQM)	● Student Space (18)	
B00C - R0015 - Practical Activities - 1hb - (43.17 SQM)	● Student Space (20)	
B00C - R0019 - Movement - (28.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Home Base - (63.7 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0025 - Movement - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0027 - Withdrawal Space - 1hb - (12.22 SQM)	● Student Space (5)	
B00C - R0028 - Home Base - (61.11 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - M0001 - Withdrawal Space - 1hb - (18.42 SQM)	● Student Space (8)	
B00D - R0002 - Movement - (18.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Staff Room Annexe - (18.65 SQM)	● Office (4)	
B00D - R0006 - Home Base - (63.02 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0008 - Movement - (21.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Withdrawal Space - 1hb - (12.14 SQM)	● Student Space (5)	
B00D - R0011 - Home Base - (61.61 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0013 - Home Base - (56.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0015 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Withdrawal Space - 1hb - (15.2 SQM)	● Student Space (7)	
B00D - R0017 - Home Base - (55.33 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0018 - Movement - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Movement - (23.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Practical Activities - 1hb - (39.2 SQM)	● Student Space (18)	
B00D - R0023 - Practical Activities - 1hb - (42.9 SQM)	● Student Space (19)	
B00E - M0001 - Withdrawal Space - 1hb - (18.52 SQM)	● Student Space (8)	
B00E - R0002 - Movement - (27.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (63.65 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0008 - Movement - (16.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (17.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Withdrawal Space - 1hb - (12.15 SQM)	● Student Space (5)	
B00E - R0011 - Home Base - (60.88 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0013 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0014 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Withdrawal Space - 1hb - (15.36 SQM)	● Student Space (7)	
B00E - R0017 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Home Base - (55.21 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0020 - Movement - (17.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (23.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Practical Activities - 1hb - (39.11 SQM)	● Student Space (18)	
B00E - R0023 - Practical Activities - 1hb - (43.25 SQM)	● Student Space (20)	
B00F - R0002 - Movement - (82.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Reading Area - (265.71 SQM)	● Student Space (123)	
B00F - R0007 - Movement - (47.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Interview - (12.2 SQM)	● Office (3)	
B00F - R0011 - Movement - (116.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Special Programs Room - (45.46 SQM)	● Student Space (21)	
B00F - R0017 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Special Programs Room - (45.82 SQM)	● Student Space (21)	
B00G - R0002 - Movement - (79.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Clerical Office/Workroom - (36.07 SQM)	● Office (9)	
B00G - R0006 - Communal Space - (242.05 SQM)	● Student Space (112)	
B00G - R0010 - Raised Platform - (108.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Canteen - (43 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (28.54 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0001 - Clerical Office - (15.8 SQM)	 Office (3)	
B00H - R0002 - Entry Vestibule - (14.65 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (32.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Principal - (23.51 SQM)	 Office (5)	
B00H - R0008 - Sick Bay - (11.46 SQM)	 Student Space (5)	
B00H - R0013 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Staff Room - (67.89 SQM)	 Office (16)	
B00H - R0017 - Deputy Principal - (17.42 SQM)	 Office (4)	
B00H - R0018 - Interview - (11.21 SQM)	 Office (2)	
B00H - R0019 - Staff Room Annexe - (17.43 SQM)	 Office (4)	
B00H - R0020 - Duplicating Workroom - (29.54 SQM)	 Office (7)	
B00H - R0021 - Movement - (21.73 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (34.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (19.98 SQM)	 Student Space (9)	
B00J - R0004 - Home Base - (59.01 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	 Student Space (5)	
B00J - R0006 - Home Base - (59.02 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.97 SQM)	 Student Space (9)	
B00K - R0001 - Special Programs Room - (40.7 SQM)	 Student Space (18)	
B00K - R0003 - Practical Activities - 1hb - (18.89 SQM)	 Student Space (8)	
B00K - R0005 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B00K - R0006 - Practical Activities - S - 1hb - (18.85 SQM)	 Student Space (8)	
B00K - R0009 - Home Base - (60.61 SQM) - Teaching Space: 1	 Student Space (28)	
B00K - R0010 - Home Base - (60.77 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0001 - Practical Activities - 1hb - (18.9 SQM)	 Student Space (8)	
B00L - R0003 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B00L - R0004 - Practical Activities - 1hb - (18.79 SQM)	 Student Space (8)	
B00L - R0006 - Home Base - (60.75 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0007 - Home Base - (60.82 SQM) - Teaching Space: 1	 Student Space (28)	