

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Crescent Head Public School (1681)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Oxley</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Kempsey</b>

1681 - Crescent Head Public School  
Site Plan (12367)



1:979

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (95.44 SQM)	● Student Space (44)	
B00A - R0012 - Canteen - (14.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (43.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (41.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Duplicating Workroom - (12.58 SQM)	● Office (3)	
B00B - R0006 - Movement - (5.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Deputy Principal - (12.7 SQM)	● Office (3)	
B00B - R0008 - Principal - (17.78 SQM)	● Office (4)	
B00B - R0009 - Practical Activities - 1hb - (19.87 SQM)	● Student Space (9)	
B00B - R0010 - Home Base - (57.54 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0011 - Entry Vestibule - (23.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (14.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Clerical Office - (13.5 SQM)	● Office (3)	
B00B - R0014 - Sick Bay - (8.88 SQM)	● Student Space (4)	
B00B - R0017 - Staff Room - (30.24 SQM)	● Office (7)	
B00C - R0007 - Reading Area - (163.41 SQM)	● Student Space (75)	
B00C - R0014 - Movement - (75.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (13.58 SQM)	● Student Space (6)	
B00D - R0005 - Practical Activities - 1hb - (13.58 SQM)	● Student Space (6)	
B00D - R0007 - Home Base - (59.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0008 - Home Base - (59.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0009 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Withdrawal Space - 1hb - (11.5 SQM)	● Student Space (5)	
B00D - R0011 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (13.58 SQM)	● Student Space (6)	
B00E - R0004 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0005 - Withdrawal Space - 1hb - (11.5 SQM)	● Student Space (5)	
B00E - R0006 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0009 - Practical Activities - 1hb - (13.58 SQM)	● Student Space (6)	
B00F - R0001 - Movement - (11.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0002 - Home Base - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Practical Activities - 1hb - (19.81 SQM)	● Student Space (9)	
B00G - R0004 - Practical Activities - 1hb - (19.78 SQM)	● Student Space (9)	
B00G - R0005 - Withdrawal Space - 1hb - (11.64 SQM)	● Student Space (5)	
B00G - R0010 - Movement - (43.02 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Communal Space - (146.54 SQM)	● Student Space (67)	
B00I - R0002 - Raised Platform - (60.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Movement - (11.21 SQM)	Not Applicable	Circulation or storage space.
B00I - R0019 - Canteen - (27.5 SQM)	Not Applicable	Circulation or storage space.
OS 602 10297 - OS 602 10297 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	