

VENTILATION AUDIT REPORT

| | |
|-------------------------------|-------------------------------------|
| SCHOOL: | Crestwood High School (8552) |
| AMU REGION: | Western Sydney |
| STATE ELECTORATE: | Baulkham Hills |
| LOCAL GOVERNMENT AREA: | The Hills |

8552 - Crestwood High School
Site Plan (12368)



1:1,656

Printed: 21-Jul-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R0001 - Seminar - (24.1 SQM) | Office (6) | |
| B00A - R0002 - Duplicating Workroom - (25.28 SQM) | Office (6) | |
| B00A - R0003 - Administration - Clerical - (36.58 SQM) | Office (9) | |
| B00A - R0004 - Movement - (34.76 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0005 - Staff Study - (16.01 SQM) | Office (4) | |
| B00A - R0011 - Public Entry - (78.33 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0012 - Administration - Clerical - (14.84 SQM) | Office (3) | |
| B00A - R0015 - Clinic - Girls - (14.26 SQM) | Office (3) | |
| B00A - R0016 - Staff Study - (17.28 SQM) | Office (4) | |
| B00A - R0017 - Movement - (85.66 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1001 - Commonroom - (111.25 SQM) | Office (27) | |
| B00A - R1002 - Interview/Office - Type 1 - (13.49 SQM) | Office (3) | |
| B00A - R1003 - Staff Study - (13.98 SQM) | Office (3) | |
| B00A - R1004 - Movement - (38.49 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1009 - Deputy Principal Office - (13.92 SQM) | Office (3) | |
| B00A - R1010 - Deputy Principal Office - (14.01 SQM) | Office (3) | |
| B00A - R1011 - Principal Office - (23.23 SQM) | Office (5) | |
| B00B - R0001 - Movement - (19.05 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0004 - General Learning Space - (40.02 SQM) - Teaching Space: 1 | Student Space (18) | |
| B00B - R0005 - General Learning Space - (48.71 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0006 - General Learning Space - (49.35 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0007 - Movement - (98.83 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0010 - General Learning Space - (47.52 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0011 - Performance Workspace - (48.51 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0012 - General Learning Space - (47.61 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0017 - Movement - (11.46 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0018 - Movement - (97.61 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0019 - General Learning Space - (49.58 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R0020 - Computer Learning Space - (48.84 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0024 - General Learning Space - (47.61 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0025 - General Learning Space - (48.06 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0026 - General Learning Space - (49.3 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0027 - Movement - (100.42 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0032 - Movement - (11.46 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0035 - General Learning Space - (47.52 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0036 - General Learning Space - (47.87 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0044 - General Learning Space - (49.3 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00B - R0049 - General Learning Space - (79.16 SQM) - Teaching Space: 1 | Student Space (36) | |
| B00B - R0050 - Seminar - (25.14 SQM) | Office (6) | |
| B00B - R0056 - Staff Study - (22.39 SQM) | Office (5) | |
| B00B - R0058 - Movement - (8.95 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0060 - Special Learning Space - (62.23 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00B - R0063 - Special Learning Space - (53.55 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00B - R0064 - Special Learning Space - (53.55 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00B - R0065 - Special Learning Space - (52.16 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00B - R0074 - Movement - (20.67 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0075 - Movement - (20.68 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0080 - General Learning Space - S/P - (29.27 SQM) - Teaching Space: 1 | Student Space (13) | |
| B00B - R0081 - Special Learning Space - (54.89 SQM) - Teaching Space: 1 | Student Space (25) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00B - R0082 - Movement - (102.77 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0083 - General Learning Space - (63.74 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00B - R0084 - Movement - (92.78 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1001 - Staff Study - (49.75 SQM) | ○ Office (12) | |
| B00B - R1002 - Interview/Office - Type 1 - (16.7 SQM) | ○ Office (4) | |
| B00B - R1003 - General Learning Space - (40.02 SQM) - Teaching Space: 1 | ● Student Space (18) | |
| B00B - R1004 - General Learning Space - (48.73 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1005 - General Learning Space - (49.35 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1006 - Movement - (80.07 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1007 - Seminar - (21.74 SQM) | ○ Office (5) | |
| B00B - R1009 - General Learning Space - (48.18 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1010 - General Learning Space - (48.15 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1011 - General Learning Space - (48.3 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1012 - Interview/Office - Type 1 - (16.7 SQM) | ○ Office (4) | |
| B00B - R1013 - Staff Study - (49.75 SQM) | ○ Office (12) | |
| B00B - R1014 - Movement - (80.43 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1015 - General Learning Space - (49.3 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1016 - General Learning Space - (48.18 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1020 - General Learning Space - (48.3 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1021 - General Learning Space - (48.27 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1022 - General Learning Space - (49.37 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1023 - Movement - (80.65 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1024 - Interview/Office - Type 1 - (16.7 SQM) | ○ Office (4) | |
| B00B - R1025 - Staff Study - (49.75 SQM) | ○ Office (12) | |
| B00B - R1028 - General Learning Space - (48.18 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1029 - General Learning Space - (48.05 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1030 - General Learning Space - (48.3 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1031 - Study Space - (16.7 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1032 - Staff Study - (49.75 SQM) | ○ Office (12) | |
| B00B - R1033 - Movement - (80.38 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1034 - General Learning Space - (49.36 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00B - R1035 - General Learning Space - (38.94 SQM) - Teaching Space: 1 | ● Student Space (18) | |
| B00B - R1037 - Seminar - Type 1 - (20.78 SQM) | ○ Office (5) | |
| B00C - R0001 - Seminar - (10.85 SQM) | ○ Office (2) | |
| B00C - R0002 - Seminar - (10.85 SQM) | ○ Office (2) | |
| B00C - R0003 - Seminar - (10.85 SQM) | ○ Office (2) | |
| B00C - R0004 - Workroom - (49.35 SQM) | ○ Office (12) | |
| B00C - R0006 - Audio Visual Workroom - (36.51 SQM) | ● Student Space (16) | |
| B00C - R0008 - Main Area - (412.76 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0009 - Movement - (6.38 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0010 - Movement - (5.41 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0011 - Movement - (161.26 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0012 - Movement - (46.52 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0004 - Movement - (12.61 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0007 - General Assistants - (9.64 SQM) | ○ Office (2) | |
| B00D - R0009 - Darkroom Space - (27.7 SQM) | ○ Office (6) | |
| B00D - R0011 - Movement - (13.86 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0017 - Movement - (24.26 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0026 - Multi-Purpose Space - (469.01 SQM) | ● Student Space (217) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00D - R0027 - Stage - (100.51 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0001 - Staff Study - (18 SQM) | Office (4) | |
| B00E - R0002 - Seminar - Type 1 - (15.7 SQM) | Office (3) | |
| B00E - R0009 - Movement - (128.17 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0010 - Student Canteen - (59.99 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0014 - Movement - (172.61 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0015 - Movement - (23.91 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Laboratory L.S. - (81.48 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R0002 - Preparation - (45.29 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0005 - Laboratory L.S. - (81.49 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R0010 - Seminar - Type 1 - (22.39 SQM) | Office (5) | |
| B00F - R0011 - Movement - (136.36 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0014 - Staff Study - (32.74 SQM) | Office (8) | |
| B00F - R0015 - Laboratory L.S. - (81.18 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R0016 - Preparation - (47.31 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0017 - Laboratory L.S. - (80.46 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R0020 - Movement - (8.27 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0026 - Movement - (42.72 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1001 - Laboratory L.S. - (81.48 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R1002 - Preparation - (45.19 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1005 - Laboratory L.S. - (81.14 SQM) - Teaching Space: 1 | Student Space (37) | |
| B00F - R1007 - Staff Study - (20.08 SQM) | Office (5) | |
| B00F - R1008 - Music Learning Space - (59.49 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R1009 - Practice/Seminar - (27.23 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1011 - Practice/Seminar - (27.03 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1012 - Music Learning Space - (79.58 SQM) - Teaching Space: 1 | Student Space (36) | |
| B00F - R1013 - Movement - (83.04 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0001 - Art Learning Space - (60.96 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00G - R0002 - Workshop - (60.53 SQM) | Student Space (28) | |
| B00G - R0003 - Art Learning Space - (59.62 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0011 - Art Entry/Display - (74.97 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0012 - Art Learning Space - (61.65 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00G - R0013 - Art Learning Space - (61.2 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00G - R0014 - Staff Study - (22.37 SQM) | Office (5) | |
| B00G - R0015 - Seminar - Type 1 - (30.72 SQM) | Office (7) | |
| B00G - R0018 - Movement - (108.85 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0019 - Movement - (60.4 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R1001 - Design L.S. - (70.19 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00G - R1002 - Staff Study - (30.09 SQM) | Office (7) | |
| B00G - R1004 - Design L.S. - (69.3 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00G - R1006 - Food Technology L.S. - (105.37 SQM) - Teaching Space: 1 | Student Space (48) | |
| B00G - R1007 - Food/Research Space - (5.73 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R1009 - Food Technology L.S. - (105.36 SQM) - Teaching Space: 1 | Student Space (48) | |
| B00G - R1010 - Movement - (113.36 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R1012 - Movement - (37.52 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0001 - Materials Technology L.S. - (90.79 SQM) - Teaching Space: 1 | Student Space (42) | |
| B00H - R0002 - Wood Technology Bay - (30.8 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0004 - Materials Technology L.S. - (90.78 SQM) - Teaching Space: 1 | Student Space (42) | |
| B00H - R0005 - Movement - (81.67 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0012 - T.A.S. Outdoor Area - (69.06 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|--|-------------------------------|
| B00H - R0013 - Welding Area - (15.46 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0014 - Movement - (73.14 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0001 - Materials Technology L.S. - (81.35 SQM) - Teaching Space: 1 | ● Student Space (37) | |
| B00I - R0002 - Welding Area - (10.23 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0003 - Metal Technology Bay - (27.88 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0004 - Welding Area - (10.23 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0005 - Materials Technology L.S. - (81.35 SQM) - Teaching Space: 1 | ● Student Space (37) | |
| B00I - R0006 - Movement - (48.12 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0007 - Movement - (26.04 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0008 - Movement - (25.96 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R1001 - Computer Learning Space - (56.52 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B00I - R1003 - Design L.S. - (54.87 SQM) - Teaching Space: 1 | ● Student Space (25) | |
| B00I - R1004 - Staff Study - (28.29 SQM) | ● Office (7) | |
| B00I - R1005 - Movement - (41.83 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R1006 - Movement - (9.37 SQM) | Not Applicable | Circulation or storage space. |