


VENTILATION AUDIT REPORT

SCHOOL:	Crestwood Public School (4441)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Baulkham Hills
LOCAL GOVERNMENT AREA:	The Hills

4441 - Crestwood Public School
Site Plan (10297)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Duplicating Workroom - (13.39 SQM)	Office (3)	
B00A - R0009 - Movement - (25.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room - (52.54 SQM)	Office (13)	
B00A - R0013 - Staff Room Annexe - (17.79 SQM)	Office (4)	
B00A - R0014 - Interview - (16.69 SQM)	Office (4)	
B00A - R0020 - Deputy Principal - (15.96 SQM)	Office (3)	
B00A - R0023 - Principal - (22.22 SQM)	Office (5)	
B00A - R0024 - Movement - (14.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview - (7.31 SQM)	Office (1)	
B00A - R0026 - Clerical Office - (7.53 SQM)	Office (1)	
B00A - R0027 - Clerical Office - (12.85 SQM)	Office (3)	
B00A - R0028 - Entry Vestibule - (22.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Deputy Principal - (23.28 SQM)	Office (5)	
B00B - R0003 - Home Base - (65.67 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0004 - Movement - (34.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (66.33 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0006 - Home Base - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0011 - Home Base - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1001 - Home Base - (66.02 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1002 - Movement - (17.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Movement - (34.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (65.8 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1005 - Home Base - (65.52 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1007 - Movement - (16.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Home Base - (65.58 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0005 - Communal Space - (149.76 SQM)	Student Space (69)	
B00D - R0002 - Practical Activities - 1hb - (12.53 SQM)	Student Space (5)	
B00D - R0003 - Home Base - (68.86 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0004 - Withdrawal Space - 1hb - (26.3 SQM)	Student Space (12)	
B00D - R0006 - Practical Activities - 1hb - (20.61 SQM)	Student Space (9)	
B00D - R0007 - Home Base - (61.23 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Home Base - (68.26 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0009 - Practical Activities - 1hb - (12.98 SQM)	Student Space (6)	
B00D - R0010 - Staff Room Annexe - (15.56 SQM)	Office (3)	
B00D - R0012 - Practical Activities - 1hb - (12.98 SQM)	Student Space (6)	
B00D - R0013 - Home Base - (68.5 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0002 - Home Base - (93.38 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0008 - Home Base - (62.12 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0009 - Home Base - (62.27 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0010 - Practical Activities - 1hb - (7.88 SQM)	Student Space (3)	
B00E - R0015 - Home Base - (93.17 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0002 - Home Base - (80.6 SQM) - Teaching Space: 1	Student Space (37)	
B00F - R0005 - Movement - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Practical Activities - 1hb - (15.99 SQM)	Student Space (7)	
B00F - R1001 - Home Base - (72.37 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R1002 - Movement - (96.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Home Base - (75.82 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R1007 - Practical Activities - 1hb - (19.62 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1008 - Home Base - (75 SQM) - Teaching Space: 1	● Student Space (34)	
B00F - R1009 - Special Programs Room - (11.18 SQM)	● Student Space (5)	
B00F - R1011 - Movement - (11.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R1012 - Home Base - (77.56 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R1013 - Practical Activities - 1hb - (19.46 SQM)	● Student Space (9)	
B00F - R1014 - Movement - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Reading Area - (163.36 SQM)	● Student Space (75)	
B00G - R0003 - Reading Area - (83.92 SQM)	● Student Space (38)	
B00G - R0004 - Seminar/Study - (13.84 SQM)	● Office (3)	
B00G - R0005 - Seminar/Study - (13.8 SQM)	● Office (3)	
B00G - R0009 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Canteen - (42.88 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (91.2 SQM)	● Student Space (42)	
B00J - R0002 - Staff Room - (6.16 SQM)	● Office (1)	
B00L - R0001 - Communal Space - (203.33 SQM)	● Student Space (94)	
B00L - R0002 - Raised Platform - (62.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (12.56 SQM)	Not Applicable	Circulation or storage space.
B00L - R0021 - Canteen - (41.39 SQM)	Not Applicable	Circulation or storage space.
OH 060 17020 - OH 060 17020 - OSHC Hub 60 - (SQM)	● Student Space ()	
OS 601 14181 - OS 601 14181 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14183 - OS 601 14183 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10570 - OS 602 10570 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11944 - OS 602 11944 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13434 - OS 602 13434 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13511 - OS 602 13511 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15349 - OS 602 15349 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15561 - OS 602 15561 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18057 - OS 602 18057 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 13459 - OS 603 13459 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 750 14371 - OS 750 14371 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	