

VENTILATION AUDIT REPORT

SCHOOL:	Cromer Public School (4241)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches

4241 - Cromer Public School
Site Plan (12369)



















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Deputy Principal - (12.53 SQM)	Office (3)	
B00A - R0003 - Staff Room Annexe - (12.53 SQM)	Office (3)	
B00A - R0004 - Sick Bay - (8.17 SQM)	Student Space (3)	
B00A - R0010 - Movement - (35.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room - (107.47 SQM)	Office (26)	
B00A - R0013 - Entry Vestibule - (18.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (15.62 SQM)	Office (3)	
B00A - R0015 - Principal - (21.68 SQM)	Office (5)	
B00A - R0016 - Deputy Principal - (12.46 SQM)	Office (3)	
B00A - R0017 - Interview - (12.46 SQM)	Office (3)	
B00A - R0022 - Movement - (36.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Reading Area - (257.8 SQM)	Student Space (119)	
B00A - R1005 - Seminar/Study - (15.33 SQM)	Office (3)	
B00A - R1006 - Seminar/Study - (13.82 SQM)	Office (3)	
B00A - R1012 - Movement - (32.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (11.71 SQM)	Student Space (5)	
B00B - R0002 - Home Base - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0003 - Home Base - (88.54 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0005 - Practical Activities - 1hb - (8.1 SQM)	Student Space (3)	
B00B - R0006 - Movement - (42.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (13.61 SQM)	Student Space (6)	
B00C - R0004 - Home Base - (78.8 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0005 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Staff Room Annexe - (6.13 SQM)	Office (1)	
B00C - R0007 - Practical Activities - 1hb - (10.75 SQM)	Student Space (4)	
B00C - R0008 - Practical Activities - 1hb - (10.75 SQM)	Student Space (4)	
B00C - R0009 - Home Base - (82.43 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0014 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Staff Room - (19.87 SQM)	Office (4)	
B00C - R0018 - Home Base - (56.41 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0019 - Practical Activities - 1hb - (10.73 SQM)	Student Space (4)	
B00C - R0020 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Practical Activities - 1hb - (10.73 SQM)	Student Space (4)	
B00C - R0023 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0024 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0025 - Practical Activities - 1hb - (10.73 SQM)	Student Space (4)	
B00C - R0028 - Movement - (163.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0009 - Practical Activities - 1hb - (18.53 SQM)	Student Space (8)	
B00D - R0010 - Movement - (140.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Home Base - (50.97 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1002 - Practical Activities - 1hb - (18.54 SQM)	Student Space (8)	
B00D - R1003 - Home Base - (50.97 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1004 - Practical Activities - 1hb - (18.53 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1005 - Special Programs Room - (48.17 SQM)	● Student Space (22)	
B00D - R1006 - Home Base - (51.51 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1007 - Practical Activities - 1hb - (18.73 SQM)	● Student Space (8)	
B00D - R1008 - Movement - (65.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0006 - Practical Activities - 1hb - (10.43 SQM)	● Student Space (4)	
B00F - R0008 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Practical Activities - 1hb - (10.43 SQM)	● Student Space (4)	
B00F - R0010 - Home Base - (56.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0011 - Home Base - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0012 - Practical Activities - 1hb - (10.5 SQM)	● Student Space (4)	
B00F - R0014 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Practical Activities - 1hb - (10.5 SQM)	● Student Space (4)	
B00F - R0016 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0017 - Special Programs Room - (49.73 SQM)	● Student Space (23)	
B00F - R0018 - Practical Activities - 1hb - (14.4 SQM)	● Student Space (6)	
B00F - R0023 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0024 - Practical Activities - 1hb - (10.61 SQM)	● Student Space (4)	
B00F - R0027 - Practical Activities - 1hb - (10.61 SQM)	● Student Space (4)	
B00F - R0028 - Home Base - (56.55 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0029 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0030 - Practical Activities - 1hb - (10.53 SQM)	● Student Space (4)	
B00F - R0033 - Practical Activities - 1hb - (10.53 SQM)	● Student Space (4)	
B00F - R0034 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R9002 - Special Programs Room - (55.39 SQM)	● Student Space (25)	
B00G - R0001 - Practical Activities - M - 1hb - (14.86 SQM)	● Student Space (6)	
B00G - R0002 - Special Programs Room - (43.25 SQM)	● Student Space (20)	
B00G - R0003 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0004 - Practical Activities - 1hb - (14.94 SQM)	● Student Space (6)	
B00H - R0004 - Movement - (120.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Canteen - (36.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Communal Space - (263.48 SQM)	● Student Space (122)	
B00H - R1003 - Raised Platform - (77.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R1007 - Movement - (25.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R1008 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (60.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0002 - Practical Activities - 1hb - (17.29 SQM)	● Student Space (8)	
B00I - R0004 - Withdrawal Space - 1hb - (9.36 SQM)	● Student Space (4)	
B00I - R0005 - Home Base - (61.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0006 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B00I - R0008 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00I - R0009 - Home Base - (60.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0010 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00I - R1001 - Home Base - (58.38 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R1002 - Practical Activities - 1hb - (20.29 SQM)	● Student Space (9)	
B00I - R1004 - Withdrawal Space - 1hb - (9.16 SQM)	● Student Space (4)	
B00I - R1005 - Home Base - (60.22 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R1006 - Practical Activities - 1hb - (18.99 SQM)	 Student Space (8)	
B00I - R1008 - Withdrawal Space - 2hb - (11.55 SQM)	 Student Space (5)	
B00I - R1009 - Home Base - (60.12 SQM) - Teaching Space: 1	 Student Space (27)	
B00I - R1010 - Practical Activities - 1hb - (19.36 SQM)	 Student Space (8)	
B00J - R0001 - Home Base - (50.14 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R0002 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R0003 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R0004 - Home Base - (50.92 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R0005 - Home Base - (50.91 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R0006 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R0007 - Movement - (61.63 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R1002 - Home Base - (50.91 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R1003 - Home Base - (50.92 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R1004 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R1005 - Practical Activities - 1hb - (18.19 SQM)	 Student Space (8)	
B00J - R1006 - Home Base - (50.14 SQM) - Teaching Space: 1	 Student Space (23)	
B00J - R1007 - Movement - (61.63 SQM)	Not Applicable	Circulation or storage space.