


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Croydon Park Public School (7412)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Strathfield</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Burwood</b>

7412 - Croydon Park Public School  
Site Plan (13032)







1:793

Printed: 11-May-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Staff Room - (15.46 SQM)	Office (3)	
B00A - R0007 - Practical Activities - 1hb - (46.75 SQM)	Student Space (21)	
B00A - R0008 - Home Base - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0009 - Home Base - (46.95 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0010 - Withdrawal Space - 1hb - (19.39 SQM)	Student Space (8)	
B00A - R0012 - Interview - (15.52 SQM)	Office (3)	
B00A - R0015 - Movement - (51.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Communal Space - (146.56 SQM)	Student Space (67)	
B00A - R0024 - Raised Platform - (23.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (18.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Movement - (73.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (48.7 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - Home Base - (47.98 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Home Base - (47.84 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - Home Base - (47.63 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Canteen - (17.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (53.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Principal - (29.71 SQM)	Office (7)	
B00E - R0011 - Clerical Office - (46.71 SQM)	Office (11)	
B00E - R0012 - Home Base - (46.4 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0013 - Practical Activities - 1hb - (19.98 SQM)	Student Space (9)	
B00E - R0014 - Practical Activities - 1hb - (8.16 SQM)	Student Space (3)	
B00E - R0015 - Withdrawal Space - 1hb - (65.82 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0016 - Home Base - (46.19 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0017 - Practical Activities - 1hb - (15.74 SQM)	Student Space (7)	
B00E - R0021 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (102.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Home Base - (73.68 SQM)	Student Space (34)	
B00E - R0024 - Duplicating Workroom - (30.47 SQM)	Office (7)	
B00E - R0025 - Staff Room - (49.98 SQM) - Teaching Space: 1	Office (12)	
B00E - R1002 - Movement - (100.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Home Base - (46.11 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R1004 - Withdrawal Space - 1hb - (46.66 SQM)	Student Space (21)	
B00E - R1005 - Home Base - (46.32 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R1006 - Home Base - (46.25 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R1007 - Withdrawal Space - 1hb - (46.33 SQM)	Student Space (21)	
B00F - R0002 - Home Base - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0003 - Withdrawal Space - 1hb - (57.4 SQM)	Student Space (26)	
B00G - R0001 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Seminar/Study - (67.45 SQM)	Office (16)	
B00G - R0007 - Reading Area - (167.16 SQM)	Student Space (77)	
B00G - R0012 - Movement - (24.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (15.42 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (46.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Home Base - (49.63 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R1004 - Home Base - (68.24 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R1005 - Home Base - (69.55 SQM) - Teaching Space: 1	Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1006 - Home Base - (50.47 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R1007 - Movement - (45.65 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Communal Space - (145.15 SQM)	 Student Space (67)	
B00L - R0002 - Raised Platform - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Canteen - (26.38 SQM)	Not Applicable	Circulation or storage space.
OS 602 10038 - OS 602 10038 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 18267 - OS 602 18267 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	