



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Entry Vestibule - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Interview - (13.69 SQM)	Office (3)	
B00A - R0006 - Principal - (19.35 SQM)	Office (4)	
B00A - R0007 - Staff Kitchen - (14.25 SQM)	Office (3)	
B00A - R0008 - Staff Room - (93.99 SQM)	Office (23)	
B00A - R0015 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Deputy Principal - (12.72 SQM)	Office (3)	
B00A - R0019 - Duplicating Workroom - (17.35 SQM)	Office (4)	
B00A - R0020 - Sick Bay - (8.46 SQM)	Student Space (3)	
B00A - R0021 - Clerical Office - (13.42 SQM)	Office (3)	
B00A - R0022 - Movement - (30.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Special Programs Room - Type 2 - (119.38 SQM)	Student Space (55)	
B00A - R0033 - Special Programs Room - Type 2 - (21.54 SQM)	Student Space (9)	
B00A - R0034 - Special Programs Room - Type 2 - (17.38 SQM)	Student Space (8)	
B00A - R0035 - Movement - (37.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (10.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Reading Area - (209.4 SQM)	Student Space (97)	
B00A - R1010 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (43.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Reading Area - (279.04 SQM)	Student Space (129)	
B00E - R0001 - Withdrawal Space - 1hb - (40.04 SQM)	Student Space (18)	
B00E - R0002 - Movement - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Special Programs Room - (89.13 SQM)	Student Space (41)	
B00E - R0006 - Raised Platform - (21.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (86.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (74.33 SQM)	Student Space (34)	
B00E - R0009 - Practical Activities - 1hb - (19.06 SQM)	Student Space (8)	
B00E - R0010 - Withdrawal Space - 1hb - (25.14 SQM)	Student Space (11)	
B00E - R0011 - Withdrawal Space - 1hb - (21.84 SQM)	Student Space (10)	
B00E - R0012 - Home Base - (49.02 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0013 - Practical Activities - 1hb - (18.81 SQM)	Student Space (8)	
B00E - R0023 - Withdrawal Space - 1hb - (22.62 SQM)	Student Space (10)	
B00E - R0024 - Home Base - (73.67 SQM)	Student Space (34)	
B00E - R0025 - Practical Activities - 1hb - (19.97 SQM)	Student Space (9)	
B00E - R0027 - Deputy Principal - (18.96 SQM)	Office (4)	
B00E - R0034 - Interview - (12.28 SQM)	Office (3)	
B00E - R0035 - Movement - (21.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Staff Room - (81.72 SQM)	Office (20)	
B00E - R0037 - Staff Kitchen - (48.14 SQM)	Office (12)	
B00E - R0038 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0039 - Withdrawal Space - 1hb - (9.51 SQM)	Student Space (4)	
B00E - R0041 - Movement - (87.73 SQM)	Not Applicable	Circulation or storage space.
B00E - R0042 - Sick Bay - (10.55 SQM)	Student Space (4)	
B00E - R0047 - Interview - (11.04 SQM)	Office (2)	
B00E - R0048 - Clerical Office/Workroom - (70.26 SQM)	Office (17)	
B00E - R0049 - Interview - (12.74 SQM)	Office (3)	
B00E - R0052 - Entry Vestibule - (9.97 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0053 - Clerical Office/Workroom - (88.76 SQM)	Office (22)	
B00H - R0002 - Communal Space - (289.69 SQM)	Student Space (134)	
B00H - R0005 - Movement - (16.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Canteen - (42.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Raised Platform - (42.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (18.47 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (11.78 SQM)	Student Space (5)	
B00I - R0004 - Home Base - (88.22 SQM) - Teaching Space: 1	Student Space (40)	
B00I - R0009 - Movement - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Home Base - (51.03 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0011 - Practical Activities - 1hb - (18.23 SQM)	Student Space (8)	
B00I - R0013 - Interview - (15.11 SQM)	Office (3)	
B00I - R0017 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Home Base - (51.18 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0021 - Practical Activities - 1hb - (18.23 SQM)	Student Space (8)	
B00I - R0026 - Practical Activities - 1hb - (10.55 SQM)	Student Space (4)	
B00I - R0027 - Home Base - (88.12 SQM) - Teaching Space: 1	Student Space (40)	
B00I - R0029 - Practical Activities - 1hb - (20.36 SQM)	Student Space (9)	
B00I - R0030 - Home Base - (74.19 SQM) - Teaching Space: 1	Student Space (34)	
B00I - R0031 - Movement - (85.26 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Practical Activities - 1hb - (18.23 SQM)	Student Space (8)	
B00I - R1002 - Home Base - (51.65 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R1003 - Withdrawal Space - 1hb - (32.78 SQM)	Student Space (15)	
B00I - R1011 - Withdrawal Space - 2hb - (32.71 SQM)	Student Space (15)	
B00I - R1012 - Practical Activities - 1hb - (18.35 SQM)	Student Space (8)	
B00I - R1013 - Home Base - (51.87 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1014 - Home Base - (51.79 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R1015 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00I - R1016 - Practical Activities - 1hb - (18.23 SQM)	Student Space (8)	
B00I - R1017 - Home Base - (51.65 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R1019 - Movement - (84.78 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Clerical Office - (14.08 SQM)	Office (3)	
B00P - R0004 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00P - R0006 - Home Base - (50.55 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0007 - Home Base - (50.63 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0008 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00P - R0011 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00P - R0015 - Withdrawal Space - 1hb - (17.53 SQM)	Student Space (8)	
B00P - R0016 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00P - R0017 - Home Base - (51.18 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0020 - Movement - (12.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R0021 - Movement - (105.09 SQM)	Not Applicable	Circulation or storage space.
B00P - R0022 - Home Base - (50.94 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0023 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00P - R0024 - Withdrawal Space - 1hb - (17.53 SQM)	Student Space (8)	
B00P - R0025 - Movement - (12.88 SQM)	Not Applicable	Circulation or storage space.
B00P - R1005 - Withdrawal Space - 1hb - (10.36 SQM)	Student Space (4)	
B00P - R1006 - Practical Activities - 1hb - (18.21 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R1007 - Home Base - (51.58 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1008 - Home Base - (51.87 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1009 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00P - R1010 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00P - R1011 - Home Base - (51.73 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1012 - Home Base - (51.64 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1013 - Practical Activities - 1hb - (18.22 SQM)	Student Space (8)	
B00P - R1016 - Withdrawal Space - 1hb - (9.8 SQM)	Student Space (4)	
B00P - R1017 - Movement - (66.64 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Home Base - (60.46 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0002 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0003 - Practical Activities - 1hb - (18.97 SQM)	Student Space (8)	
B00Q - R0004 - Practical Activities - 1hb - (19.17 SQM)	Student Space (8)	
B00Q - R0005 - Withdrawal Space - 2hb - (12.59 SQM)	Student Space (5)	
B00Q - R1001 - Home Base - (60.1 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R1002 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R1003 - Practical Activities - 1hb - (18.85 SQM)	Student Space (8)	
B00Q - R1004 - Practical Activities - 1hb - (18.96 SQM)	Student Space (8)	
B00Q - R1005 - Withdrawal Space - 2hb - (12.11 SQM)	Student Space (5)	
OS 602 11078 - OS 602 11078 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11325 - OS 602 11325 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 12208 - OS 603 12208 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 612 11909 - OS 612 11909 - Learning Unit - Double With Resource - (152 SQM)	Student Space (70)	
OS 612 12409 - OS 612 12409 - Learning Unit - Double With Resource - (152 SQM)	Student Space (70)	
OS 612 16375 - OS 612 16375 - Learning Unit - Double With Resource - (152 SQM)	Student Space (70)	
OS 612 18130 - OS 612 18130 - Learning Unit - Double With Resource - (152 SQM)	Student Space (70)	
OS 801 10257 - OS 801 10257 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.
OS 801 14184 - OS 801 14184 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.