

VENTILATION AUDIT REPORT

SCHOOL:	Cudgen Public School (1696)
AMU REGION:	North Coast
STATE ELECTORATE:	Tweed
LOCAL GOVERNMENT AREA:	Tweed

1696 - Cudgen Public School
Site Plan (12375)



1:513

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (19.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (18.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (18.51 SQM)	Office (4)	
B00A - R0004 - Clerical Office - (12.87 SQM)	Office (3)	
B00A - R0005 - Duplicating Workroom - (18.51 SQM)	Office (4)	
B00A - R0006 - Sick Bay - (9.11 SQM)	Student Space (4)	
B00A - R0009 - Staff Room - (37.41 SQM)	Office (9)	
B00A - R0010 - Movement - (21.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (18.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Special Programs Room - (35.03 SQM)	Student Space (16)	
B00A - R0016 - Home Base - (54.42 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0017 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Interview - (7.55 SQM)	Office (1)	
B00A - R0027 - Withdrawal Space - 1hb - (12.18 SQM)	Student Space (5)	
B00A - R0029 - Movement - (11.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Home Base - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0031 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Deputy Principal - (9.94 SQM)	Office (2)	
B00A - R0038 - Home Base - (62.34 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0044 - Movement - (11.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (35.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (26.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (70.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Practical Activities - 1hb - (11.81 SQM)	Student Space (5)	
B00A - R0059 - Reading Area - (110.31 SQM)	Student Space (51)	
B00A - R0060 - Special Programs Room - (43.87 SQM)	Student Space (20)	
B00C - R0001 - Movement - (15.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (42.13 SQM) - Teaching Space: 1	Student Space (19)	
B00C - R0003 - Practical Activities - 1hb - (10.89 SQM)	Student Space (5)	
B00F - R0001 - Home Base - (60.38 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0002 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0003 - Practical Activities - 1hb - (19.06 SQM)	Student Space (8)	
B00F - R0004 - Practical Activities - 1hb - (19.1 SQM)	Student Space (8)	
B00F - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	Student Space (5)	
B00F - R0008 - Movement - (43.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (114.4 SQM)	Student Space (53)	
B00H - R0001 - Canteen - (13.57 SQM)	Not Applicable	Circulation or storage space.
OS 602 11694 - OS 602 11694 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 16278 - OS 603 16278 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	