

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Culcairn Public School (1698)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Greater Hume</b>

1698 - Culcairn Public School  
Site Plan (12376)



1:675

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (16.12 SQM)	Office (4)	
B00A - R0002 - Clerical Office - (15.47 SQM)	Office (3)	
B00B - R0001 - Home Base - (48.48 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0002 - Home Base - (47.97 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0005 - Movement - (44.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (49.38 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0010 - Withdrawal Space - 1hb - (34.97 SQM)	Student Space (16)	
B00B - R0011 - Home Base - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0012 - Duplicating Workroom - (19.16 SQM)	Office (4)	
B00B - R0013 - Movement - (70.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (26.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (49.19 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Withdrawal Space - 1hb - (12.32 SQM)	Student Space (5)	
B00C - R0004 - Staff Room Annexe - (6.97 SQM)	Office (1)	
B00D - R0001 - Home Base - (53.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Movement - (9.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Special Programs Room - (48.44 SQM)	Student Space (22)	
B00F - R0001 - Staff Room - (26.27 SQM)	Office (6)	
B00F - R0005 - Reading Area - (92.33 SQM)	Student Space (42)	
B00F - R0008 - Movement - (46.69 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Reading Area - (90.25 SQM)	Student Space (41)	