

VENTILATION AUDIT REPORT

SCHOOL:	Curran Public School (4460)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

4460 - Curran Public School
Site Plan (10285)































1:869

Printed: 01-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Practical Activities - 1hb - (10 SQM)	Student Space (4)	
B00A - R0006 - Home Base - M - (89.51 SQM)	Student Space (41)	
B00A - R0007 - Home Base - (89.51 SQM)	Student Space (41)	
B00A - R0008 - Practical Activities - 1hb - (10 SQM)	Student Space (4)	
B00A - R0015 - Movement - (26.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Communal Space - (108.35 SQM)	Student Space (50)	
B00A - R0022 - Practical Activities - 1hb - (10 SQM)	Student Space (4)	
B00A - R0025 - Practical Activities - 1hb - (10 SQM)	Student Space (4)	
B00A - R0027 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (20.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (61.76 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1002 - Practical Activities - 1hb - (12.52 SQM)	Student Space (5)	
B00A - R1003 - Home Base - (74.65 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1004 - Home Base - (58.71 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1005 - Practical Activities - 1hb - (13.92 SQM)	Student Space (6)	
B00A - R1006 - Practical Activities - 1hb - (12.89 SQM)	Student Space (5)	
B00A - R1007 - Home Base - (61.35 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1008 - Home Base - (60.97 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1009 - Practical Activities - 1hb - (12.86 SQM)	Student Space (5)	
B00A - R1010 - Practical Activities - 1hb - (13.97 SQM)	Student Space (6)	
B00A - R1011 - Home Base - (60.19 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1012 - Home Base - (63.78 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1013 - Practical Activities - 1hb - (10.41 SQM)	Student Space (4)	
B00A - R1014 - Practical Activities - 1hb - (12.86 SQM)	Student Space (5)	
B00A - R1015 - Home Base - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1016 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (161.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Entry Vestibule - (15.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Clerical Office - (17 SQM)	Office (4)	
B00B - R0009 - Sick Bay - (15.81 SQM)	Student Space (7)	
B00B - R0010 - Duplicating Workroom - (17.38 SQM)	Office (4)	
B00B - R0013 - Entry Vestibule - (13.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Clerical Office - (15.41 SQM)	Office (3)	
B00B - R0015 - Principal - (17.06 SQM)	Office (4)	
B00B - R0018 - Staff Room Annexe - (15.13 SQM)	Office (3)	
B00B - R0021 - Staff Room Annexe - (15.13 SQM)	Office (3)	
B00B - R0022 - Reading Area - (217.07 SQM)	Student Space (100)	
B00B - R0025 - Movement - (14.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Staff Room - (56.85 SQM)	Office (14)	
B00B - R0032 - Staff Room Annexe - (21.19 SQM)	Office (5)	
B00B - R0033 - Staff Kitchen - (11.86 SQM)	Office (2)	
B00B - R0034 - Movement - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Withdrawal Space - 1hb - (82.83 SQM)	Student Space (38)	
B00B - R0036 - Movement - (40.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Movement - (182.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (116.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0016 - Home Base - (55.93 SQM) - Teaching Space: 1	 Student Space (25)	
B00C - R0017 - Practical Activities - 1hb - (18.59 SQM)	 Student Space (8)	
B00C - R0018 - Movement - (113.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Practical Activities - 1hb - (16.98 SQM)	 Student Space (7)	
B00D - R0006 - Home Base - (55.02 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0013 - Withdrawal Space - 1hb - (5.15 SQM)	 Student Space (2)	
B00D - R0014 - Staff Kitchen - (11.48 SQM)	 Office (2)	
B00D - R0015 - Home Base - (55.29 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0016 - Home Base - (55.29 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0017 - Practical Activities - 1hb - (11.48 SQM)	 Student Space (5)	
B00D - R0018 - Withdrawal Space - 1hb - (5.13 SQM)	 Student Space (2)	
B00D - R0022 - Practical Activities - 1hb - (16.91 SQM)	 Student Space (7)	
B00D - R0023 - Home Base - (55.36 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0029 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Practical Activities - 1hb - (16.91 SQM)	 Student Space (7)	
B00D - R0033 - Home Base - (55.36 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0034 - Home Base - (55.37 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0035 - Practical Activities - 1hb - (16.91 SQM)	 Student Space (7)	
B00D - R0039 - Movement - (20.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Movement - (21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Movement - (21.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0042 - Movement - (21.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Practical Activities - 1hb - (18.22 SQM)	 Student Space (8)	
B00D - R1003 - Home Base - (55.12 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1004 - Home Base - (55.2 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1005 - Practical Activities - 1hb - (18.55 SQM)	 Student Space (8)	
B00D - R1006 - Home Base - (55.2 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1007 - Practical Activities - 1hb - (18.54 SQM)	 Student Space (8)	
B00D - R1008 - Practical Activities - 1hb - (18.22 SQM)	 Student Space (8)	
B00D - R1009 - Home Base - (55.12 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1010 - Home Base - (55.11 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1011 - Practical Activities - 1hb - (18.23 SQM)	 Student Space (8)	
B00D - R1012 - Practical Activities - 1hb - (74.33 SQM)	 Student Space (34)	
B00D - R1013 - Practical Activities - 1hb - (18.45 SQM)	 Student Space (8)	
B00D - R1014 - Home Base - M - (55.19 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1015 - Practical Activities - 1hb - (18.31 SQM)	 Student Space (8)	
B00D - R1016 - Home Base - (55.12 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1017 - Movement - (161.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (109.42 SQM)	 Student Space (50)	
B00E - R0002 - Raised Platform - (84.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Movement - (19.56 SQM)	Not Applicable	Circulation or storage space.