


VENTILATION AUDIT REPORT

| | |
|-------------------------------|---------------------------------|
| SCHOOL: | Dapto High School (8204) |
| AMU REGION: | Southern NSW |
| STATE ELECTORATE: | Shellharbour |
| LOCAL GOVERNMENT AREA: | Wollongong |

8204 - Dapto High School
Site Plan (12465)



Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Interview/Meeting - (15.46 SQM) | Office (3) | |
| B00A - R0007 - Principal Office - (19.47 SQM) | Office (4) | |
| B00A - R0008 - Interview/Meeting - (11.1 SQM) | Office (2) | |
| B00A - R0009 - Student Reception - (12.27 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0013 - Clinic - (17.03 SQM) | Office (4) | |
| B00A - R0014 - Administration - Clerical - (10.54 SQM) | Office (2) | |
| B00A - R0019 - Movement - (31.56 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0021 - Movement - (13.37 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0023 - Public Entry - (58.31 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0026 - Administration - Clerical - (52.18 SQM) | Office (13) | |
| B00A - R0027 - Staff Kitchen - (10.51 SQM) | Office (2) | |
| B00B - R0001 - Food Technology L.S. - (63.91 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00B - R0009 - Deputy Principal Office - (19.1 SQM) | Office (4) | |
| B00B - R0013 - Staff Study - (22.88 SQM) | Office (5) | |
| B00B - R0034 - Movement - (18.77 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0037 - Movement - (6.05 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0038 - Preparation - Materials - (22.27 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0039 - Kitchen - Type 1 - (100.36 SQM) | Student Space (46) | |
| B00B - R0044 - Movement - (68.29 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0047 - Movement - (168.91 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0048 - Student Canteen - (57.91 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1001 - Design L.S. - (65.13 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00B - R1005 - Design L.S. - (50.42 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R1008 - Seminar - (31.4 SQM) | Office (7) | |
| B00B - R1011 - General Learning Space - (64.89 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00B - R1012 - General Learning Space - (65.25 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00B - R1013 - General Learning Space - (64.97 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00B - R1014 - General Learning Space - (65.17 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00B - R1015 - General Learning Space - (51.91 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00B - R1018 - Movement - (144.79 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Senior Study - (80.47 SQM) | Office (20) | |
| B00C - R0005 - Movement - (98.96 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0006 - General Learning Space - (51.92 SQM) - Teaching Space: 1 | Student Space (24) | |
| B00C - R0007 - Laboratory L.S. - (87.53 SQM) - Teaching Space: 1 | Student Space (40) | |
| B00C - R0008 - Preparation - (25.69 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0010 - Interview/Office - Type 1 - (12.08 SQM) | Office (3) | |
| B00C - R0011 - Interview/Office - Type 1 - (24.77 SQM) | Office (6) | |
| B00C - R0017 - Outdoor Learning Area - (67.76 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1001 - Computer Learning Space - (85.02 SQM) - Teaching Space: 1 | Student Space (39) | |
| B00C - R1004 - Movement - (80.5 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1005 - Staff Study - (52.21 SQM) | Office (13) | |
| B00C - R1009 - Stage - (21.57 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R1010 - Performance Workspace - (105.12 SQM) - Teaching Space: 1 | Student Space (48) | |
| B00C - R1014 - Interview/Meeting - (11.95 SQM) | Office (2) | |
| B00D - R0004 - Movement - (11.27 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0016 - Movement - (6.33 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0018 - Workshop Area - (6.63 SQM) | Student Space (3) | |
| B00D - R0020 - Wood Technology L.S. - (96.37 SQM) - Teaching Space: 1 | Student Space (44) | |
| B00D - R0021 - Metal Technology L.S. - (98.05 SQM) - Teaching Space: 1 | Student Space (45) | |
| B00D - R0023 - Movement - (6.14 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00D - R0027 - Materials Technology L.S. - (93.91 SQM) - Teaching Space: 1 | ● Student Space (43) | |
| B00D - R0031 - Workshop Area - (99.52 SQM) | ● Student Space (46) | |
| B00E - R0004 - Preparation - (17.29 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0006 - Laboratory L.S. - (88.98 SQM) - Teaching Space: 1 | ● Student Space (41) | |
| B00E - R0007 - Interview/Meeting - (19.19 SQM) | ● Office (4) | |
| B00E - R0008 - Interview/Meeting - (15.02 SQM) | ● Office (3) | |
| B00E - R0009 - Staff Study - (10.83 SQM) | ● Office (2) | |
| B00E - R0011 - Staff Study - (25.45 SQM) | ● Office (6) | |
| B00E - R0012 - Staff Study - (38.92 SQM) | ● Office (9) | |
| B00E - R0013 - Staff Study - (38.85 SQM) | ● Office (9) | |
| B00E - R0016 - General Learning Space - (51.99 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00E - R0028 - Commonroom - (99.84 SQM) | ● Office (24) | |
| B00E - R0030 - Movement - (174.04 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R1005 - Staff Study - (34.44 SQM) | ● Office (8) | |
| B00E - R1007 - General Learning Space - (51.99 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00E - R1008 - General Learning Space - (52.06 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00E - R1009 - General Learning Space - (51.27 SQM) - Teaching Space: 1 | ● Student Space (23) | |
| B00E - R1010 - General Learning Space - (52.13 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00E - R1012 - Interview/Office - Type 1 - (18.8 SQM) | ● Office (4) | |
| B00E - R1015 - General Learning Space - (52.14 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00E - R1016 - General Learning Space - (65.12 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R1021 - Computer Learning Space - (65.98 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00E - R1026 - Movement - (144.44 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0003 - General Learning Space - (52.13 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00F - R0006 - General Learning Space - (52.13 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00F - R0021 - Movement - (6.98 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0022 - General Learning Space - (61.65 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00F - R0023 - General Learning Space - (42.88 SQM) - Teaching Space: 1 | ● Student Space (19) | |
| B00F - R0024 - General Learning Space - (36.37 SQM) - Teaching Space: 1 | ● Student Space (16) | |
| B00F - R0025 - Practical Activities - (24.74 SQM) | ● Student Space (11) | |
| B00F - R0028 - Staff Room - (22.03 SQM) | ● Office (5) | |
| B00F - R0030 - Movement - (90.98 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0031 - Staff Lounge - (44.46 SQM) | ● Office (11) | |
| B00F - R1001 - Computer Learning Space - (65.68 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00F - R1005 - Staff Study - (24.85 SQM) | ● Office (6) | |
| B00F - R1007 - Staff Study - (51.7 SQM) | ● Office (12) | |
| B00F - R1008 - General Learning Space - (52.21 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00F - R1009 - General Learning Space - (51.93 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00F - R1010 - General Learning Space - (52.21 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00F - R1012 - Movement - (90.77 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1013 - Movement - (32.66 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0004 - Multi-Purpose Space - (401.51 SQM) | ● Student Space (186) | |
| B00H - R0005 - Staff Kitchen - (13.09 SQM) | ● Office (3) | |
| B00H - R0010 - Stage - (87.53 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0023 - Staff Study - (22.48 SQM) | ● Office (5) | |
| B00H - R0030 - Staff Study - (12.38 SQM) | ● Office (3) | |
| B00J - R0004 - Staff Study - (26 SQM) | ● Office (6) | |
| B00J - R0006 - Design L.S. - (51.06 SQM) - Teaching Space: 1 | ● Student Space (23) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00J - R0010 - Design L.S. - (52.49 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00J - R0011 - Movement - (32.54 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R1004 - Art Learning Space - (51.9 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00J - R1009 - Art Learning Space - (64.26 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00K - R0003 - Duplicating Workroom - (18.11 SQM) | ● Office (4) | |
| B00K - R0005 - Staff Study - (25.39 SQM) | ● Office (6) | |
| B00K - R0006 - General Learning Space - (52.79 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R0007 - General Learning Space - (52.86 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R0008 - General Learning Space - (52.86 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R0009 - General Learning Space - (52.85 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R0010 - Staff Study - (25.91 SQM) | ● Office (6) | |
| B00K - R1006 - General Learning Space - (52.56 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R1007 - General Learning Space - (53.58 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R1008 - General Learning Space - (52.7 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R1009 - General Learning Space - (52.7 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00K - R1012 - Art Learning Space - (52.26 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00L - R0001 - Laboratory L.S. - (94.22 SQM) - Teaching Space: 1 | ● Student Space (43) | |
| B00L - R0005 - Laboratory L.S. - (94.22 SQM) - Teaching Space: 1 | ● Student Space (43) | |
| B00L - R0007 - General Assistants - (25.8 SQM) | ● Office (6) | |
| B00L - R0013 - Preparation - Science - (38.67 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0014 - Movement - (6.08 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R1001 - Laboratory L.S. - (92.69 SQM) - Teaching Space: 1 | ● Student Space (43) | |
| B00L - R1003 - Preparation - (28.73 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R1005 - Laboratory L.S. - (92.75 SQM) - Teaching Space: 1 | ● Student Space (43) | |
| B00L - R1012 - Staff Study - (51.1 SQM) | ● Office (12) | |
| B00M - R0006 - Movement - (31.07 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R1001 - General Learning Space - (52.56 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00M - R1005 - General Learning Space - (52.64 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B00N - R0007 - Workshop Area - (61.64 SQM) | ● Student Space (28) | |
| B00O - R0002 - Movement - (41.21 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0003 - Multi-Purpose Space - (177.58 SQM) | ● Student Space (82) | |
| B00O - R0004 - Gymnasium - (103.02 SQM) | ● Student Space (47) | |
| B00P - R0007 - Workroom - (50.6 SQM) | ● Office (12) | |
| B00P - R0011 - Audio Visual Workroom - (49.86 SQM) | ● Student Space (23) | |
| B00P - R0012 - Movement - (56.39 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R0014 - Main Area - (219.52 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R0017 - Main Entry - (30.77 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R1001 - Interview/Meeting - (16.2 SQM) | ● Office (4) | |
| B00P - R1003 - Main Area - (117.66 SQM) | Not Applicable | Circulation or storage space. |
| B00P - R1005 - Seminar - (16.08 SQM) | ● Office (4) | |
| B00P - R1006 - Seminar - (16.49 SQM) | ● Office (4) | |
| B00P - R1007 - Deputy Principal Office - (16.65 SQM) | ● Office (4) | |
| B00P - R1009 - Main Area - (117.01 SQM) | Not Applicable | Circulation or storage space. |
| B00R - R0001 - General Assistants - (40.71 SQM) | ● Office (10) | |
| B00T - R0001 - General Learning Space - (61.67 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00V - R0001 - General Learning Space - Bd/Cd/Ed - (61.61 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| OS 601 11419 - OS 601 11419 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |
| OS 601 11994 - OS 601 11994 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |