

VENTILATION AUDIT REPORT

SCHOOL:	Darcy Road Public School (4222)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta












4222 - Darcy Road Public School
Site Plan (12466)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0006 - Movement - (5.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Home Base - (56.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0009 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0011 - Interview/Meeting - (16.37 SQM)	● Office (4)	
B00A - R0015 - Movement - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (57.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0004 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0011 - Home Base - (57.39 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0001 - Canteen - (17.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Special Programs Room - (19.39 SQM)	● Student Space (8)	
B00D - R0003 - Movement - (22.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Reading Area - (114.69 SQM)	● Student Space (53)	
B00D - R0014 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Special Programs Room - (58.57 SQM)	● Student Space (27)	
B00E - R0004 - Movement - (17.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Staff Kitchen - (9.89 SQM)	● Office (2)	
B00E - R0008 - Staff Room - (92.56 SQM)	● Office (23)	
B00F - R0003 - Staff Kitchen - (7.53 SQM)	● Office (1)	
B00F - R0006 - Clerical/Printing - (13.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Sick Bay - (8.74 SQM)	● Student Space (4)	
B00F - R0008 - Principal - (14.63 SQM)	● Office (3)	
B00F - R0009 - Clerical Office - (58.65 SQM)	● Office (14)	
B00G - R0001 - Home Base - (67.54 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0004 - Movement - (15.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Home Base - (67.52 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R0010 - Movement - (28.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (68.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Deputy Principal - (10.41 SQM)	● Office (2)	
B00H - R0005 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (53.32 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0007 - Home Base - (53.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0008 - Home Base - (53.32 SQM) - Teaching Space: 1	● Student Space (24)	
B00Q - R0001 - Communal Space - (147.1 SQM)	● Student Space (68)	
B00Q - R0002 - Raised Platform - (59.98 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0016 - Movement - (11.87 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0017 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
OS 601 10260 - OS 601 10260 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10495 - OS 601 10495 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10134 - OS 602 10134 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11763 - OS 602 11763 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11888 - OS 602 11888 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11957 - OS 602 11957 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12006 - OS 602 12006 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12055 - OS 602 12055 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13204 - OS 602 13204 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13403 - OS 602 13403 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 13550 - OS 602 13550 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13742 - OS 602 13742 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14155 - OS 602 14155 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14220 - OS 602 14220 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14466 - OS 602 14466 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15138 - OS 602 15138 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15863 - OS 602 15863 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16359 - OS 602 16359 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17691 - OS 602 17691 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 18315 - OS 602 18315 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 750 17705 - OS 750 17705 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	