

VENTILATION AUDIT REPORT

SCHOOL:	Davidson High School (8479)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Davidson
LOCAL GOVERNMENT AREA:	Northern Beaches

8479 - Davidson High School
Site Plan (10681)



1:1,826


















Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0003 - Main Entry - (13.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Main Area - (194.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Computer Room - (7.84 SQM)	● Student Space (3)	
B00L - R0011 - Movement - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Tiered Learning Area - (11.94 SQM)	● Student Space (5)	
B00L - R1004 - Main Area - (114.58 SQM)	Not Applicable	Circulation or storage space.
B00L - R1010 - Movement - (6.42 SQM)	Not Applicable	Circulation or storage space.
B00L - R1011 - Study Space - (21 SQM)	Not Applicable	Circulation or storage space.
B00L - R1012 - Study Space - (41.58 SQM)	Not Applicable	Circulation or storage space.
B00L - R1013 - Leading Teacher - (15.69 SQM)	○ Office (3)	
B00L - R1015 - Movement - (7.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R1019 - Study Space - (79.23 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0011 - Interview/Office - Type 1 - (13.36 SQM)	○ Office (3)	
BOAM - R0017 - Staff Study - (12.25 SQM)	○ Office (3)	
BOAM - R0020 - Administration - Clerical - (11.16 SQM)	○ Office (2)	
BOAM - R0021 - Clinic - (11.13 SQM)	○ Office (2)	
BOAM - R0026 - Principal Office - (22.05 SQM)	○ Office (5)	
BOAM - R0044 - Student Waiting - (10.41 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0046 - Movement - (43.62 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0049 - Seminar - (125.69 SQM)	○ Office (31)	
BOAM - R0050 - Staff Study - (25.47 SQM)	○ Office (6)	
BOAM - R0051 - Movement - (27.12 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0053 - Commonroom - (113.13 SQM)	○ Office (28)	
BOAM - R0054 - Staff Kitchen - (11.94 SQM)	○ Office (2)	
BOAM - R0057 - Public Reception - (16.2 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0058 - Administration - Clerical - (41.87 SQM)	○ Office (10)	
BOAM - R0063 - Deputy Principal Office - (24.23 SQM)	○ Office (6)	
BOAM - R0065 - Deputy Principal Office - (20.88 SQM)	○ Office (5)	
BOAM - R0067 - Movement - (43.71 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1001 - Administration - Clerical - (12.82 SQM)	○ Office (3)	
BOAM - R1005 - Interview/Office - Type 1 - (12.71 SQM)	○ Office (3)	
BOAM - R1010 - Staff Study - (39.78 SQM)	○ Office (9)	
BOAM - R1011 - General Learning Space - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1012 - General Learning Space - (64.78 SQM) - Teaching Space: 1	● Student Space (30)	
BOAM - R1013 - Computer Learning Space - (64.69 SQM) - Teaching Space: 1	● Student Space (30)	
BOAM - R1014 - Computer Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1015 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1016 - General Learning Space - (52.11 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1020 - Movement - (74.35 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1024 - General Assistants - (8.73 SQM)	○ Office (2)	
BOAM - R1025 - Movement - (49.48 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1027 - Movement - (20.7 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1028 - Computer Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1029 - Staff Study - (28.99 SQM)	○ Office (7)	
BOC1 - R0004 - Art Learning Space - (70.86 SQM) - Teaching Space: 1	● Student Space (32)	
BOC1 - R0005 - Art Learning Space - (69.74 SQM) - Teaching Space: 1	● Student Space (32)	
BOC1 - R1002 - Staff Study - (13.6 SQM)	○ Office (3)	
BOC1 - R1003 - Staff Study - (19.66 SQM)	○ Office (4)	
BOC1 - R1004 - Design L.S. - (69.72 SQM) - Teaching Space: 1	● Student Space (32)	
BOC1 - R1007 - Design L.S. - (69.6 SQM) - Teaching Space: 1	● Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0C2 - R0001 - Art Learning Space - (66.41 SQM) - Teaching Space: 1	Student Space (30)	
B0C2 - R0004 - Wood Technology L.S. - (78.63 SQM) - Teaching Space: 1	Student Space (36)	
B0C2 - R0008 - Wood Technology L.S. - (78.46 SQM) - Teaching Space: 1	Student Space (36)	
B0C2 - R0013 - Food/Research Space - (64.17 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R0015 - Wood Technology Bay - (12.71 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R1003 - Staff Study - (31.85 SQM)	Office (7)	
B0C2 - R1004 - Food Technology L.S. - (96.1 SQM) - Teaching Space: 1	Student Space (44)	
B0C2 - R1006 - Preparation - Materials - (16.69 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R1008 - Food Technology L.S. - (93.91 SQM) - Teaching Space: 1	Student Space (43)	
B0C3 - R0014 - Metal Technology L.S. - (116.08 SQM) - Teaching Space: 1	Student Space (53)	
B0C3 - R0015 - Welding Area - (7.06 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0017 - Materials Workshop - Type 2 - (61.36 SQM)	Student Space (28)	
B0C3 - R1001 - Music Learning Space - (56.1 SQM) - Teaching Space: 1	Student Space (26)	
B0C3 - R1005 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R1006 - Design L.S. - (66.1 SQM) - Teaching Space: 1	Student Space (30)	
B0C3 - R1012 - Design/Technology L.S. - (90.67 SQM) - Teaching Space: 1	Student Space (42)	
B0EL - R0001 - General Learning Space - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R0002 - General Learning Space - (50.5 SQM) - Teaching Space: 1	Student Space (23)	
B0EL - R0003 - General Learning Space - (67.94 SQM) - Teaching Space: 1	Student Space (31)	
B0EL - R0004 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R0005 - Staff Study - (45.28 SQM)	Office (11)	
B0EL - R0017 - Dark Room - (26.99 SQM)	Office (6)	
B0EL - R0038 - Performance Workshop - (54.05 SQM)	Student Space (25)	
B0EL - R0039 - Performance Workshop - (52.87 SQM)	Student Space (24)	
B0EL - R0040 - Staff Study - (23.22 SQM)	Office (5)	
B0EL - R0042 - Photographic Studio - (24.42 SQM)	Office (6)	
B0EL - R1001 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1002 - General Learning Space - (50.85 SQM) - Teaching Space: 1	Student Space (23)	
B0EL - R1003 - General Learning Space - (65.93 SQM) - Teaching Space: 1	Student Space (30)	
B0EL - R1004 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1005 - Staff Study - (46.87 SQM)	Office (11)	
B0EL - R1010 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1011 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1012 - General Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1013 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B0EL - R1020 - Staff Study - (23.89 SQM)	Office (5)	
B0HC - R0001 - General Learning Space - (67.23 SQM) - Teaching Space: 1	Student Space (31)	
B0HC - R0002 - General Learning Space - (66.75 SQM) - Teaching Space: 1	Student Space (30)	
B0HC - R0003 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B0HC - R0006 - Staff Study - (42.12 SQM)	Office (10)	
B0HC - R0009 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B0HC - R0010 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B0HC - R0023 - Staff Study - (22.87 SQM)	Office (5)	
B0HC - R1001 - General Learning Space - (65.8 SQM) - Teaching Space: 1	Student Space (30)	
B0HC - R1002 - General Learning Space - (65.61 SQM) - Teaching Space: 1	Student Space (30)	
B0HC - R1003 - General Learning Space - (53.17 SQM) - Teaching Space: 1	Student Space (24)	
B0HC - R1010 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHC - R1017 - Computer Learning Space - (72.81 SQM) - Teaching Space: 1	 Student Space (33)	
BOHC - R1018 - Staff Study - (22.37 SQM)	 Office (5)	
BOS1 - R0010 - Staff Study - (23.97 SQM)	 Office (5)	
BOS1 - R1006 - Staff Study - (12.36 SQM)	 Office (3)	
BOS2 - R0001 - Laboratory L.S. - (93.8 SQM) - Teaching Space: 1	 Student Space (43)	
BOS2 - R0005 - Laboratory L.S. - (94.19 SQM) - Teaching Space: 1	 Student Space (43)	
BOS2 - R0006 - General Assistants - (17.68 SQM)	 Office (4)	
BOS2 - R0012 - Preparation - (49.75 SQM)	Not Applicable	Circulation or storage space.
BOS2 - R1001 - Computer Learning Space - (92.77 SQM) - Teaching Space: 1	 Student Space (43)	
BOS2 - R1003 - Preparation - Science - (45.84 SQM)	Not Applicable	Circulation or storage space.
BOS2 - R1005 - Laboratory L.S. - (92.68 SQM) - Teaching Space: 1	 Student Space (42)	
BOS3 - R0001 - Laboratory L.S. - (94.19 SQM) - Teaching Space: 1	 Student Space (43)	
BOS3 - R0002 - Preparation - Science - (51.29 SQM)	Not Applicable	Circulation or storage space.
BOS3 - R0005 - Laboratory L.S. - (93.8 SQM) - Teaching Space: 1	 Student Space (43)	
BOS3 - R1001 - Laboratory L.S. - (92.59 SQM) - Teaching Space: 1	 Student Space (42)	
BOS3 - R1007 - Laboratory L.S. - (92.5 SQM) - Teaching Space: 1	 Student Space (42)	
BOS3 - R1008 - Preparation - Science - (50.66 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0005 - Multi-Purpose Space - (457.83 SQM)	 Student Space (212)	
BOSC - R0006 - Performance Workspace - (100.38 SQM) - Teaching Space: 1	 Student Space (46)	
BOSC - R0019 - Student Canteen - (59.47 SQM)	Not Applicable	Circulation or storage space.
BOSC - R1006 - Music Learning Space - (78.47 SQM) - Teaching Space: 1	 Student Space (36)	
BOSC - R1008 - Music Learning Space - (81.34 SQM) - Teaching Space: 1	 Student Space (37)	
BOSC - R1020 - Practice/Seminar - (61.91 SQM)	Not Applicable	Circulation or storage space.
BOSC - R1029 - Movement - (24.66 SQM)	Not Applicable	Circulation or storage space.