

VENTILATION AUDIT REPORT

SCHOOL:	Dawson Public School (4446)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

4446 - Dawson Public School
Site Plan (10328)



1:977

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (102.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (93.77 SQM)	Office (23)	
B00A - R0003 - Staff Kitchen - (8.02 SQM)	Office (2)	
B00A - R0005 - Movement - (15.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (64.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Room Annexe - (15.61 SQM)	Office (3)	
B00A - R0014 - Movement - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (15.26 SQM)	Office (3)	
B00A - R0018 - Interview - (7.33 SQM)	Office (1)	
B00A - R0019 - Entry Vestibule - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (15.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Interview - (7.92 SQM)	Office (1)	
B00A - R0022 - Deputy Principal - (18.81 SQM)	Office (4)	
B00A - R0026 - Duplicating Workroom - (15.61 SQM)	Office (3)	
B00A - R0027 - Sick Bay - (9.33 SQM)	Student Space (4)	
B00A - R0028 - Clerical Office - (14.01 SQM)	Office (3)	
B00B - R0001 - Movement - (100.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Communal Space - (159.61 SQM)	Student Space (74)	
B00B - R0004 - Raised Platform - (39.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Canteen - (25.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (29.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (68.46 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0004 - Movement - (13.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (55.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0007 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0008 - Movement - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Home Base - (69.23 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0012 - Movement - (18.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Home Base - (69.15 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R1003 - Movement - (55.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1005 - Home Base - (68.98 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R1006 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0001 - Movement - (89.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Reading Area - (177.72 SQM)	Student Space (82)	
B00D - R0003 - Seminar/Study - (52.86 SQM)	Office (13)	
B00D - R0004 - Seminar/Study - (6.43 SQM)	Office (1)	
B00D - R0006 - Movement - (28.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (86.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0007 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0009 - Home Base - (60.29 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0014 - Home Base - (59.96 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0001 - Movement - (86.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Communal Space - (108.52 SQM)	Student Space (50)	
B00F - R0005 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0006 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0001 - Movement - (86.38 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Home Base - (91.63 SQM) - Teaching Space: 1	● Student Space (42)	
B00G - R0015 - Home Base - (60.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0001 - Movement - (95.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (92.52 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0003 - Home Base - (92.64 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0012 - Home Base - (94.87 SQM) - Teaching Space: 1	● Student Space (44)	
B00J - R0001 - Movement - (27.07 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - Pre - (42.5 SQM) - Teaching Space: 1	● Student Space (19)	
B00J - R0013 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Movement - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (60.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Practical Activities - Pre - (18.67 SQM)	● Student Space (8)	
B00K - R0004 - Home Base - Pre - (50.69 SQM) - Teaching Space: 1	● Student Space (23)	
B00K - R0006 - Home Base - Pre - (46.27 SQM) - Teaching Space: 1	● Student Space (21)	
B00K - R0007 - Practical Activities - Pre - (23.04 SQM)	● Student Space (10)	
B00M - R0001 - Communal Space - (147.57 SQM)	● Student Space (68)	
B00M - R0002 - Raised Platform - (59.93 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Movement - (11.52 SQM)	Not Applicable	Circulation or storage space.