

VENTILATION AUDIT REPORT

| | |
|-------------------------------|-------------------------------------|
| SCHOOL: | Dee Why Public School (1744) |
| AMU REGION: | Northern Sydney |
| STATE ELECTORATE: | Wakehurst |
| LOCAL GOVERNMENT AREA: | Northern Beaches |

1744 - Dee Why Public School
Site Plan (10954)



1:652

Printed: 20-May-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Staff Room - (54.33 SQM) | Office (13) | |
| B00A - R0009 - Deputy Principal - (15.08 SQM) | Office (3) | |
| B00A - R0011 - Principal - (17.91 SQM) | Office (4) | |
| B00A - R0013 - Movement - (30.82 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0015 - Sick Bay - (10.71 SQM) | Student Space (4) | |
| B00A - R0016 - Clerical Office - (10.71 SQM) | Office (2) | |
| B00A - R0019 - Entry Vestibule - (13.58 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0020 - Clerical Office/Workroom - (47.46 SQM) | Office (11) | |
| B00A - R0021 - Home Base - (47.44 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00A - R0022 - Movement - (37.05 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0023 - Home Base - (45.68 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0026 - Home Base - (45.68 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0028 - Movement - (71.44 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0029 - Movement - (36.49 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0030 - Home Base - (47.13 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0031 - Home Base - (47.13 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0045 - Staff Kitchen - (28.26 SQM) | Office (7) | |
| B00A - R9008 - Canteen - (27.54 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0001 - Movement - (11.73 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0002 - Communal Space - (217.26 SQM) | Student Space (100) | |
| B00B - R0003 - Movement - (6.03 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0008 - Raised Platform - (46.68 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0013 - Movement - (6.03 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0005 - Staff Room Annexe - (12.24 SQM) | Office (3) | |
| B00C - R0006 - Staff Room Annexe - (12.6 SQM) | Office (3) | |
| B00C - R0007 - Movement - (28.96 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0010 - Special Programs Room - (52.85 SQM) | Student Space (24) | |
| B00C - R0011 - Reading Area - (187.03 SQM) | Student Space (86) | |
| B00C - R0012 - Movement - (15.09 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R9007 - Movement - (173.9 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Home Base - (60.49 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00D - R0002 - Home Base - (59.5 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R0003 - Home Base - (59.5 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R0008 - Home Base - (58.75 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R0009 - Home Base - (59.82 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R0012 - Home Base - (60.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R0017 - Movement - (143.57 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0018 - Movement - (6.53 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R1001 - Home Base - (60.49 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00D - R1004 - Home Base - (59.5 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R1005 - Home Base - (59.5 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R1010 - Home Base - (58.75 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R1011 - Home Base - (59.82 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R1014 - Home Base - (60.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00D - R1020 - Movement - (123.5 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0016 - Clerical Office - (10.74 SQM) | Office (2) | |
| B00F - R0049 - Movement - (34.99 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0050 - Movement - (34.48 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0051 - Child Care Centre - (8.41 SQM) | Student Space (3) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00F - R0052 - Child Care Centre - (12.75 SQM) | Student Space (5) | |
| B00F - R0053 - Child Care Centre - (18.25 SQM) | Student Space (8) | |
| B00F - R0054 - Child Care Centre - (13.9 SQM) | Student Space (6) | |
| B00F - R0055 - Child Care Centre - (6.73 SQM) | Student Space (3) | |
| B00F - R0056 - Child Care Centre - (24.42 SQM) | Student Space (11) | |
| B00F - R0057 - Child Care Centre - (23.51 SQM) | Student Space (10) | |
| B00F - R0058 - Child Care Centre - (125.71 SQM) | Student Space (58) | |
| B00F - R0059 - Child Care Centre - (10.19 SQM) | Student Space (4) | |
| B00F - R0062 - Child Care Centre - (75.53 SQM) | Student Space (35) | |
| B00F - R0063 - Child Care Centre - (9.59 SQM) | Student Space (4) | |
| B00F - R0064 - Child Care Centre - (68.46 SQM) | Student Space (31) | |
| B00F - R0065 - Child Care Centre - (68.76 SQM) | Student Space (31) | |
| B00F - R0066 - Child Care Centre - (72.68 SQM) | Student Space (33) | |
| B00F - R0068 - Child Care Centre - (8.99 SQM) | Student Space (4) | |
| B00F - R0069 - Child Care Centre - (5.64 SQM) | Student Space (2) | |
| B00F - R0070 - Child Care Centre - (45.98 SQM) | Student Space (21) | |
| B00F - R0084 - Child Care Centre - (9.59 SQM) | Student Space (4) | |
| B00F - R0085 - Child Care Centre - (54.55 SQM) | Student Space (25) | |
| B00F - R0086 - Child Care Centre - (21.78 SQM) | Student Space (10) | |
| B00F - R0087 - Child Care Centre - (10.19 SQM) | Student Space (4) | |
| B00F - R0088 - Child Care Centre - (25.15 SQM) | Student Space (11) | |
| B00F - R0089 - Child Care Centre - (10.75 SQM) | Student Space (4) | |
| B00F - R0090 - Child Care Centre - (8.85 SQM) | Student Space (4) | |
| B00F - R0091 - Child Care Centre - (11.38 SQM) | Student Space (5) | |
| B00F - R1011 - Interview - (10.79 SQM) | Office (2) | |
| B00F - R1016 - Staff Room Annexe - (10.37 SQM) | Office (2) | |
| B00F - R1019 - Staff Room - (36.05 SQM) | Office (9) | |
| B00F - R1021 - Movement - (43.91 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R1022 - Child Care Centre - (70.33 SQM) | Student Space (32) | |
| B00G - R0001 - Practical Activities - (19.09 SQM) | Student Space (8) | |
| B00G - R0002 - Home Base - (59.96 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0004 - Withdrawal Space - 2hb - (11.75 SQM) | Student Space (5) | |
| B00G - R0005 - Practical Activities - (19.07 SQM) | Student Space (8) | |
| B00G - R0006 - Home Base - (60.17 SQM) - Teaching Space: 1 | Student Space (27) | |
| OS 600 13702 - OS 600 13702 - Learning Unit - Small - (57 SQM) | Student Space (26) | |
| OS 602 10521 - OS 602 10521 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 11848 - OS 602 11848 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 606 11249 - OS 606 11249 - Learning Unit - Standard With P.A.A A/C - (SQM) | Student Space () | |
| OS 606 13169 - OS 606 13169 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19113 - OS 606 19113 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19809 - OS 606 19809 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19812 - OS 606 19812 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |