

VENTILATION AUDIT REPORT




















SCHOOL:	Delegate Public School (1745)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Snowy Monaro

1745 - Delegate Public School
Site Plan (12470)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Reading Area - (103.69 SQM)	 Student Space (48)	
B00B - R0012 - Clerical Office - (11.65 SQM)	 Office (2)	
B00B - R0015 - Movement - (11.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Staff Room - (21.65 SQM)	 Office (5)	
B00B - R0017 - Principal - (14.42 SQM)	 Office (3)	
B00C - R0007 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (43.85 SQM)	 Student Space (20)	
B00D - R0003 - Canteen - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (20.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (20.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Practical Activities - 1hb - (25.32 SQM)	 Student Space (11)	
B00F - R0005 - Withdrawal Space - 1hb - (5.78 SQM)	 Student Space (2)	
B00F - R0006 - Home Base - (50.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0007 - Home Base - (50.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0008 - Withdrawal Space - 1hb - (5.78 SQM)	 Student Space (2)	
B00F - R0010 - Practical Activities - 1hb - (26.02 SQM)	 Student Space (12)	
B00F - R0011 - Communal Space - (64 SQM)	 Student Space (29)	
B00F - R0012 - Movement - (19.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Practical Activities - 1hb - (25.41 SQM)	 Student Space (11)	
B00F - R0016 - Withdrawal Space - 1hb - (5.77 SQM)	 Student Space (2)	
B00F - R0017 - Home Base - (50.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0018 - Home Base - (50.76 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0019 - Withdrawal Space - 1hb - (5.77 SQM)	 Student Space (2)	
B00F - R0021 - Practical Activities - 1hb - (26.02 SQM)	 Student Space (12)	
B00G - R0001 - Communal Space - (61.37 SQM)	 Student Space (28)	