


VENTILATION AUDIT REPORT

SCHOOL:	Delungra Public School (1747)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Inverell

1747 - Delungra Public School
Site Plan (13376)













1:661

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (6.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Reading Area - (43.87 SQM)	 Student Space (20)	
B00A - R0004 - Reading Area - (11.79 SQM)	 Student Space (5)	
B00A - R0005 - Movement - (29.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (40.38 SQM) - Teaching Space: 1	 Student Space (18)	
B00A - R0008 - Home Base - (44.44 SQM) - Teaching Space: 1	 Student Space (20)	
B00A - R0009 - Home Base - (38.86 SQM) - Teaching Space: 1	 Student Space (18)	
B00A - R0012 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (47.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (56.92 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0011 - Staff Room - (27.95 SQM)	 Office (6)	
B00B - R0012 - Clerical Office - (13.77 SQM)	 Office (3)	
B00B - R0013 - Principal - (13.76 SQM)	 Office (3)	
B00F - R0001 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (60 SQM)	 Student Space (27)	