


VENTILATION AUDIT REPORT

SCHOOL:	Denison College of Secondary Education (Bathurst) (8103)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Bathurst

8103 - Denison College of Secondary Education (Bathurst)
Site Plan (12315)



1:1,527

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - M1001 - Senior Study - (25.55 SQM)	Office (6)	
B00H - M1002 - Senior Study - (23.29 SQM)	Office (5)	
B00H - R0001 - General Learning Space - (61.4 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0002 - General Learning Space - (55.08 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0003 - General Learning Space - (54.81 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0006 - Movement - (48.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Movement - (15.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Study - (23.53 SQM)	Office (5)	
B00H - R0009 - General Learning Space - (49.81 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0010 - General Learning Space - (54.79 SQM) - Teaching Space: 1	Student Space (25)	
B00H - R0011 - General Learning Space - (61.42 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0018 - Performance Workspace - (110.51 SQM) - Teaching Space: 1	Student Space (51)	
B00H - R0021 - Staff Study - (45.22 SQM)	Office (11)	
B00H - R0027 - Movement - (177.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R0032 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Audio Visual Workroom - (63.7 SQM)	Student Space (29)	
B00H - R1003 - General Learning Space - (56.83 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R1004 - General Learning Space - (64.35 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1007 - Movement - (20.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R1008 - Movement - (13.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R1009 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00H - R1011 - Interview/Office - Type 1 - (13.2 SQM)	Office (3)	
B00H - R1012 - Seminar - (12.1 SQM)	Office (3)	
B00H - R1013 - Seminar - (14.53 SQM)	Office (3)	
B00H - R1014 - Interview - (10.65 SQM)	Office (2)	
B00H - R1016 - Entry - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R1019 - Movement - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R1021 - Workroom - (42.48 SQM)	Office (10)	
B00H - R1028 - Main Area - (236.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R9003 - Movement - (12.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R9006 - Senior Study - (49.8 SQM)	Office (12)	
B00H - R9008 - Senior Study - (49.8 SQM)	Office (12)	
B00H - R9012 - Movement - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R9015 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R9016 - Senior Study - (78.78 SQM)	Office (19)	
B00K - R0018 - Design L.S. - (66.19 SQM) - Teaching Space: 1	Student Space (30)	
B00K - R0019 - Staff Study - (26.55 SQM)	Office (6)	
B00K - R0021 - Movement - (7.34 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Art Learning Space - (66.03 SQM) - Teaching Space: 1	Student Space (30)	
B00K - R0026 - Art Learning Space - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
B00K - R0034 - Seminar - (32.55 SQM)	Office (8)	
B00K - R0035 - Food Technology L.S. - (85.42 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0036 - Preparation - (22.39 SQM)	Not Applicable	Circulation or storage space.
B00K - R0043 - Preparation - Materials - (17.24 SQM)	Not Applicable	Circulation or storage space.
B00K - R0044 - Food Technology L.S. - (119.41 SQM) - Teaching Space: 1	Student Space (55)	
B00K - R0050 - Movement - (250.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R1003 - Music Learning Space - (79.21 SQM) - Teaching Space: 1	Student Space (36)	
B00K - R1005 - Music Learning Space - (93.26 SQM) - Teaching Space: 1	Student Space (43)	
B00K - R1009 - Art Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R1016 - General Learning Space - Type 2 - (65.98 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R1017 - Computer Learning Space - (79.36 SQM) - Teaching Space: 1	● Student Space (36)	
B00K - R1018 - Staff Study - (26.33 SQM)	● Office (6)	
B00K - R1024 - Movement - (292.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R9002 - General Assistants - (18.06 SQM)	● Office (4)	
B00K - R9020 - Movement - (38.04 SQM)	Not Applicable	Circulation or storage space.
B00K - R9025 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00K - R9026 - General Assistants - (79.38 SQM)	● Office (19)	
B00K - R9028 - Materials Technology L.S. - (196.46 SQM) - Teaching Space: 1	● Student Space (91)	
B00N - R0008 - Movement - (49.44 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - General Learning Space - (49.51 SQM) - Teaching Space: 1	● Student Space (22)	
B00N - R0010 - General Learning Space - (48.75 SQM) - Teaching Space: 1	● Student Space (22)	
B00N - R0011 - General Learning Space - (49.93 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R0012 - Staff Study - (23.55 SQM)	● Office (5)	
B00N - R0015 - Movement - (24.26 SQM)	Not Applicable	Circulation or storage space.
B00N - R0021 - Materials Learning Space - Type 1 - (129.29 SQM) - Teaching Space: 1	● Student Space (59)	
B00N - R0022 - Movement - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00N - R0023 - Materials Learning Space - Type 1 - (91.27 SQM) - Teaching Space: 1	● Student Space (42)	
B00N - R1001 - General Learning Space - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R1002 - General Learning Space - (50.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R1003 - General Learning Space - (50.44 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R1004 - General Learning Space - (51.15 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R1005 - Movement - (67.42 SQM)	Not Applicable	Circulation or storage space.
B00N - R1009 - Movement - (54.69 SQM)	Not Applicable	Circulation or storage space.
B00N - R1010 - Interview - (12.31 SQM)	● Office (3)	
B00N - R1011 - Interview - (12.54 SQM)	● Office (3)	
B00N - R1012 - Staff Study - (12.52 SQM)	● Office (3)	
B00N - R1013 - Staff Study - (16.21 SQM)	● Office (4)	
B00N - R1016 - Movement - (176.51 SQM)	Not Applicable	Circulation or storage space.
B00N - R1017 - Student Canteen - (68.35 SQM)	Not Applicable	Circulation or storage space.
B00N - R1024 - Movement - (41.08 SQM)	Not Applicable	Circulation or storage space.
B00N - R1025 - Movement - (14.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R2001 - General Learning Space - (50.79 SQM) - Teaching Space: 1	● Student Space (23)	
B00N - R2009 - Movement - (112.33 SQM)	Not Applicable	Circulation or storage space.
B00N - R2010 - Preparation - (27.81 SQM)	Not Applicable	Circulation or storage space.
B00N - R2011 - Laboratory L.S. - (96.93 SQM) - Teaching Space: 1	● Student Space (44)	
B00N - R2014 - Staff Study - (43.31 SQM)	● Office (10)	
B00N - R2015 - Laboratory L.S. - (95.93 SQM) - Teaching Space: 1	● Student Space (44)	
B00N - R2017 - Preparation - (58.14 SQM)	Not Applicable	Circulation or storage space.
B00N - R2018 - Laboratory L.S. - (95.75 SQM) - Teaching Space: 1	● Student Space (44)	
B00N - R2020 - General Learning Space - (49.1 SQM) - Teaching Space: 1	● Student Space (22)	
B00N - R2021 - Movement - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00N - R2023 - Preparation - (21.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R2024 - Science Laboratory - (100.21 SQM)	● Student Space (46)	
B00N - R2028 - Movement - (19.02 SQM)	Not Applicable	Circulation or storage space.
B00N - R2033 - Movement - (12.31 SQM)	Not Applicable	Circulation or storage space.
B00N - R3001 - Commonroom - (89.67 SQM)	● Office (22)	
B00N - R3004 - Deputy Principal Office - (20.08 SQM)	● Office (5)	
B00N - R3006 - Clinic - Boys - (13.02 SQM)	● Office (3)	
B00N - R3009 - Clinic - Girls - (13.89 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R3010 - Staff Study - (13.88 SQM)	Office (3)	
B00N - R3011 - Staff Study - (11.29 SQM)	Office (2)	
B00N - R3012 - Staff Study - (11.29 SQM)	Office (2)	
B00N - R3013 - Movement - (69.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R3014 - Movement - (16.21 SQM)	Not Applicable	Circulation or storage space.
B00N - R3015 - Pupil Entry - (33.88 SQM)	Not Applicable	Circulation or storage space.
B00N - R3016 - Duplicating Workroom - (26.55 SQM)	Office (6)	
B00N - R3017 - Administration - Clerical - (25.59 SQM)	Office (6)	
B00N - R3018 - Public Entry - (17.5 SQM)	Not Applicable	Circulation or storage space.
B00N - R3020 - Staff Study - (23.66 SQM)	Office (5)	
B00N - R3021 - Ancillary Staff - (23.73 SQM)	Office (5)	
B00N - R3023 - Movement - (11.22 SQM)	Not Applicable	Circulation or storage space.
B00N - R3025 - Interview/Meeting - (13.28 SQM)	Office (3)	
B00N - R3026 - Principal Office - (12.11 SQM)	Office (3)	
B00N - R9001 - Movement - (16.95 SQM)	Not Applicable	Circulation or storage space.
B00N - R9002 - Movement - (28.09 SQM)	Not Applicable	Circulation or storage space.
B00N - R9003 - Design L.S. - (78.36 SQM) - Teaching Space: 1	Student Space (36)	
B00N - R9004 - Staff Study - (29.49 SQM)	Office (7)	
B00N - R9007 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00N - R9009 - Darkroom Space - (31.44 SQM)	Office (7)	
B00N - R9012 - Movement - (11.08 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00P - R0012 - Movement - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00P - R0019 - General Learning Space - S/P - (54.07 SQM) - Teaching Space: 1	Student Space (25)	
B00P - R0020 - Practical Activities - S - 1hb - (23.53 SQM)	Student Space (10)	
B00P - R0021 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00P - R0024 - Commonroom - (25.36 SQM)	Office (6)	
B00P - R0028 - General Learning Space - (51.8 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R0030 - Movement - (5.1 SQM)	Not Applicable	Circulation or storage space.
B00P - R0032 - Commonroom - (17.79 SQM)	Office (4)	
B00P - R0034 - General Learning Space - (84.81 SQM) - Teaching Space: 1	Student Space (39)	
B00P - R0035 - General Learning Space - (51.87 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R0036 - General Learning Space - (51.65 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0038 - Movement - (20.01 SQM)	Not Applicable	Circulation or storage space.
B00P - R0039 - Movement - (50.86 SQM)	Not Applicable	Circulation or storage space.
B00P - R0040 - Movement - (22.49 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Computer Learning Space - (66.84 SQM) - Teaching Space: 1	Student Space (31)	
B00P - R1004 - Commonroom - (25.04 SQM)	Office (6)	
B00P - R1005 - Staff Study - (25.4 SQM)	Office (6)	
B00P - R1006 - General Learning Space - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1007 - General Learning Space - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1008 - General Learning Space - (51.44 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1009 - General Learning Space - (51.37 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R1012 - General Learning Space - (66.19 SQM) - Teaching Space: 1	Student Space (30)	
B00P - R1014 - Movement - (6.73 SQM)	Not Applicable	Circulation or storage space.
B00P - R1018 - Movement - (111.49 SQM)	Not Applicable	Circulation or storage space.
B00P - R9017 - Movement - (29.94 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Gymnasium - (614.98 SQM)	Student Space (285)	
B00T - R0008 - Fitness Laboratory - (90.73 SQM)	Student Space (42)	
B00T - R0011 - Movement - (108.43 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00T - R1001 - General Learning Space - Type 13 - (61.56 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R1002 - General Learning Space - Type 13 - (61.3 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R1003 - Practice/Seminar - (20.93 SQM)	Not Applicable	Circulation or storage space.
B00T - R1004 - Practice/Seminar - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00T - R1006 - Movement - (58.99 SQM)	Not Applicable	Circulation or storage space.
B00T - R9004 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B0AG - R0005 - Movement - (25.65 SQM)	Not Applicable	Circulation or storage space.
BOAS - M0001 - Movement - (22.31 SQM)	Not Applicable	Circulation or storage space.
BOAS - M0002 - Movement - (11.86 SQM)	Not Applicable	Circulation or storage space.
BOAS - M0006 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
BOAS - R0014 - Stage - (139.78 SQM)	Not Applicable	Circulation or storage space.
BOAS - R0016 - Performance Workshop - (237.49 SQM)	● Student Space (110)	
BOAS - R0017 - Performance Workshop - (161.03 SQM)	● Student Space (74)	
BOAS - R0018 - Movement Studio - (135.6 SQM)	Not Applicable	Circulation or storage space.
BOAS - R0022 - Performance Workshop - (159.2 SQM)	● Student Space (73)	
BOAS - R9016 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
NS 100 14347 - NS 100 14347 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 601 10633 - OS 601 10633 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10755 - OS 601 10755 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13876 - OS 601 13876 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15148 - OS 601 15148 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15459 - OS 601 15459 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 18297 - OS 601 18297 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19484 - OS 601 19484 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19785 - OS 601 19785 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 621 10946 - OS 621 10946 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 760 12171 - OS 760 12171 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.