


VENTILATION AUDIT REPORT

SCHOOL:	Denison College of Secondary Education (Kelso) (8517)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Bathurst
LOCAL GOVERNMENT AREA:	Bathurst

8517 - Denison College of Secondary Education (Kelso)
Site Plan (12965)



1:1,689
























Printed: 15-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0001 - Wood Technology Bay - (67.96 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0001 - Clinic - Girls - (14.79 SQM)	Office (3)	
B0AA - R0002 - Deputy Principal - (13.9 SQM)	Office (3)	
B0AA - R0003 - Deputy Principal - (13.56 SQM)	Office (3)	
B0AA - R0004 - Administration - Executive - (15.57 SQM)	Office (3)	
B0AA - R0005 - Principal Office - (19.71 SQM)	Office (4)	
B0AA - R0006 - Principal Office - (19.54 SQM)	Office (4)	
B0AA - R0010 - Interview/Meeting - (25.58 SQM)	Office (6)	
B0AA - R0011 - Visitors Office - (12.52 SQM)	Office (3)	
B0AA - R0012 - Public Reception - (33.14 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0015 - Tea Room - (6.06 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0017 - Movement - (19.38 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0018 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0019 - Administration - Clerical - (55.83 SQM)	Office (13)	
B0AA - R0021 - Movement - (16.88 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0023 - Student Reception - (15.77 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0024 - Interview/Office - Type 2 - (13.46 SQM)	Office (3)	
B0AA - R0025 - Interview/Office - Type 1 - (12.93 SQM)	Office (3)	
B0AA - R0026 - Student Waiting - (5.78 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0027 - Clinic - Boys - (12.86 SQM)	Office (3)	
B0AA - R0029 - Outdoor Learning Area - (25.92 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0008 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0011 - Movement Studio - (158.84 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0023 - Gymnasium - (484.1 SQM)	Student Space (224)	
BOBB - R0026 - Stage - (99.44 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0030 - General Assistants - (12.8 SQM)	Office (3)	
BOFF - R0001 - Staff Study - (144.3 SQM)	Office (36)	
BOFF - R0001 - Staff Study - (144.3 SQM)	Office (36)	
BOFF - R0002 - Staff Lounge - (108.06 SQM)	Office (27)	
BOFF - R0003 - Staff Study - (141.26 SQM)	Office (35)	
BOFF - R0003 - Staff Study - (141.26 SQM)	Office (35)	
BOFF - R0012 - Movement - (60.73 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0014 - Interview/Meeting - (12.96 SQM)	Office (3)	
BOFF - R0015 - Interview/Meeting - (12.99 SQM)	Office (3)	
BOGG - R0001 - General Learning Space - (61.77 SQM) - Teaching Space: 1	Student Space (28)	
BOGG - R0002 - General Learning Space - (62.01 SQM) - Teaching Space: 1	Student Space (28)	
BOGG - R0008 - General Learning Space - (61.51 SQM) - Teaching Space: 1	Student Space (28)	
BOGG - R0009 - General Learning Space - (61.93 SQM) - Teaching Space: 1	Student Space (28)	
BOGG - R0015 - Science Laboratory - (110.83 SQM)	Student Space (51)	
BOGG - R0016 - Preparation - Science - (54.48 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0017 - Science Laboratory - (111.53 SQM)	Student Space (51)	
BOGG - R0018 - Seminar - Type 2 - (38.63 SQM)	Office (9)	
BOHH - R0003 - Design/Technology L.S. - (60.71 SQM) - Teaching Space: 1	Student Space (28)	
BOHH - R0007 - Materials Workshop - Type 2 - (130.9 SQM)	Student Space (60)	
BOHH - R0009 - Materials Workshop - Type 2 - (112.93 SQM)	Student Space (52)	
BOHH - R0010 - Materials Workshop - Type 2 - (118.96 SQM)	Student Space (55)	
BOHH - R0012 - Design/Technology L.S. - (65.58 SQM) - Teaching Space: 1	Student Space (30)	
BOHH - R0015 - Metal Technology Bay - (90.45 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHH - R0021 - Visual Arts Workshop - (100.82 SQM)	Student Space (46)	
BOHH - R0027 - Student Canteen - (48.09 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0028 - General Learning Space - Type 4 - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
BOHH - R0029 - General Learning Space - Type 5 - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0030 - Dark Room - (27.96 SQM)	Office (6)	
BOHH - R0032 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0035 - Wood Technology Bay - (5.9 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R0002 - General Learning Space - Type 1 - (59.65 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0003 - General Learning Space - Type 1 - (60.07 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0004 - General Learning Space - Type 1 - (60.31 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0005 - General Learning Space - Type 1 - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0006 - General Learning Space - Type 1 - (60.15 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0007 - General Learning Space - Type 1 - (59.63 SQM) - Teaching Space: 1	Student Space (27)	
B0JJ - R0008 - Performance Workshop - (101.64 SQM)	Student Space (47)	
B0JJ - R0010 - Practice/Seminar - (21.4 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R0011 - Practice/Seminar - (21.29 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R0013 - Performance Workshop - (102.14 SQM)	Student Space (47)	
B0JJ - R0015 - Seminar - Type 1 - (21.01 SQM)	Office (5)	
B0JJ - R0017 - Fitness Laboratory - (95.72 SQM)	Student Space (44)	
B0KK - R0001 - Computer Learning Space - (68.44 SQM) - Teaching Space: 1	Student Space (31)	
B0KK - R0006 - Seminar - Type 3 - (12.96 SQM)	Office (3)	
B0KK - R0007 - Seminar - Type 3 - (12.96 SQM)	Office (3)	
B0KK - R0008 - Main Area - (245.77 SQM)	Not Applicable	Circulation or storage space.
B0KK - R0012 - Main Entry - (28.06 SQM)	Not Applicable	Circulation or storage space.
B0KK - R0013 - Senior Study - (56.28 SQM)	Office (14)	
B0MM - R0002 - Computer Learning Space - (65.53 SQM) - Teaching Space: 1	Student Space (30)	
B0MM - R0003 - Shared Learning Space - (49.63 SQM)	Student Space (23)	
B0MM - R0007 - General Learning Space - S/P - (65.73 SQM) - Teaching Space: 1	Student Space (30)	
B0MM - R0008 - Practical Activities Area - 2 G.L.S. - (49.8 SQM)	Student Space (23)	
B0MM - R0014 - Movement - (31.64 SQM)	Not Applicable	Circulation or storage space.
B0MM - R0015 - General Learning Space - S/P - (65.56 SQM) - Teaching Space: 1	Student Space (30)	
B0MM - R0018 - General Learning Space - Type 1 - (58.94 SQM) - Teaching Space: 1	Student Space (27)	
B0MM - R0019 - Seminar - Type 1 - (23.81 SQM)	Office (5)	
B0MM - R0020 - General Learning Space - Type 1 - (58.94 SQM) - Teaching Space: 1	Student Space (27)	
B0MM - R0025 - Movement - (56.24 SQM)	Not Applicable	Circulation or storage space.
B0MM - R0026 - Practical Activity Area - (7.75 SQM)	Student Space (3)	
B0PP - R0004 - General Assistants - (15.64 SQM)	Office (3)	
B0PP - R0008 - Serviced Learning Space - (64.46 SQM) - Teaching Space: 1	Student Space (29)	
BOSS - R0001 - Outdoor Workshop - (96.78 SQM)	Not Applicable	Circulation or storage space.
BHHH - R0001 - Kitchen - Type 1 - (100.45 SQM)	Student Space (46)	
BHHH - R0002 - Preparation - Materials - (20.9 SQM)	Not Applicable	Circulation or storage space.
BHHH - R0003 - Kitchen - Type 1 - (100.16 SQM)	Student Space (46)	
BHHH - R0004 - General Learning Space - Type 7 - (60.17 SQM) - Teaching Space: 1	Student Space (27)	
BHHH - R0005 - General Learning Space - Type 6 - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
BHHH - R0006 - Seminar - Type 2 - (19.64 SQM)	Office (4)	
BHHH - R0012 - General Learning Space - Type 7 - (60.19 SQM) - Teaching Space: 1	Student Space (27)	
BHHH - R0013 - General Learning Space - Type 6 - (60.1 SQM) - Teaching Space: 1	Student Space (27)	
BHHH - R0014 - Movement - (16.22 SQM)	Not Applicable	Circulation or storage space.
BNED - R0001 - Computer Learning Space - (65.93 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BNED - R0003 - Shared Learning Space - (43.35 SQM)	 Student Space (20)	
BNED - R0004 - General Learning Space - Type 1 - (61.13 SQM) - Teaching Space: 1	 Student Space (28)	
BNED - R0005 - General Learning Space - Type 1 - (61.21 SQM) - Teaching Space: 1	 Student Space (28)	
BNED - R0006 - Shared Learning Space - (43.35 SQM)	 Student Space (20)	
BNED - R0008 - Computer Learning Space - (65.62 SQM) - Teaching Space: 1	 Student Space (30)	
BNED - R0009 - Seminar - Type 1 - (22.52 SQM)	 Office (5)	
BNED - R0010 - Computer Learning Space - (65.69 SQM) - Teaching Space: 1	 Student Space (30)	
BNED - R0012 - Shared Learning Space - (43.34 SQM)	 Student Space (20)	
BNED - R0013 - General Learning Space - Type 2 - (65.77 SQM) - Teaching Space: 1	 Student Space (30)	
BNED - R0014 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0015 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0016 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0019 - Movement - (83.31 SQM)	Not Applicable	Circulation or storage space.
BNED - R0020 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0021 - General Learning Space - Type 1 - (58.84 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0022 - Seminar - Type 1 - (24.67 SQM)	 Office (6)	
BNED - R0023 - General Learning Space - Type 1 - (58.84 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0026 - Movement - (86.55 SQM)	Not Applicable	Circulation or storage space.
BNED - R0029 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0030 - Seminar - Type 1 - (23.75 SQM)	 Office (5)	
BNED - R0031 - General Learning Space - Type 1 - (58.93 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0032 - General Learning Space - Type 1 - (58.84 SQM) - Teaching Space: 1	 Student Space (27)	
BNED - R0033 - Practical Activity Area - (8.22 SQM)	 Student Space (3)	
BNED - R0034 - Movement - (62.34 SQM)	Not Applicable	Circulation or storage space.
BNED - R0035 - Practical Activity Area - (8.21 SQM)	 Student Space (3)	
BNED - R0036 - Practical Activity Area - (8.19 SQM)	 Student Space (3)	