

VENTILATION AUDIT REPORT

SCHOOL:	Denman Public School (1749)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Muswellbrook



1749 - Denman Public School
Site Plan (10330)



1:830

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (79.66 SQM) - Teaching Space: 1	● Student Space (36)	
B00A - R0003 - Practical Activities - 1hb - (13.41 SQM)	● Student Space (6)	
B00A - R0009 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0010 - Practical Activities - 1hb - (9.61 SQM)	● Student Space (4)	
B00A - R0011 - Home Base - (60.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0012 - Practical Activities - 1hb - (9.64 SQM)	● Student Space (4)	
B00A - R0014 - Entry Vestibule - (11.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (19.68 SQM)	● Office (4)	
B00A - R0016 - Movement - (38.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Clerical Office - (12.57 SQM)	● Office (3)	
B00A - R0018 - Clerical Office - (12.46 SQM)	● Office (3)	
B00A - R0020 - Sick Bay - (8.83 SQM)	● Student Space (4)	
B00A - R0024 - Interview - (12.17 SQM)	● Office (3)	
B00A - R0025 - Staff Room Annexe - (12.53 SQM)	● Office (3)	
B00A - R0026 - Staff Room Annexe - (12.36 SQM)	● Office (3)	
B00A - R0027 - Duplicating Workroom - (12.36 SQM)	● Office (3)	
B00A - R0028 - Staff Room - (40.01 SQM)	● Office (10)	
B00B - R0002 - Withdrawal Space - 1hb - (10.88 SQM)	● Student Space (5)	
B00B - R0004 - Home Base - (53.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Reading Area - (156.04 SQM)	● Student Space (72)	
B00G - R0002 - Canteen - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Practical Activities - 1hb - (16.44 SQM)	● Student Space (7)	
B00G - R0006 - Practical Activities - 1hb - (16.37 SQM)	● Student Space (7)	
B00G - R0007 - Home Base - (61.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0009 - Movement - (13.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Withdrawal Space - 1hb - (12.1 SQM)	● Student Space (5)	
B00G - R0011 - Movement - (14.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Home Base - (61.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0003 - Communal Space - (114.86 SQM)	● Student Space (53)	
B00I - R0002 - Practical Activities - 1hb - (18.99 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (61.19 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0005 - Withdrawal Space - 2hb - (11.67 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (61.23 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0008 - Practical Activities - 1hb - (18.97 SQM)	● Student Space (8)	