

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Movement - (36.85 SQM)	Not Applicable	Circulation or storage space.
B001 - R0004 - Home Base - (64.38 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0005 - Home Base - (50.99 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0006 - Movement - (32.99 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Interview - (13.18 SQM)	● Office (3)	
B001 - R0010 - Home Base - (51.48 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0011 - Home Base - (51.54 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0025 - Duplicating Workroom - (21.04 SQM)	● Office (5)	
B001 - R0026 - Principal - (13.33 SQM)	● Office (3)	
B001 - R0027 - Interview - (13.83 SQM)	● Office (3)	
B001 - R0029 - Entry Vestibule - (20.92 SQM)	Not Applicable	Circulation or storage space.
B001 - R0030 - Clerical Office - (18.04 SQM)	● Office (4)	
B001 - R0031 - Sick Bay - (8.68 SQM)	● Student Space (4)	
B001 - R0036 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
B001 - R0037 - Staff Room - (50.09 SQM)	● Office (12)	
B001 - R0039 - Movement - (95.83 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Reading Area - (172.3 SQM)	● Student Space (79)	
B008 - R0007 - Special Programs Room - Type 2 - (16.65 SQM)	● Student Space (7)	
B008 - R0009 - Special Programs Room - Type 2 - (16.65 SQM)	● Student Space (7)	
B009 - R0001 - Communal Space - (77.26 SQM)	● Student Space (35)	
B009 - R0002 - Movement - (22.01 SQM)	Not Applicable	Circulation or storage space.
B009 - R0003 - Raised Platform - (34.82 SQM)	Not Applicable	Circulation or storage space.
B009 - R0008 - Canteen - (26.32 SQM)	Not Applicable	Circulation or storage space.
B010 - R0001 - Home Base - (59.62 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0003 - Practical Activities - 1hb - (18.3 SQM)	● Student Space (8)	
B010 - R0004 - Withdrawal Space - 2hb - (11.33 SQM)	● Student Space (5)	
B010 - R0005 - Home Base - (59.66 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0007 - Practical Activities - 1hb - (18.33 SQM)	● Student Space (8)	
B010 - R0009 - Home Base - (59.59 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0011 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B010 - R0012 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
B010 - R0013 - Home Base - (59.51 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0015 - Practical Activities - 1hb - (18.2 SQM)	● Student Space (8)	
OS 601 10044 - OS 601 10044 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12263 - OS 601 12263 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14127 - OS 601 14127 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 14063 - OS 602 14063 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	