

VENTILATION AUDIT REPORT

SCHOOL:	Doonside Technology High School (8399)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

8399 - Doonside Technology High School
Site Plan (12474)



1:1,906

Printed: 12-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Study - (25.91 SQM)	Office (6)	
B00A - R0003 - Laboratory L.S. - (85.94 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0006 - Laboratory L.S. - (86.75 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0010 - Food Technology L.S. - (66.03 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0018 - Staff Study - (25.92 SQM)	Office (6)	
B00A - R0021 - Movement - (120.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Food/Research Space - (17.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Food Technology L.S. - (91.26 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0030 - Preparation - Science - (38.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Laboratory L.S. - (79.21 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1005 - General Learning Space - (65.7 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1008 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1011 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - Movement - (113.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Staff Study - (47.79 SQM)	Office (11)	
B00B - M0002 - Movement - (127.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - General Assistants - (20.05 SQM)	Office (5)	
B00B - R0004 - Movement - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (139.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Student Canteen - (38.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Gymnasium - (87.51 SQM)	Student Space (40)	
B00B - R0035 - Movement - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Gymnasium - (48.35 SQM)	Student Space (22)	
B00C - R0004 - Materials Technology L.S. - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0008 - Materials Technology L.S. - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0013 - Staff Study - (25.19 SQM)	Office (6)	
B00C - R0015 - Materials Technology L.S. - (78.98 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0022 - Movement - (119.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Materials Technology L.S. - (93.08 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0032 - Materials Technology L.S. - (76.9 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R1002 - Computer Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1003 - Design L.S. - (39.05 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R1007 - Music Learning Space - (49.27 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1008 - Practice/Seminar - (12.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Performance Workspace - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1016 - Art Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1017 - Art Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1025 - Movement - (30.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R1026 - Movement - (20.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R1027 - Movement - (30.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R1028 - Movement - (33.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R1031 - Art Learning Space - (66.11 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1032 - Staff Study - (42.61 SQM)	Office (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1033 - Darkroom Space - (22.03 SQM)	Office (5)	
B00D - R0007 - Public Entry - (46.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Administration - Clerical - (25.77 SQM)	Office (6)	
B00D - R0012 - Principal Office - (19.15 SQM)	Office (4)	
B00D - R0015 - Administration - Clerical - (12.74 SQM)	Office (3)	
B00D - R0018 - Deputy Principal Office - (19.29 SQM)	Office (4)	
B00D - R0021 - Duplicating Workroom - (24.92 SQM)	Office (6)	
B00D - R0025 - Movement - (61.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Movement - (19.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0032 - Staff Study - (32.8 SQM)	Office (8)	
B00D - R0033 - Commonroom - (103.42 SQM)	Office (25)	
B00D - R0034 - Staff Kitchen - (10.89 SQM)	Office (2)	
B00D - R0036 - Staff Study - (15.83 SQM)	Office (3)	
B00D - R0042 - Movement - (62.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0045 - Computer Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0046 - Deputy Principal Office - (19.33 SQM)	Office (4)	
B00D - R0047 - Computer Learning Space - (52.93 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0048 - Public Reception - (19.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0049 - Administration - Clerical - (57.97 SQM)	Office (14)	
B00D - R0050 - Staff Study - (25.92 SQM)	Office (6)	
B00D - R0053 - Movement - (52.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0054 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Assistants - (5.73 SQM)	Office (1)	
B00D - R1002 - Movement - (15.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1006 - General Learning Space - (65.7 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1007 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - Staff Study - (47.91 SQM)	Office (11)	
B00D - R1012 - Movement - (106.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Computer Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1015 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1016 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1019 - General Learning Space - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1020 - Senior Study - (61.66 SQM)	Office (15)	
B00E - R0001 - Laboratory L.S. - (92.96 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0004 - Laboratory L.S. - (92.96 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0005 - Computer Learning Space - (66.02 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0007 - Movement - (130.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Special Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0011 - Special Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0012 - Special Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0014 - Staff Study - (25 SQM)	Office (6)	
B00E - R0022 - Staff Study - (25.99 SQM)	Office (6)	
B00E - R0023 - Seminar - Type 1 - (25.99 SQM)	Office (6)	
B00E - R0025 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Preparation - Science - (32.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1005 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1011 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1014 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1015 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1016 - General Learning Space - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1017 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1018 - Staff Study - (25.01 SQM)	● Office (6)	
B00E - R1021 - Movement - (120.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Staff Study - (52.7 SQM)	● Office (13)	
B00E - R1025 - General Learning Space - (39.36 SQM) - Teaching Space: 1	● Student Space (18)	
B00E - R1026 - Movement - (7.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Entry - (70.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Staff Kitchen - (17.57 SQM)	● Office (4)	
B00F - R0020 - Movement - (14.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Stage - (111.61 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Multi-Purpose Space - (450.09 SQM)	● Student Space (208)	
B00G - R0002 - Staff Study - (34.64 SQM)	● Office (8)	
B00G - R0004 - Workroom - (40.5 SQM)	● Office (10)	
B00G - R0005 - Entry - (16.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Seminar - (13.39 SQM)	● Office (3)	
B00G - R0011 - Seminar - (20.71 SQM)	● Office (5)	
B00G - R0012 - Main Area - (406.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (5.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Metal Technology Bay - (164.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Metal Technology Bay - (84.62 SQM)	Not Applicable	Circulation or storage space.
OS 601 14703 - OS 601 14703 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	