


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Dorchester School (5454)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Campbelltown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

5454 - Dorchester School  
Site Plan (11237)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room Annexe - (7.44 SQM)	Office (1)	
B00A - R0003 - Staff Room Annexe - (7.44 SQM)	Office (1)	
B00A - R0004 - Interview - (7.44 SQM)	Office (1)	
B00A - R0005 - Movement - (16.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Interview - (11.12 SQM)	Office (2)	
B00A - R0009 - Clerical Office - (18.5 SQM)	Office (4)	
B00A - R0012 - Principal - (18.3 SQM)	Office (4)	
B00A - R0013 - Entry Vestibule - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Room Annexe - (10.26 SQM)	Office (2)	
B00B - R0001 - Staff Room - (44.59 SQM)	Office (11)	
B00B - R0004 - Home Base - (66.96 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0005 - Special Programs Room - (57.82 SQM)	Student Space (26)	
B00B - R0010 - Reading Area - (14.62 SQM)	Student Space (6)	
B00B - R0011 - Reading Area - (42.4 SQM)	Student Space (19)	
B00B - R0014 - Home Base - (66.8 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0019 - Practical Activities - 1hb - (13.36 SQM)	Student Space (6)	
B00B - R0020 - Home Base - (39.06 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0022 - Home Base - (41.45 SQM) - Teaching Space: 1	Student Space (19)	
B00B - R0023 - Practical Activities - 1hb - (11.55 SQM)	Student Space (5)	
B00B - R0026 - Practical Activities - 1hb - (12.43 SQM)	Student Space (5)	
B00B - R0027 - Home Base - (40.21 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0028 - Movement - (182.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (33.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Raised Platform - (96.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Communal Space - (193.8 SQM)	Student Space (89)	
B00C - R0007 - Movement - (34.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (95.14 SQM)	Not Applicable	Circulation or storage space.