


VENTILATION AUDIT REPORT

SCHOOL:	Dorrigo High School (8453)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Bellingen

8453 - Dorrigo High School
Site Plan (11744)



1:542

Printed: 02-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (18.33 SQM)	Office (4)	
B00A - R0002 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0003 - General Learning Space - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0004 - Senior Study - (22.36 SQM)	Office (5)	
B00A - R0005 - Serviced Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0006 - Design L.S. - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0011 - Food Technology L.S. - (88.82 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0014 - General Learning Space - (48.79 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0029 - Commonroom - (38.2 SQM)	Office (9)	
B00A - R0041 - Materials Technology L.S. - (65.34 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0042 - Staff Study - (25.55 SQM)	Office (6)	
B00A - R0045 - Staff Study - (22.16 SQM)	Office (5)	
B00A - R0046 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0047 - General Learning Space - (52.93 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0048 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Movement - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Movement - (314.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Duplicating Workroom - (15.72 SQM)	Office (3)	
B00A - R0061 - Movement - (8.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Staff Study - (39.15 SQM)	Office (9)	
B00A - R0065 - Performance Workspace - (62.37 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0066 - Multi-Purpose Space - (162.96 SQM)	Student Space (75)	
B00A - R0068 - Student Canteen - (30.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0071 - Staff Study - (39.34 SQM)	Office (9)	
B00A - R0072 - Art Learning Space - (97.44 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R0073 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R021A - Stage - (36.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R9008 - Darkroom Space - (24.24 SQM)	Office (6)	
B00A - R9009 - Workshop - (73.56 SQM)	Student Space (34)	
B00A - R9010 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Laboratory L.S. - (91.71 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0002 - Laboratory L.S. - (91.7 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0003 - General Learning Space - (58.69 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0004 - Preparation - (43.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Staff Study - (7.65 SQM)	Office (1)	
B00B - R0012 - Movement - (150.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1004 - Seminar - (12.6 SQM)	Office (3)	
B00B - R1005 - Workroom - (12.78 SQM)	Office (3)	
B00B - R1006 - Interview/Office - Type 1 - (12.97 SQM)	Office (3)	
B00B - R1009 - Workroom - (8.16 SQM)	Office (2)	
B00B - R1010 - Workroom - (11.24 SQM)	Office (2)	
B00B - R1011 - Main Area - (191.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R1012 - Movement - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Seminar - (13.03 SQM)	Office (3)	
B00C - R0008 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Seminar - (33.45 SQM)	Office (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0010 - Staff Study - (17.49 SQM)	Office (4)	
B00D - R0004 - Movement - (37.51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Metal Technology Bay - (125.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0033 - Movement - (8.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Workshop Area - (177.31 SQM)	Student Space (82)	
B00E - R0036 - Staff Kitchen - (23.61 SQM)	Office (5)	
B00E - R0037 - Seminar/Technology Space - (40.95 SQM)	Office (10)	
B00F - R0006 - Music Learning Space - (68.33 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0009 - Practice/Seminar - (26.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Learning Space - (55.83 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0003 - Movement - (17 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Interview/Office - Type 1 - (12.78 SQM)	Office (3)	
B00L - R0002 - Interview/Office - Type 1 - (14.06 SQM)	Office (3)	
B00L - R0003 - Public Entry - (18.85 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Administration - Clerical - (38.36 SQM)	Office (9)	
B00L - R0006 - Movement - (25.44 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Interview/Office - Type 1 - (10.88 SQM)	Office (2)	
B00L - R0008 - Public Entry - (22.33 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Clinic - Girls - (8.94 SQM)	Office (2)	
B00L - R0011 - Clinic - Boys - (8.94 SQM)	Office (2)	
B00L - R0012 - Deputy Principal Office - (13.31 SQM)	Office (3)	
B00L - R0013 - Administration - Clerical - (8.21 SQM)	Office (2)	
B00L - R0014 - Principal Office - (19.67 SQM)	Office (4)	
B00L - R0018 - Commonroom - (5.16 SQM)	Office (1)	
B00L - R0020 - Movement - (69.45 SQM)	Not Applicable	Circulation or storage space.