


VENTILATION AUDIT REPORT

SCHOOL:	Dorrigo Public School (7316)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Bellingen

7316 - Dorrigo Public School
Site Plan (13343)









1:1,102

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (143.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (19.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (12.07 SQM)	Office (3)	
B00A - R0004 - Duplicating Workroom - (21.45 SQM)	Office (5)	
B00A - R0005 - Sick Bay - (9.28 SQM)	Student Space (4)	
B00A - R0006 - Deputy Principal - (12.14 SQM)	Office (3)	
B00A - R0007 - Deputy Principal - (12.25 SQM)	Office (3)	
B00A - R0008 - Teachers Aide Special Ed - (11.61 SQM)	Office (2)	
B00A - R0011 - Principal - (18.48 SQM)	Office (4)	
B00A - R0014 - Staff Room - (48.54 SQM)	Office (12)	
B00A - R0015 - Movement - (178.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Communal Space - (169.98 SQM)	Student Space (78)	
B00A - R0017 - Raised Platform - (43.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Canteen - (30.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (147.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Teachers Aide Special Ed - (11.66 SQM)	Office (2)	
B00A - R0038 - Teachers Aide Special Ed - (12.18 SQM)	Office (3)	
B00A - R0040 - Special Programs Room - (35.53 SQM)	Student Space (16)	
B00A - R0041 - Special Programs Room - (35.53 SQM)	Student Space (16)	
B00A - R0042 - Teachers Aide Special Ed - (24.81 SQM)	Office (6)	
B00A - R0043 - Practical Activities - 1hb - (133.84 SQM)	Student Space (62)	
B00A - R0046 - Movement - (22.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Home Base - (56.19 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0051 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00A - R0052 - Home Base - (56.52 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0054 - Home Base - (56.26 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0056 - Withdrawal Space - 1hb - (12.22 SQM)	Student Space (5)	
B00A - R0057 - Home Base - (55.92 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0059 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0061 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Movement - (10.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Movement - (22.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Movement - (67.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Movement - (10.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0072 - Withdrawal Space - 1hb - (12.22 SQM)	Student Space (5)	
B00A - R0073 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0075 - Movement - (10.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0076 - Movement - (169.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Movement - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0079 - Movement - (10.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0080 - Home Base - (56.86 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0082 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00A - R0083 - Home Base - (56.86 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0085 - Movement - (10.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0086 - Home Base - (56.18 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0088 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0089 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0090 - Home Base - (56.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0091 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0094 - Movement - (16.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0097 - Home Base - (56.05 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0099 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0100 - Withdrawal Space - 1hb - (12.18 SQM)	 Student Space (5)	
B00A - R0101 - Home Base - (55.9 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0103 - Movement - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0105 - Movement - (74.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0120 - Special Programs Room - (5.91 SQM)	 Student Space (2)	
B00A - R0122 - Reading Area - (127.31 SQM)	 Student Space (59)	
B00B - R0002 - Movement - (48.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (8.48 SQM)	Not Applicable	Circulation or storage space.