

VENTILATION AUDIT REPORT

SCHOOL:	Drummond Memorial Public School (1058)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

1058 - Drummond Memorial Public School
Site Plan (12477)



1:1,237

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Communal Space - (135.87 SQM)	● Student Space (63)	
B00A - R0003 - Raised Platform - (24.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Canteen - (17.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0020 - Duplicating Workroom - (11.5 SQM)	● Office (2)	
B00A - R0023 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Interview - (8.39 SQM)	● Office (2)	
B00A - R0032 - Entry Vestibule - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Clerical Office - (19.08 SQM)	● Office (4)	
B00A - R0035 - Sick Bay - (6.92 SQM)	● Student Space (3)	
B00A - R0036 - Principal - (17.31 SQM)	● Office (4)	
B00A - R0038 - Withdrawal Space - 1hb - (12.67 SQM)	● Student Space (5)	
B00A - R0039 - Withdrawal Space - 1hb - (12.67 SQM)	● Student Space (5)	
B00A - R0040 - Home Base - (79.35 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0002 - Movement - (88.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Special Programs Room - (7.5 SQM)	● Student Space (3)	
B00B - R0007 - Movement - (5.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Interview - (12.64 SQM)	● Office (3)	
B00B - R0012 - Home Base - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0021 - Home Base - (52.41 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0023 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (9.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Staff Room Annexe - (5.51 SQM)	● Office (1)	
B00B - R0032 - Staff Room Annexe - (5.82 SQM)	● Office (1)	
B00B - R0035 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0036 - Home Base - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0037 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Staff Room Annexe - (25.62 SQM)	● Office (6)	
B00B - R0040 - Staff Kitchen - (6.96 SQM)	● Office (1)	
B00C - R0001 - Reading Area - (167.66 SQM)	● Student Space (77)	
B00C - R0006 - Movement - (28.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Special Programs Room - (41.77 SQM)	● Student Space (19)	
B00E - R0004 - Staff Room - (49.67 SQM)	● Office (12)	
B00E - R0009 - Movement - (35.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Deputy Principal - (15.77 SQM)	● Office (3)	
B00E - R0012 - Movement - (69.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Home Base - (62.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0016 - Home Base - E - (40.75 SQM) - Teaching Space: 1	● Student Space (18)	
B00E - R0018 - Practical Activities - E - (15.5 SQM)	● Student Space (7)	
B00E - R0020 - Home Base - (75.58 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0003 - Movement - (41.61 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (82.26 SQM) - Teaching Space: 1	● Student Space (38)	
B00F - R0007 - Home Base - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0013 - Home Base - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0014 - Staff Room Annexe - (6.66 SQM)	● Office (1)	
B00F - R0015 - Special Programs Room - (6.69 SQM)	● Student Space (3)	
B00H - R0003 - Home Base - (65.34 SQM) - Teaching Space: 1	● Student Space (30)	