

VENTILATION AUDIT REPORT

SCHOOL:	Dubbo College Senior Campus (8110)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

8110 - Dubbo College Senior Campus
Site Plan (14625)



1:1,634

Printed: 21-Mar-2020


















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0001 - Seminar - Type 2 - (20.32 SQM)	Office (5)	
B00J - R0003 - General Learning Space - Type 3 - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0004 - General Learning Space - Type 3 - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0010 - General Learning Space - Type 3 - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0011 - General Learning Space - Type 3 - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0012 - General Learning Space - Type 3 - (59.45 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0013 - General Learning Space - Type 3 - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0014 - Science Laboratory - (99.73 SQM)	Student Space (46)	
B00J - R0015 - Science Laboratory - (99.63 SQM)	Student Space (46)	
B00J - R0016 - Preparation - Science - (49.96 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Science Laboratory - (99.02 SQM)	Student Space (45)	
B00J - R0018 - Movement - (244.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Movement Studio - (157.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Gymnasium - (619.73 SQM)	Student Space (287)	
B00K - R0029 - Stage - (95.43 SQM)	Not Applicable	Circulation or storage space.
B00K - R0033 - Movement - (264.74 SQM)	Not Applicable	Circulation or storage space.
B00K - R0034 - Movement - (15.3 SQM)	Not Applicable	Circulation or storage space.
B00K - R0035 - Movement - (72.47 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (20.92 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - General Learning Space - Type 2 - (65.1 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R0003 - Shared Learning Space - (116.84 SQM)	Student Space (54)	
B00L - R0004 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0005 - General Learning Space - Type 2 - (65.01 SQM) - Teaching Space: 1	Student Space (30)	
B00L - R0006 - Movement - (25.29 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Shared Learning Space - (111.91 SQM)	Student Space (51)	
B00L - R0008 - General Learning Space - Type 1 - (59.33 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0010 - Seminar - Type 1 - (24.03 SQM)	Office (6)	
B00L - R0011 - General Learning Space - Type 1 - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0012 - General Learning Space - Type 1 - (59.24 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0013 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0017 - Seminar - Type 1 - (24.61 SQM)	Office (6)	
B00L - R0018 - General Learning Space - Type 1 - (59.17 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0019 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0020 - General Learning Space - Type 1 - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0025 - Movement - (140.05 SQM)	Not Applicable	Circulation or storage space.
B00L - R0026 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0027 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - General Learning Space - Type 1 - (57.74 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0004 - General Learning Space - Type 1 - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R0006 - Seminar - Type 2 - (20.02 SQM)	Office (5)	
B00M - R0007 - Fitness Laboratory - (98.65 SQM)	Student Space (45)	
B00M - R0010 - General Learning Space - Type 1 - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0011 - Shared Learning Space - (112.29 SQM)	Student Space (52)	
B00M - R0012 - General Learning Space - Type 2 - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0013 - Movement - (21.5 SQM)	Not Applicable	Circulation or storage space.
B00M - R0017 - General Learning Space - Type 1 - (58.84 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0018 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0019 - General Learning Space - Type 1 - (59.25 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0020 - Seminar - Type 1 - (24.03 SQM)	Office (6)	
B00M - R0023 - Movement - (269.84 SQM)	Not Applicable	Circulation or storage space.
B00M - R0024 - Movement - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Movement - (16.13 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - General Assistants - (49.06 SQM)	Office (12)	
B00Q - R0001 - General Assistants - (13.36 SQM)	Office (3)	
B00S - R0002 - Preparation - Materials - (17.87 SQM)	Not Applicable	Circulation or storage space.
B00S - R0004 - Food Technology L.S. - (110.93 SQM) - Teaching Space: 1	Student Space (51)	
B00S - R0007 - Food/Research Space - (54.04 SQM)	Not Applicable	Circulation or storage space.
B00S - R0009 - Hospitality Space - (48.86 SQM)	Student Space (22)	
B00T - R0001 - Welding Area - (20.6 SQM)	Not Applicable	Circulation or storage space.
B00T - R0002 - Workshop Area - (210.11 SQM)	Student Space (97)	
B00T - R0003 - Materials Technology L.S. - (38.06 SQM) - Teaching Space: 1	Student Space (17)	
B00T - R0005 - Workshop Area - (80.88 SQM)	Student Space (37)	
B00T - R0006 - Materials Technology L.S. - (51.4 SQM) - Teaching Space: 1	Student Space (23)	
B0AA - R0001 - Clinic - Girls - (13.07 SQM)	Office (3)	
B0AA - R0002 - Interview/Office - Type 1 - (13.07 SQM)	Office (3)	
B0AA - R0003 - Student Reception - (41.75 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0006 - Clinic - Boys - (13 SQM)	Office (3)	
B0AA - R0007 - Interview/Office - Type 1 - (13.08 SQM)	Office (3)	
B0AA - R0008 - Interview/Office - Type 2 - (13.08 SQM)	Office (3)	
B0AA - R0009 - Deputy Principal Office - (15.12 SQM)	Office (3)	
B0AA - R0010 - Student Waiting - (12.67 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0012 - Administration - Clerical - (67.45 SQM)	Office (16)	
B0AA - R0015 - Principal Office - (20.28 SQM)	Office (5)	
B0AA - R0019 - Tea Room - (5.11 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0021 - Interview/Meeting - (13.24 SQM)	Office (3)	
B0AA - R0022 - Interview/Meeting - (13.2 SQM)	Office (3)	
B0AA - R0023 - Public Reception - (20.32 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0024 - Visitors Office - (15.04 SQM)	Office (3)	
B0AA - R0025 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0026 - Movement - (17.41 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0027 - Movement - (38.93 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0001 - Seminar - Type 3 - (12.95 SQM)	Office (3)	
BOBB - R0002 - Seminar - Type 3 - (13.54 SQM)	Office (3)	
BOBB - R0003 - Seminar - Type 3 - (13.58 SQM)	Office (3)	
BOBB - R0004 - Main Area - (407.83 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0006 - Computer Learning Space - (65.21 SQM) - Teaching Space: 1	Student Space (30)	
BOBB - R0011 - Main Entry - (22.04 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0012 - Computer Learning Space - (65.68 SQM) - Teaching Space: 1	Student Space (30)	
BOBB - R0017 - Movement - (35.06 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0018 - Movement - (25.12 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0001 - Lecture Space - (100.17 SQM) - Teaching Space: 2	Student Space (46)	
BOCC - R0003 - Movement - (64.87 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0004 - General Learning Space - Type 2 - (65.04 SQM) - Teaching Space: 1	Student Space (30)	
BOCC - R0005 - Practical Activity Area - (70.46 SQM)	Student Space (32)	
BOCC - R0012 - General Learning Space - S/P - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
BOCC - R0013 - General Learning Space - S/P - (60.27 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCC - R0017 - General Learning Space - S/P - (60.18 SQM) - Teaching Space: 1	Student Space (27)	
BOCC - R0020 - Movement - (137.29 SQM)	Not Applicable	Circulation or storage space.
BODD - R0002 - Student Canteen - (51.78 SQM)	Not Applicable	Circulation or storage space.
BODD - R0011 - Movement - (331.64 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0003 - Dark Room - (26.83 SQM)	Office (6)	
BOEE - R0004 - Visual Arts Workshop - (100.57 SQM)	Student Space (46)	
BOEE - R0006 - Materials Workshop - Type 2 - (120.33 SQM)	Student Space (55)	
BOEE - R0010 - General Learning Space - Type 9 - (58.89 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0011 - General Learning Space - Type 8 - (58.85 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0013 - General Learning Space - Type 5 - (58.75 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0014 - General Learning Space - Type 4 - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0015 - Outdoor Workshop - (89.63 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0017 - Welding/Hot Metals Area - (12.05 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0023 - Movement - (249.32 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0001 - General Learning Space - Type 1 - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
BOFF - R0002 - General Learning Space - Type 1 - (56.27 SQM) - Teaching Space: 1	Student Space (26)	
BOFF - R0003 - Performance Workshop - (100.61 SQM)	Student Space (46)	
BOFF - R0004 - Practice/Seminar - (19.78 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0007 - General Learning Space - Type 6 - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
BOFF - R0008 - General Learning Space - Type 7 - (58.9 SQM) - Teaching Space: 1	Student Space (27)	
BOFF - R0009 - Seminar - Type 2 - (20.06 SQM)	Office (5)	
BOFF - R0014 - Preparation - Materials - (24.38 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0015 - Kitchen - Type 1 - (99.03 SQM)	Student Space (45)	
BOFF - R0017 - Movement - (205.62 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0001 - Movement - (77.76 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0002 - Staff Study - (240.89 SQM)	Office (60)	
BOGG - R0003 - Staff Lounge - (108.11 SQM)	Office (27)	
BOGG - R0004 - Staff Study - (229.92 SQM)	Office (57)	
BOGG - R0005 - Interview/Meeting - (13.19 SQM)	Office (3)	
BOGG - R0006 - Interview/Meeting - (13.27 SQM)	Office (3)	
BOGG - R0015 - Interview/Meeting - (13.2 SQM)	Office (3)	
BOGG - R0016 - Interview/Meeting - (13.18 SQM)	Office (3)	
BOGG - R0024 - Materials Technology L.S. - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
BOGG - R0029 - Outdoor Workshop - (150.01 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0032 - Materials Workshop - Type 2 - (219.24 SQM)	Student Space (101)	
BOGG - R0033 - Materials Technology L.S. - (55.78 SQM) - Teaching Space: 1	Student Space (25)	
BOHH - R0001 - Movement - (21.7 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0002 - General Learning Space - Type 2 - (65.02 SQM) - Teaching Space: 1	Student Space (30)	
BOHH - R0003 - Shared Learning Space - (116.67 SQM)	Student Space (54)	
BOHH - R0004 - General Learning Space - Type 1 - (59.25 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0005 - General Learning Space - Type 2 - (64.85 SQM) - Teaching Space: 1	Student Space (30)	
BOHH - R0006 - Movement - (25.34 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0007 - Shared Learning Space - (112.12 SQM)	Student Space (52)	
BOHH - R0008 - General Learning Space - Type 1 - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0010 - Seminar - Type 1 - (23.9 SQM)	Office (5)	
BOHH - R0011 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0012 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0013 - General Learning Space - Type 1 - (59.17 SQM) - Teaching Space: 1	Student Space (27)	
BOHH - R0017 - Seminar - Type 1 - (24.58 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHH - R0018 - General Learning Space - Type 1 - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
BOHH - R0019 - General Learning Space - Type 1 - (59.19 SQM) - Teaching Space: 1	 Student Space (27)	
BOHH - R0020 - General Learning Space - Type 1 - (59.26 SQM) - Teaching Space: 1	 Student Space (27)	
BOHH - R0025 - Movement - (137.36 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0026 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0027 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
BOII - R0001 - Movement - (20.83 SQM)	Not Applicable	Circulation or storage space.
BOII - R0002 - General Learning Space - Type 2 - (65.01 SQM) - Teaching Space: 1	 Student Space (30)	
BOII - R0003 - Shared Learning Space - (116.74 SQM)	 Student Space (54)	
BOII - R0004 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0005 - General Learning Space - Type 2 - (64.86 SQM) - Teaching Space: 1	 Student Space (30)	
BOII - R0006 - Movement - (25.23 SQM)	Not Applicable	Circulation or storage space.
BOII - R0007 - Shared Learning Space - (112.26 SQM)	 Student Space (52)	
BOII - R0008 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0010 - Seminar - Type 1 - (23.9 SQM)	 Office (5)	
BOII - R0011 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0012 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0013 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0017 - Seminar - Type 1 - (24.58 SQM)	 Office (6)	
BOII - R0018 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0019 - General Learning Space - Type 1 - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0020 - General Learning Space - Type 1 - (59.11 SQM) - Teaching Space: 1	 Student Space (27)	
BOII - R0025 - Movement - (137.98 SQM)	Not Applicable	Circulation or storage space.
BOII - R0026 - Movement - (18.24 SQM)	Not Applicable	Circulation or storage space.
BOII - R0027 - Movement - (18.25 SQM)	Not Applicable	Circulation or storage space.