

VENTILATION AUDIT REPORT

SCHOOL:	Dubbo North Public School (1776)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

1776 - Dubbo North Public School
Site Plan (11138)



1:944

Printed: 03-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (67.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (6.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Home Base - (58.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0007 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office/Workroom - (18.73 SQM)	● Office (4)	
B00A - R0011 - Duplicating Workroom - (14.45 SQM)	● Office (3)	
B00A - R0012 - Sick Bay - (10 SQM)	● Student Space (4)	
B00A - R0018 - Clerical Office - (13.5 SQM)	● Office (3)	
B00A - R0019 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Entry Vestibule - (15.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Clerical Office - (17 SQM)	● Office (4)	
B00B - R0001 - Home Base - (46.79 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0002 - Home Base - (46.86 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0003 - Home Base - (47.32 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0004 - Home Base - (47.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0006 - Movement - (64.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Interview - (14.77 SQM)	● Office (3)	
B00B - R0011 - Staff Room Annexe - (11.04 SQM)	● Office (2)	
B00C - R0004 - Canteen - (23.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Withdrawal Space - 1hb - (10.89 SQM)	● Student Space (5)	
B00C - R0008 - Movement - (5.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (66.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Home Base - (63.44 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0011 - Practical Activities - 1hb - (21.8 SQM)	● Student Space (10)	
B00D - R0001 - Staff Room Annexe - (13 SQM)	● Office (3)	
B00D - R0005 - Withdrawal Space - 1hb - (18.85 SQM)	● Student Space (8)	
B00D - R0007 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (80.39 SQM) - Teaching Space: 1	● Student Space (37)	
B00D - R0011 - Withdrawal Space - 1hb - (15.86 SQM)	● Student Space (7)	
B00E - R0002 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (55.77 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0004 - Home Base - (57.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0006 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (40.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (41.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (14.79 SQM)	● Student Space (6)	
B00F - R0003 - Home Base - (70.39 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R0007 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Special Programs Room - (41.6 SQM)	● Student Space (19)	
B00F - R0010 - Practical Activities - 1hb - (14.63 SQM)	● Student Space (6)	
B00G - R0004 - Movement - (103.4 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Reading Area - (159.27 SQM)	● Student Space (73)	
B00M - R0005 - Staff Room Annexe - (20.04 SQM)	● Office (5)	
B00M - R0009 - Movement - (44.12 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Staff Kitchen - (13.06 SQM)	● Office (3)	
B00M - R0011 - Staff Room - (34.48 SQM)	● Office (8)	
B00N - R0013 - Communal Space - (145.26 SQM)	● Student Space (67)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0014 - Raised Platform - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00N - R0018 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
OS 601 11456 - OS 601 11456 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13788 - OS 601 13788 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14177 - OS 601 14177 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	