

VENTILATION AUDIT REPORT

SCHOOL:	Dubbo School of Distance Education (4587)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

4587 - Dubbo School of Distance Education
Site Plan (10337)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (162.29 SQM)	Office (40)	
B00A - R0010 - Principal - (20.41 SQM)	Office (5)	
B00A - R0011 - Deputy Principal - (12.89 SQM)	Office (3)	
B00A - R0012 - Clerical Office - (12.84 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (12.94 SQM)	Office (3)	
B00A - R0014 - Entry Vestibule - (36.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (75.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Sick Bay - (14.3 SQM)	Student Space (6)	
B00A - R0026 - Clerical Office/Workroom - (81.47 SQM)	Office (20)	
B00B - R0002 - Staff Room Annexe - (276.11 SQM)	Office (69)	
B00B - R0007 - Clerical Office/Workroom - (56.83 SQM)	Office (14)	
B00C - R0010 - Workroom - (13.81 SQM)	Office (3)	
B00C - R0012 - Audio Visual Workroom - (12.91 SQM)	Student Space (5)	
B00C - R0014 - General Learning Space - (46.31 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0016 - Audio Visual Workroom - (18.41 SQM)	Student Space (8)	
B00C - R0017 - Audio Visual Workroom - (18.47 SQM)	Student Space (8)	
B00C - R0018 - Audio Visual Workroom - (18.47 SQM)	Student Space (8)	
B00C - R0019 - Audio Visual Workroom - (9 SQM)	Student Space (4)	
B00C - R0020 - Audio Visual Workroom - (8.8 SQM)	Student Space (4)	
B00C - R0031 - Seminar/Study - (26.12 SQM)	Office (6)	
B00C - R0032 - Reading Area - (332.3 SQM)	Student Space (154)	
B00G - R0008 - Staff Study - (359.11 SQM)	Office (89)	
B00H - R0012 - Darkroom Space - (28.4 SQM)	Office (7)	
B00H - R0017 - Art Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0019 - Materials Workshop - Type 2 - (12.88 SQM)	Student Space (5)	
B00H - R0021 - Materials Workshop - Type 2 - (17.4 SQM)	Student Space (8)	
B00H - R0022 - Workshop Area - (53.68 SQM)	Student Space (24)	
B00H - R0023 - Materials Workshop - Type 3 - (25.51 SQM)	Student Space (11)	
B00H - R0025 - Food/Research Space - (27.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0037 - Metal Technology Bay - (60.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0038 - Staff Kitchen - (7.17 SQM)	Office (1)	
B00H - R0039 - Interview/Office - Type 1 - (15.5 SQM)	Office (3)	
B00H - R0040 - Interview/Office - Type 1 - (15.5 SQM)	Office (3)	
B00H - R0041 - Interview/Office - Type 2 - (50.35 SQM)	Office (12)	
B00H - R0045 - Practical Activities - 1hb - (62.06 SQM)	Student Space (28)	
B00H - R0046 - Withdrawal Space - 1hb - (8.97 SQM)	Student Space (4)	
B00H - R0048 - Practical Activities - 1hb - (11.37 SQM)	Student Space (5)	
B00M - R0002 - Home Base - Pre - (77.97 SQM) - Teaching Space: 1	Student Space (36)	
B00R - R0002 - Practical Activities - 1hb - (19.38 SQM)	Student Space (8)	
B00R - R0004 - Home Base - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	Student Space (4)	
B00R - R0006 - Home Base - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0008 - Practical Activities - 1hb - (19.38 SQM)	Student Space (8)	
B00W - R0001 - Home Base - (50.35 SQM)	Student Space (23)	
B00W - R0002 - Practical Activities - (6.09 SQM)	Student Space (2)	
B00Y - R0001 - Home Base X3 - (176.59 SQM) - Teaching Space: 3	Student Space (81)	
B00Y - R0002 - Practical Activities - (6.09 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Y - R0006 - Breakout Area - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0007 - Breakout Area - (11.81 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0014 - Outdoor Learning Area - (87.81 SQM)	Not Applicable	Circulation or storage space.
B00Y - R0016 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
OS 600 10235 - OS 600 10235 - Learning Unit - Small - (57 SQM)	● Student Space (26)	