

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Dubbo West Public School (3591)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Dubbo</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Dubbo</b>

3591 - Dubbo West Public School  
Site Plan (10959)



1.823

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (53.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0002 - Home Base - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0003 - Staff Room Annexe - (22.16 SQM)	● Office (5)	
B00A - R0006 - Deputy Principal - (12.35 SQM)	● Office (3)	
B00A - R0011 - Interview - (12.35 SQM)	● Office (3)	
B00A - R0012 - Sick Bay - (8.91 SQM)	● Student Space (4)	
B00A - R0013 - Clerical Office - (12.74 SQM)	● Office (3)	
B00A - R0014 - Duplicating Workroom - (19.58 SQM)	● Office (4)	
B00A - R0015 - Principal - (16.24 SQM)	● Office (4)	
B00A - R0019 - Movement - (56.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (106.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Staff Room - (53.35 SQM)	● Office (13)	
B00A - R0027 - Staff Kitchen - (13.52 SQM)	● Office (3)	
B00B - R0002 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (58.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0005 - Home Base - M - (58.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0007 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Practical Activities - 1hb - (29.17 SQM)	● Student Space (13)	
B00C - R0003 - Home Base - (54.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0004 - Practical Activities - 1hb - (19.72 SQM)	● Student Space (9)	
B00C - R0005 - Practical Activities - 1hb - (19.71 SQM)	● Student Space (9)	
B00C - R0006 - Home Base - (53.94 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0014 - Movement - (26.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Home Base - (69.13 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R0017 - Movement - (56.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Home Base - (56.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1012 - Withdrawal Space - 1hb - (8.54 SQM)	● Student Space (3)	
B00C - R1013 - Practical Activities - 3hb - (25.66 SQM)	● Student Space (11)	
B00C - R1014 - Withdrawal Space - 1hb - (8.63 SQM)	● Student Space (4)	
B00C - R1015 - Practical Activities/Movement - 4hb - (110.4 SQM)	● Student Space (51)	
B00C - R1016 - Home Base - (54.66 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1020 - Home Base - (57.63 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1021 - Home Base - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1022 - Practical Activities - (13.58 SQM)	● Student Space (6)	
B00C - R1023 - Home Base - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1024 - Practical Activities - (14.11 SQM)	● Student Space (6)	
B00C - R1025 - Movement - (22.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (33.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Special Programs Room - (44.04 SQM)	● Student Space (20)	
B00F - R0003 - Special Programs Room - (44.37 SQM)	● Student Space (20)	
B00G - R0001 - Special Programs Room - (51 SQM)	● Student Space (23)	
B00G - R0002 - Movement - (9.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (57 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0006 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Home Base - (56.86 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0012 - Movement - (50.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Canteen - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Communal Space - (203.75 SQM)	● Student Space (94)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0002 - Raised Platform - (61.38 SQM)	Not Applicable	Circulation or storage space.
B00P - R0024 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00P - R0025 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0003 - Reading Area - (164.46 SQM)	● Student Space (76)	
B00R - R0001 - Special Programs Room - (32.4 SQM)	● Student Space (15)	
B00U - R0003 - Home Base - Pre - (108.06 SQM) - Teaching Space: 1	● Student Space (50)	
B00U - R0006 - Interview - (13.08 SQM)	● Office (3)	
B00U - R0007 - Entry Vestibule - (12.07 SQM)	Not Applicable	Circulation or storage space.
OS 534 10688 - OS 534 10688 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 602 14431 - OS 602 14431 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14925 - OS 602 14925 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12720 - OS 603 12720 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19078 - OS 606 19078 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19078 - OS 606 19078 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19078 - OS 606 19078 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19078 - OS 606 19078 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19078 - OS 606 19078 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	