

VENTILATION AUDIT REPORT

SCHOOL:	Dudley Public School (1778)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Charlestown
LOCAL GOVERNMENT AREA:	Lake Macquarie

1778 - Dudley Public School
Site Plan (10960)



1:1,077

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (97.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Deputy Principal - (15 SQM)	Office (3)	
B00A - R0003 - Principal - (22.21 SQM)	Office (5)	
B00A - R0004 - Entry Vestibule - (26.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Duplicating Workroom - (12.71 SQM)	Office (3)	
B00A - R0006 - Movement - (23.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Interview - (12.64 SQM)	Office (3)	
B00A - R0018 - Movement - (30.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Canteen - (17.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (57.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Raised Platform - (16.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Communal Space - (124.52 SQM)	Student Space (57)	
B00A - R0032 - Movement - (61.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Clerical Office - (24.62 SQM)	Office (6)	
B00A - R1001 - Movement - (78.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Staff Room - (62.27 SQM)	Office (15)	
B00A - R1003 - Practical Activities - 1hb - (14.76 SQM)	Student Space (6)	
B00A - R1004 - Home Base - (58.15 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1005 - Practical Activities - 1hb - (13.32 SQM)	Student Space (6)	
B00A - R1006 - Home Base - (52.12 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - Movement - (10.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Seminar/Study - (13.38 SQM)	Office (3)	
B00A - R1016 - Reading Area - (160.11 SQM)	Student Space (74)	
B00A - R1017 - Special Programs Room - (50.26 SQM)	Student Space (23)	
B00B - R0003 - Practical Activities - 1hb - (10.04 SQM)	Student Space (4)	
B00B - R0004 - Practical Activities - 1hb - (7.64 SQM)	Student Space (3)	
B00B - R0005 - Home Base - (105.92 SQM) - Teaching Space: 1	Student Space (49)	
B00C - R0001 - Movement - (24.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (44.53 SQM) - Teaching Space: 1	Student Space (20)	
B00C - R0003 - Movement - (28.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Seminar/Study - (22.73 SQM)	Office (5)	
B00C - R0005 - Home Base - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Practical Activities - 1hb - (25.88 SQM)	Student Space (12)	
B00C - R0007 - Home Base - (52.34 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Practical Activities - 1hb - (25.74 SQM)	Student Space (11)	
B00C - R0009 - Movement - (36.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Home Base - (49.91 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0011 - Practical Activities - 1hb - (15.99 SQM)	Student Space (7)	
B00C - R0012 - Practical Activities - 1hb - (16.52 SQM)	Student Space (7)	
B00C - R0013 - Home Base - (49.97 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0002 - Communal Space - (143.28 SQM)	Student Space (66)	
B00D - R0003 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Raised Platform - (60.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (14.46 SQM)	Not Applicable	Circulation or storage space.
OS 601 10335 - OS 601 10335 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 12453 - OS 602 12453 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12926 - OS 602 12926 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	